

| Date       | Time        | Bldg#  | Building Name                      | Bldg Type        | Nature Of Event | Device Location                      | Cause  |
|------------|-------------|--------|------------------------------------|------------------|-----------------|--------------------------------------|--|
| 12/6/2018  | 6:45:00 PM  | 121    | Villa Del Puente                   | RESIDENTIAL - R2 | False Alarm     | Pod space 209/211                    | Steam from shower.   |
| 12/4/2018  | 10:00:00 AM | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm     | Smoke detector-Rec room 102          | Cooking  |
| 12/3/2018  | 6:40:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm     | Room 214                             | Student microwaved tin foil. Event Number from UAPD #V183370031  |
| 12/1/2018  | 3:37:00 PM  | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm     | Room 108                             | Burnt popcorn set off detector.  |
| 12/1/2018  | 8:20:00 PM  | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm     | Room 856                             | Burnt food set off detector  |
| 12/1/2018  | 2:40:00 PM  | 85a    | La Aldea                           | RESIDENTIAL - R2 | False Alarm     | Room 324b                            | Burnt food set off detector  |
| 12/1/2018  | 12:15:00 PM | 131    | Likins Hall                        | RESIDENTIAL - R2 | False Alarm     | Room 459                             | UAPD responded to reset the fire panel after a faulty detector was set off in LKNS-459.  |
| 11/20/2018 | 3:00:00 AM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm     | Room 820                             | Unknown  |
| 11/18/2018 | 1:20:00 PM  | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm     | In 326                               | Unknown  |
| 11/17/2018 | 5:05:00 PM  | 5      | Coconino Residence Hall            | RESIDENTIAL - R2 | False Alarm     | 1st floor pull station               | Unknown  |
| 11/17/2018 | 11:51:00 AM | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm     | In 822                               | Unknown  |
| 11/16/2018 | 8:28:00 PM  | 151    | Babcock                            | RESIDENTIAL - R2 | False Alarm     | D317                                 | Unknown  |
| 11/15/2018 | 10:15:00 PM | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm     | room 838                             | Fire alarm going off in 838 but turned off when UAPD got to room. No known cause for trigger.  |
| 11/15/2018 | 1:15:00 PM  | 135    | Pima Residence Hall                | RESIDENTIAL - R2 | False Alarm     | By room 106                          | Burnt food   |
| 11/14/2018 | 12:29:00 PM | 7/7a   | Manzanita/Mohave Residence Halls   | RESIDENTIAL - R2 | False Alarm     | By room353                           | May have been hit or bumped  |
| 11/13/2018 | 7:15:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm     | In room 816                          | Contacts were dirty on smoke head.   |
| 11/13/2018 | 4:20:00 PM  | 118    | Colonia De La Paz Residence Hall   | RESIDENTIAL - R2 | False Alarm     | Room c205                            | Fire alarm activated due to burnt food from microwave.   |
| 11/11/2018 | 10:55:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm     | Room 304                             | TFD and UAPD responded, no one was in the room. UAPD disarmed the alarm.   |
| 11/7/2018  | 12:00:00 AM | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm     | room 746                             | Residents burnt popcorn in room  |
| 11/5/2018  | 7:40:00 PM  | 79/79a | Huachuca/Kaibab Residence Hall     | RESIDENTIAL - R2 | False Alarm     | Kitchen                              | Possibility of a pot of beans in kitchen.  |
| 11/4/2018  | 3:29:00 PM  | 10     | Yuma Residence hall                | RESIDENTIAL - R2 | False Alarm     | Room 302                             | A resident accidentally hit the fire alarm in the dorm study room, causing the alarm to sound and UAPD to be called but did not respond. |
| 10/29/2018 | 8:30:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm     | 304                                  | Resident was straightening her hair and set off the alarm.   |
| 10/28/2018 | 2:40:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm     | Room 308                             | Resident was straightening her hair and set off the alarm.   |
| 10/27/2018 | 8:20:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm     | In room - 2nd floor                  | Smoke detector possibly triggered by vaping.   |
| 10/24/2018 | 8:25:00 PM  | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm     | Room 112                             | Flat iron.   |
| 10/23/2018 | 8:30:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm     | Kitchen                              | Cooking  |
| 10/18/2018 | 11:05:00 AM | 9      | Maricopa Residence Hall            | RESIDENTIAL - R2 | Nuisance Alarm  | Room 214                             | Device was tampered with   |
| 10/18/2018 | 12:30:00 PM | 59/60  | Stadium Complex - Pinal/Navajo     | RESIDENTIAL - R2 | False Alarm     | Navajo/Pinal                         | It is unclear why the alarm went off at the Stadium since we were located in Navajo Pinal.   |
| 10/17/2018 | 9:10:00 PM  | 135    | Pima Residence Hall                | RESIDENTIAL - R2 | False Alarm     | Room 207                             | Resident using air fryer   |
| 10/14/2018 | 1:00:00 AM  | 79/79a | Huachuca/Kaibab Residence Hall     | RESIDENTIAL - R2 | False Alarm     | Room 302                             | Building fire alarm possibly due to burnt popcorn.   |
| 10/11/2018 | 2:43:00 PM  | 85a    | La Aldea                           | RESIDENTIAL - R2 | False Alarm     | 1st flr building H-I handicap rm 121 | Burnt food   |
| 10/10/2018 | 12:20:00 AM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm     | Room 304                             | Room alarm set off due to resident's straightening hair.   |

|           |             |        |                                    |                  |             |                                 |   |
|-----------|-------------|--------|------------------------------------|------------------|-------------|---------------------------------|---|
| 10/8/2018 | 8:35:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 371                        | Building alarm activated due to burnt popcorn.  |
| 10/8/2018 | 9:45:00 PM  | 121    | Villa Del Puente                   | RESIDENTIAL - R2 | False Alarm | Room 341                        | Room alarm activated due to steaming sheets in room.  |
| 10/5/2018 | 3:31:00 PM  | 10     | Yuma Residence hall                | RESIDENTIAL - R2 | False Alarm | 1st floor by kitchen            | By student burning potatoe cakes in skillet   |
| 10/5/2018 | 3:30:00 PM  | 10     | Yuma Residence hall                | RESIDENTIAL - R2 | False Alarm | Kitchen                         | Smoke from cooking in dorm kitchen.   |
| 10/5/2018 | 11:53:00 AM | 132    | Arbol De La Vida                   | RESIDENTIAL - R2 | False Alarm | In room A208                    | Burnt popcorn   |
| 10/2/2018 | 11:55:00 PM | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm | Room 204                        | Cause unknown   |
| 10/1/2018 | 1:45:00 PM  | 59/60  | Stadium Complex - Pinal/Navajo     | RESIDENTIAL - R2 | False Alarm | NA                              | Unknown   |
| 10/1/2018 | 4:20:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | Kitchen                         | Burnt popcorn in kitchen.   |
| 10/1/2018 | 6:30:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | Kitchen                         | Smoke in the kitchen from cooking.  |
| 10/1/2018 | 4:55:00 PM  | 121    | Villa Del Puente                   | RESIDENTIAL - R2 | False Alarm | El Portal                       | False alarm was triggered in the south building of Villa del Puente due to fire alarm set off in El Portal. |
| 10/1/2018 | 7:40:00 PM  | 121    | Villa Del Puente                   | RESIDENTIAL - R2 | False Alarm | El Portal                       | False fire alarm occurred in the south building of Villa del Puente.  |
| 10/1/2018 | 3:04:00 PM  | 182    | El Portal                          | RESIDENTIAL - R2 | False Alarm | Level 1 elevator lobby          | Condensation from the rain was collecting on the detector, and causing the false alarms.                    |
| 9/30/2018 | 8:13:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 118                        | Air freshner set off smoke detector   |
| 9/23/2018 | 10:40:00 PM | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm | Room 106                        | Unknown cause of alarm  |
| 9/22/2018 | 2:00:00 PM  | 9      | Maricopa Residence Hall            | RESIDENTIAL - R2 | False Alarm | 316                             | Outlet sparking when hair dryer plugged in.   |
| 9/19/2018 | 10:15:00 PM | 31     | Cochise Residence Hall             | RESIDENTIAL - R2 | Drill       | na                              | Fire drill  |
| 9/17/2018 | 8:14:00 AM  | 59/60  | Stadium Complex - Pinal/Navajo     | RESIDENTIAL - R2 | False Alarm | Stadium Construction Zone       | Construction  |
| 9/17/2018 | 11:36:00 AM | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 5th floor in room 520           | Resident was cooking food in the microwave , the food was wrapped in aluminum foil.                         |
| 9/17/2018 | 7:00:00 AM  | 118    | Colonia De La Paz Residence Hall   | RESIDENTIAL - R2 | False Alarm | L230                            | Smoke detector  |
| 9/16/2018 | 8:24:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | 353                             | Residents had a candle.   |
| 9/13/2018 | 6:20:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | Drill       | na                              | Fire drill  |
| 9/13/2018 | 1:33:00 AM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 9th floor                       | Fire alarm on the 9th floor was activated but UAPD couldn't find out where or why.                          |
| 9/13/2018 | 6:30:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | Drill       | na                              | Fire drill  |
| 9/13/2018 | 10:40:00 AM | 377    | Rawls Eller Lodge                  | RESIDENTIAL - R2 | Drill       | na                              | Fire drill  |
| 9/10/2018 | 9:37:00 PM  | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm | Room 646                        | Alarm activated by burnt popcorn  |
| 9/9/2018  | 10:50:00 AM | 131    | Likins Hall                        | RESIDENTIAL - R2 | False Alarm | CD Apartment                    | Fire alarm set off in CD apartment.   |
| 9/6/2018  | 4:05:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Kitchen in basement             | Cooking in kitchen  |
| 9/3/2018  | 5:10:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Kitchen                         | Smoke from cooking - no other details provided.   |
| 8/30/2018 | 11:34:00 AM | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm | 1st floor by West center stairs | Residents were cooking bacon, smoke from the bacon set off the smoke detector                               |
| 8/29/2018 | 8:35:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 411                             | Alarm activated by opening bag of popcorn under smoke detector  |
| 8/27/2018 | 7:20:00 PM  | 10     | Yuma Residence hall                | RESIDENTIAL - R2 | False Alarm | Kitchen                         | Cooking burger.   |
| 8/27/2018 | 12:21:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | 1ST FLR SANTA CRUZ IN 183       | Steam iron for clothes  |

|           |             |        |                                  |                  |                |   |   |
|-----------|-------------|--------|----------------------------------|------------------|----------------|---|---|
| 8/26/2018 | 7:50:00 PM  | 83/84  | Sonora/Arizona Residence Halls   | RESIDENTIAL - R2 | False Alarm    | 706   | Clothing steamer  |
| 8/26/2018 | 7:50:00 PM  | 83/84  | Sonora/Arizona Residence Halls   | RESIDENTIAL - R2 | False Alarm    | 706   | Clothing steamer. UAPD Case # V182380068  |
| 8/25/2018 | 5:55:00 PM  | 85     | Coronado Residence hall          | RESIDENTIAL - R2 | False Alarm    | 758   | Burnt toast   |
| 8/25/2018 | 10:51:00 PM | 131    | Likins Hall                      | RESIDENTIAL - R2 | False Alarm    | 550   | Burnt popcorn   |
| 8/23/2018 | 10:30:00 AM | 151    | Babcock                          | RESIDENTIAL - R2 | Nuisance Alarm | 2nd floor in room B203 (Smoke detector) no answer | Trouble alarm was cause by the removal of the smoke sensor from its base.   |
| 8/17/2018 | 5:00:00 PM  | 132    | Arbol De La Vida                 | RESIDENTIAL - R2 | False Alarm    | A430  | Alarm in a dorm room went off due to a burnt pop tart.  |
| 8/16/2018 | 9:45:00 AM  | 151    | Babcock                          | RESIDENTIAL - R2 | False Alarm    | Room B-203  | Dirty smoke contacts.   |
| 8/14/2018 | 8:00:00 AM  | 59/60  | Stadium Complex - Pinal/Navajo   | RESIDENTIAL - R2 | False Alarm    | Navajo/Pinal                                      | Construction  |
| 8/14/2018 | 8:58:00 PM  | 151    | Babcock                          | RESIDENTIAL - R2 | False Alarm    | B203  | Smoke detector  |
| 8/6/2018  | 1:14:00 PM  | 122    | Posada San Pedro                 | RESIDENTIAL - R2 | False Alarm    | Heat Detector, bottom of elev shaft               | Determined that custodial had been using a hose to wash down outdoor corridors and got water in the elevator shaft getting the device wet.  |
| 7/29/2018 | 7:25:00 PM  | 85a    | La Aldea                         | RESIDENTIAL - R2 | False Alarm    | In room 405 bed room smoke detector               | Low battery alarm   |
| 7/20/2018 | 6:58:00 AM  | 85     | Coronado Residence hall          | RESIDENTIAL - R2 | False Alarm    | Basement heat over 4160 Transformer               | Contractor work heat from ambient air   |
| 7/20/2018 | 9:57:00 AM  | 85a    | La Aldea                         | RESIDENTIAL - R2 | False Alarm    | In handicap room 100                              | Contractors resumed working in the room. Upon arrival there was a worker, wearing a respirator because of the dust he was creating, scraping the floor. I instructed them they are to not work any more and to leave campus for the day. Informed them they are wasting state resources by activating Fire Safety, UAPD and TFD for |
| 7/20/2018 | 9:29:00 AM  | 85a    | La Aldea                         | RESIDENTIAL - R2 | False Alarm    | In room 100                                       | Contractors working on floor.   |
| 7/18/2018 | 12:35:00 PM | 85a    | La Aldea                         | RESIDENTIAL - R2 | False Alarm    | In handicap room 100                              | Contractors were cutting a hole in the quartz countertop to install a sink  |
| 7/17/2018 | 11:20:00 AM | 7/7a   | Manzanita/Mohave Residence Halls | RESIDENTIAL - R2 | False Alarm    | 5th floor elevator lobby                          | Res life is moving new mattresses in, possibly hit detector with one  |
| 7/14/2018 | 6:05:00 PM  | 79/79a | Huachuca/Kaibab Residence Hall   | RESIDENTIAL - R2 | Nuisance Alarm | na  | Fire alarm went off due to cover being lifted.  |
| 7/13/2018 | 9:35:00 PM  | 79/79a | Huachuca/Kaibab Residence Hall   | RESIDENTIAL - R2 | Nuisance Alarm | na  | Fire alarm due to cover being lifted.   |
| 7/13/2018 | 1:43:00 PM  | 132    | Arbol De La Vida                 | RESIDENTIAL - R2 | False Alarm    | Building D LVL 3 Room D304                        | Candle in room  |
| 7/11/2018 | 7:45:00 PM  | 9      | Maricopa Residence Hall          | RESIDENTIAL - R2 | False Alarm    | na  | Conference guest burnt food   |
| 6/27/2018 | 1:48:00 PM  | 85a    | La Aldea                         | RESIDENTIAL - R2 | False Alarm    | 4th Floor Building C Water Flow                   | Contractor Lloyd Construction hit and broke sprinkler head. Superintendent Chris Velasquez shut down the 4th floor tamper himself preventing water from flowing.  |
| 6/12/2018 | 7:10:00 PM  | 123    | Pueblo De La Cienega             | RESIDENTIAL - R2 | False Alarm    | 2nd floor   | It was discovered that a Med Start Facilitator and a Med Start Counselor had engaged in a sage burning Native American ceremony within the building without notifying UAPD or Residential Life.   |
| 6/10/2018 | 11:14:00 AM | 85     | Coronado Residence hall          | RESIDENTIAL - R2 | False Alarm    | 5th floor in room 507 smoke detector              | Dirty smoke sensor (M5-7)   |
| 6/4/2018  | 1:33:00 PM  | 79/79a | Huachuca/Kaibab Residence Hall   | RESIDENTIAL - R2 | False Alarm    | 3rd floor Kaibab by room 321                      | Sanding in rooms contractor IFS James is the supervisor outside contractor  |

|           |             |        |                                    |                  |             |                                     |   |
|-----------|-------------|--------|------------------------------------|------------------|-------------|-------------------------------------|---|
| 5/25/2018 | 1:10:00 AM  | 121    | Villa Del Puente                   | RESIDENTIAL - R2 | False Alarm | Elevator electrical room            | Elevator electrical room was filled with smoke  |
| 5/22/2018 | 2:24:00 PM  | 122    | Posada San Pedro                   | RESIDENTIAL - R2 | False Alarm | Level 1 in room 137                 | Contractors   |
| 5/21/2018 | 12:47:00 PM | 132    | Arbol De La Vida                   | RESIDENTIAL - R2 | False Alarm | Room A222/D221                      | Dusting   |
| 5/10/2018 | 2:27:00 PM  | 52/53  | Greenlee/Graham Residence Halls    | RESIDENTIAL - R2 | False Alarm | 1st floor by room 127               | dryer #13 burning hot caused smoke and strong burning smell in laundry room   |
| 5/5/2018  | 2:00:00 AM  | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm | Room 636                            | Unknown   |
| 5/3/2018  | 10:26:00 AM | 121    | Villa Del Puente                   | RESIDENTIAL - R2 | False Alarm | In room 161                         | Curling iron had residue on it that started smoking.  |
| 5/2/2018  | 11:35:00 AM | 118    | Colonia De La Paz Residence Hall   | RESIDENTIAL - R2 | False Alarm | In room B116                        | Resident was making a cookie in the microwave and it burnt  |
| 4/30/2018 | 10:00:00 AM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Santa Cruz west hall smoke detector | Smoke detector base   |
| 4/28/2018 | 10:00:00 AM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | na                                  | Unknown cause of fire alarm activation.   |
| 4/24/2018 | 6:30:00 PM  | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm | Room 300                            | UAPD gave the all clear, and stated that an air freshener may have been the cause of the alarm.                         |
| 4/24/2018 | 9:18:00 PM  | 132    | Arbol De La Vida                   | RESIDENTIAL - R2 | False Alarm | E319                                | Burnt food in microwave   |
| 4/14/2018 | 2:35:00 AM  | 7/7a   | Manzanita/Mohave Residence Halls   | RESIDENTIAL - R2 | False Alarm | Hallway                             | Source unknown  |
| 4/14/2018 | 2:19:00 AM  | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm | na                                  | Someone pulled pull station no location provided  |
| 4/14/2018 | 9:00:00 AM  | 57     | Hopi Lodge Residence Hall          | RESIDENTIAL - R2 | False Alarm | By janitor room 21                  | Student cooking in kitchen (Hot cooking oil)  |
| 4/12/2018 | 9:46:00 PM  | 121    | Villa Del Puente                   | RESIDENTIAL - R2 | False Alarm | Kitchen                             | Burnt food  |
| 4/6/2018  | 1:09:00 AM  | 57     | Hopi Lodge Residence Hall          | RESIDENTIAL - R2 | False Alarm | Room 6                              | Student vaping in room  |
| 4/4/2018  | 8:45:00 PM  | 31     | Cochise Residence Hall             | RESIDENTIAL - R2 | False Alarm | Room 300                            | Possible vaping by resident   |
| 4/1/2018  | 11:57:00 PM | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | Laundry room 11                     | Overfull lint trap in laundry room  |
| 3/28/2018 | 1:33:00 AM  | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm | 6th Floor                           | Fire extinguisher discharged  |
| 3/27/2018 | 9:10:00 PM  | 151    | Babcock                            | RESIDENTIAL - R2 | False Alarm | B110                                | Burnt popcorn   |
| 3/26/2018 | 9:29:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | Kitchen                             | Burnt food in kitchen   |
| 3/25/2018 | 7:00:00 AM  | 151    | Babcock                            | RESIDENTIAL - R2 | False Alarm | Smoke in room c307                  | Found smoke detector cover off and broken, inner cover off and bent and base off the wall and screws bent.              |
| 3/20/2018 | 7:18:00 AM  | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm | Room 625                            | Steam for iron for clothing   |
| 3/15/2018 | 1:00:00 PM  | 132    | Arbol De La Vida                   | RESIDENTIAL - R2 | False Alarm | Room C223                           | Humidifier  |
| 3/14/2018 | 9:45:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 505                                 | Burnt food in microwave   |
| 3/14/2018 | 4:25:00 PM  | 132    | Arbol De La Vida                   | RESIDENTIAL - R2 | False Alarm | C223                                | Air conditioning unit   |
| 3/13/2018 | 4:20:00 PM  | 132    | Arbol De La Vida                   | RESIDENTIAL - R2 | False Alarm | D308                                | Resident burnt food in microwave.   |
| 3/12/2018 | 4:15:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 425                                 | Resident using vape pen.  |
| 3/12/2018 | 1:13:00 PM  | 151    | Babcock                            | RESIDENTIAL - R2 | False Alarm | In room D311                        | Occupant using steam aroma diffuser   |
| 3/8/2018  | 2:50:00 PM  | 59/60  | Stadium Complex - Pinal/Navajo     | RESIDENTIAL - R2 | False Alarm | Sierra Waterflow monitor            | Contractors opened a valve for a part of the system they thought was deactivated. System still has water and is active. |
| 3/8/2018  | 10:35:00 PM | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm | 522                                 | Burnt food in microwave.  |
| 3/4/2018  | 3:37:00 PM  | 7/7a   | Manzanita/Mohave Residence Halls   | RESIDENTIAL - R2 | False Alarm | Kitchen                             | Smoke in kitchen. Source not identified in report.  |
| 3/2/2018  | 9:02:00 PM  | 10     | Yuma Residence hall                | RESIDENTIAL - R2 | False Alarm | Room 344                            | Students vaping in room   |
| 3/1/2018  | 12:48:00 PM | 7/7a   | Manzanita/Mohave Residence Halls   | RESIDENTIAL - R2 | False Alarm | By room 327                         | Window and door to the bathroom was open creating a breeze  |



|           |             |        |                                    |                  |             |                                   |  |
|-----------|-------------|--------|------------------------------------|------------------|-------------|-----------------------------------|--|
| 2/27/2018 | 3:00:00 PM  | 7/7a   | Manzanita/Mohave Residence Halls   | RESIDENTIAL - R2 | False Alarm | 3rd floor by room 327             | air freshener was sprayed in hall  |
| 2/27/2018 | 7:40:00 AM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 4th floor West stair entrance     | Someone discharged a fire extinguisher in the West stair well on the 4th floor   |
| 2/26/2018 | 9:20:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 715                               | Unknown  |
| 2/24/2018 | 7:01:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | 110                               | Burnt hair from curling iron   |
| 2/24/2018 | 9:20:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 1st floor east wing               | Cotton candy machine began to smoke  |
| 2/24/2018 | 10:11:00 PM | 132    | Arbol De La Vida                   | RESIDENTIAL - R2 | False Alarm | A215                              | Residents vaping in room   |
| 2/23/2018 | 8:55:00 AM  | 135    | Pima Residence Hall                | RESIDENTIAL - R2 | False Alarm | 1st floor in room 116 south       | Resident was cooking bacon and caused the smoke detector to go in to alarm   |
| 2/20/2018 | 10:40:00 PM | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 607                               | Burnt popcorn  |
| 2/18/2018 | 3:10:00 AM  | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm | Basement                          | Pull-station - unknown   |
| 2/18/2018 | 3:10:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | FACP                              | Unknown  |
| 2/16/2018 | 5:44:00 PM  | 7/7a   | Manzanita/Mohave Residence Halls   | RESIDENTIAL - R2 | False Alarm | 2nd floor manzanita by room 226   | Cause unknown. UAPD had not reset the pull station.  |
| 2/16/2018 | 2:52:00 PM  | 151    | Babcock                            | RESIDENTIAL - R2 | False Alarm | 3rd flr in room D314              | foot warmer in microwave gave off sent and steam   |
| 2/15/2018 | 1:21:00 PM  | 57     | Hopi Lodge Residence Hall          | RESIDENTIAL - R2 | False Alarm | N. Side in hall by janitors rm 21 | Cooking in kitchen - burnt food  |
| 2/15/2018 | 8:39:00 AM  | 151    | Babcock                            | RESIDENTIAL - R2 | False Alarm | By room B110                      | Device got wet and shorted   |
| 2/14/2018 | 5:30:00 PM  | 8      | Gila Residence Hall                | RESIDENTIAL - R2 | False Alarm | Kitchen                           | Cooking smoke  |
| 2/14/2018 | 2:12:00 PM  | 151    | Babcock                            | RESIDENTIAL - R2 | False Alarm | In room B304                      | Resident says he pulled something steamy out of the microwave and set off the smoke detector, what was observed was a haze in the room with a strong smell of cherry vape in the room, resident denies |
| 2/4/2018  | 4:26:00 PM  | 31     | Cochise Residence Hall             | RESIDENTIAL - R2 | False Alarm | Basement lounge                   | Steam from popcorn machine   |
| 2/4/2018  | 7:47:00 PM  | 118    | Colonia De La Paz Residence Hall   | RESIDENTIAL - R2 | False Alarm | Room A207                         | Burnt cookies  |
| 1/29/2018 | 8:10:00 AM  | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm | Room 644                          | Student using hand held hair straightener  |
| 1/24/2018 | 3:23:00 PM  | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm | In room 229                       | UAPD suspected an e-cigarette  |
| 1/20/2018 | 5:00:00 AM  | 7/7a   | Manzanita/Mohave Residence Halls   | RESIDENTIAL - R2 | False Alarm | 4th floor                         | Unknown  |
| 1/20/2018 | 7:15:00 PM  | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | 2nd floor                         | Student set off a fire extinguisher.   |
| 1/18/2018 | 12:00:00 AM | 34     | Yavapai Residence Hall             | RESIDENTIAL - R2 | False Alarm | Room 318                          | Residents vaping in room. Case V180170099  |
| 1/14/2018 | 11:58:00 AM | 85     | Coronado Residence hall            | RESIDENTIAL - R2 | False Alarm | In room 941                       | Unknown  |
| 1/13/2018 | 10:29:00 PM | 57     | Hopi Lodge Residence Hall          | RESIDENTIAL - R2 | False Alarm | 51                                | Nuisance alarm in a students room.   |
| 1/13/2018 | 10:00:00 PM | 83/84  | Sonora/Arizona Residence Halls     | RESIDENTIAL - R2 | False Alarm | Kitchen                           | Burnt food in kitchen  |
| 1/12/2018 | 9:55:00 PM  | 10     | Yuma Residence hall                | RESIDENTIAL - R2 | False Alarm | 215                               | Burnt pasta in resident room   |
| 1/9/2018  | 6:40:00 PM  | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Kitchen                           | Cooking  |
| 1/9/2018  | 6:40:00 PM  | 151    | Babcock                            | RESIDENTIAL - R2 | False Alarm | D315                              | Resident was blow drying her hair and set off the alarm.   |
| 1/8/2018  | 10:15:00 PM | 7/7a   | Manzanita/Mohave Residence Halls   | RESIDENTIAL - R2 | False Alarm | na                                | Dust, no location provided.  |
| 1/7/2018  | 6:30:00 PM  | 135    | Pima Residence Hall                | RESIDENTIAL - R2 | False Alarm | Laundry Room                      | Resident overfilled washer which caused it to smoke.   |

|          |            |     |                  |                  |             |              |  |
|----------|------------|-----|------------------|------------------|-------------|--------------|--|
| 1/1/2018 | 4:50:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | D300 Hallway | During winter closure, a hallway lightbulb overheated and causing smoke to occur and set off alarm |
|----------|------------|-----|------------------|------------------|-------------|--------------|--|