

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/30/2009	12:45:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Trouble	na	AC power rocking in and out of trouble
12/30/2009	9:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	2nd floor	Dirty smoke sensor
12/8/2009	2:21:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor Navajo	Burning muffins in oven on 3rd floor. Oven had been reported as malfunctioning on several occasions per RA and had been cleared by Residence life, area needs to be reviewed for possible addition
12/4/2009	12:32:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Stairwell 1st floor Huachuca	Unknown
12/3/2009	7:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	3rd floor	Smoke sensor base in 333
11/16/2009	12:24:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	Bldg. 52 1st floor	Dirty smoke sensor
11/1/2009	9:55:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Students cooking in kitchen
10/30/2009	7:47:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kaibab 2nd	Unknown
10/28/2009	8:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	na	Unknown
10/26/2009	4:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Emergency Evacuation	4th floor	Fire extinguisher
10/16/2009	3:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Lobby Sonora side elevator	Someone may have hit sprinkler head
10/16/2009	1:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Basement elevator	System Failure
10/6/2009	11:55:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	5th floor	Unknown
10/2/2009	10:38:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor	Per UAPD vacume cleaner overheated
10/1/2009	4:35:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Level 2 east stairwell	Dirty smoke detector
10/1/2009	12:45:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2E	Unknown
9/30/2009	11:40:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2E	Pull-station pulled
9/30/2009	10:58:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona basement	Smoke detector set off fire alarm
9/29/2009	8:43:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen 1st floor	Burnt food
9/23/2009	7:24:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/23/2009	7:30:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/23/2009	7:52:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Risk Management fire drill

9/15/2009	7:25:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/15/2009	9:40:00 PM	59/60/61	Pinal/Navajo/Siera Residence Halls	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/15/2009	8:46:00 PM	79/79a	Huachuca/Kaiba Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/15/2009	6:35:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/15/2009	6:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill of the semester
9/12/2009	11:00:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen room 109	Burnt pancakes
9/9/2009	3:15:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor south	Face plate of pull-station came loose and off the wall
9/8/2009	1:05:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B107 hallway	Unknown
9/7/2009	12:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	9th floor Arizona	Unknown
9/3/2009	8:04:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management Fire drill
9/3/2009	7:25:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
9/3/2009	8:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/3/2009	8:35:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/3/2009	9:50:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	Student section	Risk Management fire drill
9/2/2009	12:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	na	Pull-station
9/1/2009	9:42:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 221	Dirty smoke
9/1/2009	9:43:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Outside room 221	Defective device
9/1/2009	7:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Outside room 221	Smoke detector
8/29/2009	11:43:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	1st floor lobby	Unknown
8/23/2009	8:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	na	Fire drill
8/18/2009	7:09:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor, East wing	Burn food
8/16/2009	11:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	11th floor	Elevator brake shoes locked up
8/7/2009	9:40:00 AM	59/60/61	Pinal/Navajo/Siera Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor	Shop vacume set off alarm

6/24/2009	10:10:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	na	Student hit smoke detector with mattress
6/18/2009	8:53:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	1st floor	Dirty smoke
6/17/2009	9:35:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor	Residence Life soldering
6/17/2009	12:23:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor	Cleaning fan coil on second floor
4/27/2009	11:39:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor lounge in Arizona	Cooking. Vent hood does not vent outside
4/24/2009	12:13:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor smokes	Strong odor of food cooked/burnt.
3/20/2009	12:36:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor	Burnt food in microwave
2/24/2009	6:45:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	na	Dirty smoke
2/14/2009	12:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor	Dirty smoke
1/30/2009	2:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	na	na
1/16/2009	11:11:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 857	Burnt food