

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/31/2010	12:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL -R2	Trouble	Basement miniplex panel	Bad Power Supply
12/31/2010	1:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement Main Panel	Bad battery charger
12/28/2010	1:15:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL -R2	Trouble	Basement	Bad power supply, will advise supervisor need to order one.
12/24/2010	2:30:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL -R2	Trouble	Basement	Unknown
12/12/2010	2:30:00 AM	31	Cochise Residence Hall	RESIDENTIAL -R2	False Alarm	First floor west hallway	Pull-station pulled
12/10/2010	8:31:00 PM	123	Pueblo De La Cienega	RESIDENTIAL -R2	False Alarm	In room 263	Hair spray used by student
12/7/2010	10:35:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	3rd floor sonora by room 325	Dirty smoke sensor
12/7/2010	8:45:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Outside room 325	UAPD believes it was just a faulty alarm
12/5/2010	12:16:00 PM	31	Cochise Residence Hall	RESIDENTIAL -R2	False Alarm	By 312	The 3E fire extinguisher was sprayed in hallway
12/3/2010	10:16:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor top of stairs	Dirty smoke sensor
12/2/2010	7:20:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	False Alarm	By L302	The alarm panel was indicating that room L302 needs to have its smoke detector cleaned and air filter changed: lint and dirt in the smoke detector.
12/1/2010	4:20:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor (zone 3)	Unknown
11/25/2010	12:12:00 PM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	By room 948	Discharged fire extinguisher
11/19/2010	2:45:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	Kitchen first floor	Cooking
11/17/2010	9:36:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	By room 325	he carpet cleaning crew was steam cleaning the carpet by room 325 smoke detector that caused the alarm
11/16/2010	11:07:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	4th floor hall	Custodial cleaning
11/16/2010	12:37:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	4th floor hall	Custodial cleaning
11/9/2010	9:53:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	By room 420	The carpet cleaning crew set the alarm off by cleaning the carpet in the hallway
11/7/2010	5:25:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Arizona Kitchen	Intentionally caused by students who were later identified.
11/6/2010	10:54:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	Kaibab 2nd floor north	Intentional
11/3/2010	2:00:00 AM	122	Posada San Pedro	RESIDENTIAL -R2	False Alarm	103 Mail area and 341	Unknown
11/1/2010	12:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	Trouble	North basement	Extreme steam
10/31/2010	8:05:00 PM	122	Posada San Pedro	RESIDENTIAL -R2	False Alarm	Lobby by 103	Dirty smoke
10/31/2010	10:00:00 PM	122	Posada San Pedro	RESIDENTIAL -R2	False Alarm	103 mail area	Unknown
10/30/2010	4:00:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor Huachuca	Someone pulled pull-station

10/25/2010	3:15:00 AM	31	Cochise Residence Hall	RESIDENTIAL -R2	False Alarm	2nd floor east side	Someone pulled the 2nd floor east side pull-station
10/25/2010	9:15:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	3rd Kaibab North	Intentional activation of pull-station
10/19/2010	12:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	Trouble	Room 12B	Power outage
10/18/2010	11:33:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	By room 117	Smoke detector by room 117 M1-33 was in alarm because their was a water leaking from the ceiling into the smoke detector base and head. Replaced smoke detector part number is 519-690 and
10/16/2010	4:15:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	By room 323	Broken pull station tamper proof cover
10/13/2010	12:45:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL -R2	Trouble	Ground fault	Found custodial sevicees in two different womens bathrooms with quarter to half inch of water on floor. Water could have seeped to floor below.
10/3/2010	10:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	6th floor Arizona	Unintentional
9/25/2010	8:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor stairwell	Noted as water pipe alarm
9/24/2010	12:52:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	Room 721	Extinguisher was set off in room 721 for a spark that was let out by the microwave
9/19/2010	1:25:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor	Unknown
9/17/2010	9:02:00 PM	34	Yavapai Residence Hall	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/16/2010	8:39:00 PM	31	Cochise Residence Hall	RESIDENTIAL -R2	Drill	Lobby	Risk Management annual fire drill
9/16/2010	7:40:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/16/2010	5:55:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/16/2010	8:30:00 PM	423	Sky View Apartments	RESIDENTIAL -R2	Drill	1st floor lobby	Risk Management fire drill
9/15/2010	9:01:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL -R2	Drill	1st floor lobby	Risk Management Annual Fire Drill
9/15/2010	8:21:00 PM	85	Coronado Residence hall	RESIDENTIAL -R2	Drill	na	Risk Management annual fire drill
9/15/2010	7:35:00 PM	121	Villa Del Puente	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/15/2010	7:30:00 PM	122	Posada San Pedro	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/15/2010	6:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/14/2010	6:20:00 PM	5	Coconino Residence Hall	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/14/2010	5:50:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL -R2	Drill	na	Risk Management annual fire drill
9/14/2010	6:30:00 PM	8	Gila Residence Hall	RESIDENTIAL -R2	Drill	Lobby	Risk Management fire drill
9/14/2010	7:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	Drill	na	Risk Management fire drill

9/14/2010	8:40:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/14/2010	9:15:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL -R2	Drill	Front lobby	Risk Management fire drill
9/14/2010	7:55:00 PM	151	Babcock	RESIDENTIAL -R2	Drill	2nd floor	Risk Management Annual Fire Drill
9/14/2010	9:30:00 PM	448	Parker House	RESIDENTIAL -R2	Drill	Lobby	Risk Management Annual Fire Drill
9/13/2010	9:52:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	8th floor hall	Not sure, something probably sprayed in hallway
9/7/2010	9:30:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL -R2	False Alarm	Room 274 kitchen	na
8/27/2010	10:15:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL -R2	False Alarm	1 NE Wing by 160	Cooking
8/24/2010	6:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	6th floor Sonora	UAPD believes it was lint in unit but ultimately said is was just a faulty alarm
8/23/2010	7:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	By room 620	Student cooking top-ramen in microwave oven
8/20/2010	2:30:00 AM	31	Cochise Residence Hall	RESIDENTIAL -R2	Nuisance Alarm	3W	Multiple residents reported seeing a "couple of guys" running from building
8/20/2010	11:35:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	6th floor reading room	Unknown
8/16/2010	8:38:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	By room 463	Water leak above smoke sensor
8/14/2010	5:45:00 PM	423	Sky View Apartments	RESIDENTIAL -R2	False Alarm	3rd floor smoke	The smoke detector was dirty and needed to be cleaned
8/4/2010	4:54:00 PM	31	Cochise Residence Hall	RESIDENTIAL -R2	False Alarm	1st floor	Dirty smoke sensor by 1st floor south east exit door
8/4/2010	5:44:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement elevator lobby	Dirty smoke sensor and base
7/23/2010	4:44:00 AM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor East wing	Unknown
7/23/2010	7:05:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	Basement	Contractor bumped start lever
7/15/2010	2:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Arizona basement lobby	Unknown
7/14/2010	1:01:00 PM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	8th floor in room 860	Dirty smoke sensor
7/1/2010	8:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Room 111	Contractor sweeping floor causing dust which set off alarm
7/1/2010		83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	In room 111	Contractor was sweeping floor causing dust which set off the alarm
6/24/2010	5:20:00 PM	8	Gila Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor	Dirty smoke sensor
6/18/2010	7:15:00 PM	8	Gila Residence Hall	RESIDENTIAL -R2	Trouble	At panel	Talley over-exceeded limits
6/18/2010	9:20:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	False Alarm	By room L321	Contractor worker using vacuum cleaner w/o filter
6/4/2010	11:42:00 AM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	2nd floor smoke detector	Residence life maintenance personnel
4/13/2010	1:00:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	False Alarm	na	Residence hall maintenance set off smoke detector while cleaning carpet

4/3/2010	1:00:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL -R2	Trouble	na	na
4/3/2010	6:45:00 PM	135	Pima Residence Hall	RESIDENTIAL -R2	False Alarm	Room 328	Unknown
4/2/2010	8:21:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL -R2	False Alarm	2nd floor kitchen	Someone was cooking in the kitchen and burned some food in the oven
3/24/2010	6:44:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	2nd floor by 209	Hair spray
3/17/2010	12:12:00 PM	5	Coconino Residence Hall	RESIDENTIAL -R2	False Alarm	Sitting room 1st floor	Burnt popcorn
3/8/2010	10:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Kitchen	Cooking
2/25/2010	12:42:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL -R2	False Alarm	By room 316	Burn food in microwave
2/25/2010	12:05:00 PM	121	Villa Del Puente	RESIDENTIAL -R2	False Alarm	In room 179	Human error. Hi pressure steam valve removed by Residence Life personnel
2/18/2010	8:21:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	na	TFD reported heat detector probably set off by hair straightener
2/16/2010	10:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	By Room 9/11 Sonora side	Jantiors cleaning
2/10/2010	11:11:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	11th floor Elevator equipment room	Elevator 1 brake shoes locked up
2/8/2010	3:09:00 PM	135	Pima Residence Hall	RESIDENTIAL -R2	False Alarm	Room 228	Student cooking with microwave
2/1/2010	4:15:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	Room 248	Burnt pop-tart
1/30/2010	8:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement	Uknown
1/29/2010	8:10:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	Room 209	Unknown
1/26/2010	10:45:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement	Unknown
1/24/2010	10:05:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement	Unknown
1/22/2010	1:44:00 PM	8	Gila Residence Hall	RESIDENTIAL -R2	False Alarm	Kitchen	Cooking
1/16/2010	8:07:00 PM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	9th floor	Dirty smoke
1/12/2010	9:12:00 AM	5	Coconino Residence Hall	RESIDENTIAL-R2	False Alarm	Top of elevator shaft	Dirt possibly from maintenance of dampers