

| Date | Time | Bldg # | Building Name | Bldg Type | Nature Of Event | Device Location | Cause |
|------------|-------------|--------|------------------------------------|------------------|-----------------|---|---|
| 12/22/2011 | 6:30:00 AM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | Nuisance Alarm | 'A' Building | UAPD attributed the alarm to surging water, same as multiple other alarms |
| 12/16/2011 | 4:00:00 AM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | na | Repeated water flow issue per UAPD |
| 12/14/2011 | 2:25:00 AM | 85a | La Aldea | RESIDENTIAL - R2 | Nuisance Alarm | By 125 | Unknown individual pulled pull station, no damages reported |
| 12/13/2011 | 4:00:00 AM | 7/7a | Manzanita/Mohave Residence Halls | RESIDENTIAL - R2 | Nuisance Alarm | 3-Mohave Women's Wing | Could not identify the person who pulled it as no witnesses came forward. |
| 12/13/2011 | 11:20:00 PM | 79/79a | Huachuca/Kaibab Residence Hall | RESIDENTIAL - R2 | False Alarm | Kitchen | Burnt food |
| 12/13/2011 | 3:50:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | Roof Building C, AHU E5 Duct Detector | Water damaged duct detector test switch |
| 12/12/2011 | 3:12:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | Roof AHU B6.01 Duct detector | Unknown at the time of site investigation |
| 12/10/2011 | 12:30:00 AM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | | Loss of water pressure |
| 12/8/2011 | 5:00:00 PM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | Kitchen B101 | Burnt food |
| 11/28/2011 | 2:45:00 PM | 131 | Likins Hall | RESIDENTIAL - R2 | Fire | 3rd floor Waterflow | Someone started a fire to the paper towel dispenser in the mens restroom in room B352 and the sprinkler head released which put the fire out in the restroom. The fire caused significant damage to the wall, floor, and dispenser, and the room is closed down until |
| 11/17/2011 | 6:45:00 PM | 34 | Yavapai Residence Hall | RESIDENTIAL - R2 | False Alarm | Room 124, Wing 1E | Burnt food |
| 11/16/2011 | 6:35:00 PM | 10 | Yuma Residence hall | RESIDENTIAL - R2 | False Alarm | Kitchen | Burnt food Officer Kubik provided the following case number: U1111160034 |
| 11/14/2011 | 9:25:00 AM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Basement | Custodial cleaning |
| 11/13/2011 | 1:30:00 AM | 135 | Pima Residence Hall | RESIDENTIAL - R2 | Trouble | In room 106b bathroom | Strobe in room 106B bathroom going bad |
| 11/5/2011 | 9:05:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | Building B 2nd floor west end of hall near stairs | Leaking victaulic inside the wall connected to sprinkler riser |
| 11/3/2011 | 10:20:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 6th floor by room 616 | The smoke detector was dirty |
| 11/2/2011 | 10:33:00 AM | 122 | Posada San Pedro | RESIDENTIAL - R2 | False Alarm | In room 139 | The student was heating toast in microwave and it burned setting the alarm off |
| 10/25/2011 | 5:00:00 PM | 10 | Yuma Residence hall | RESIDENTIAL - R2 | False Alarm | Kitchen | Case #U1110250027 The fire alarm went off due to smoke coming from someone cooking chicken. The person cooking did not turn the hood on over the stove. |
| 10/24/2011 | 10:20:00 AM | 8 | Gila Residence Hall | RESIDENTIAL - R2 | False Alarm | Room 200 | Burnt food. Students using illegal toaster. |
| 10/22/2011 | 4:30:00 AM | 122 | Posada San Pedro | RESIDENTIAL - R2 | False Alarm | | Cause of the alarm was unknown, most likely the disturbed plastic cover |
| 10/21/2011 | 11:11:00 AM | 122 | Posada San Pedro | RESIDENTIAL - R2 | False Alarm | SANP 2N | Fire alarm in the hallway was dirty which caused the fire panel to sound |
| 10/21/2011 | 12:25:00 PM | 423 | Sky View Apartments | RESIDENTIAL - R2 | False Alarm | Not determined | UAPD could not determine cause |
| 10/21/2011 | 4:25:00 AM | 423 | Sky View Apartments | RESIDENTIAL - R2 | False Alarm | not determined | Once again, UAPD could not determine the cause |
| 10/21/2011 | 7:52:00 PM | 423 | Sky View Apartments | RESIDENTIAL - R2 | False Alarm | na | Other, unknown |
| 10/17/2011 | 6:40:00 AM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | Basement | Water pressure issue with sprinkler control system in basement |

| | | | | | | | |
|------------|-------------|--------|----------------------------------|------------------|----------------|---|---|
| 10/13/2011 | 3:36:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 6th floor by room 616 | Unknown - unable to pin-point cause |
| 10/8/2011 | 4:00:00 PM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | B204 | The smoke detector was excessively dirty. |
| 10/7/2011 | 11:35:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | Trouble | 206b | Dirty smoke detector |
| 10/1/2011 | 2:30:00 AM | 122 | Posada San Pedro | RESIDENTIAL - R2 | False Alarm | Room 390 | Burnt Food |
| 9/27/2011 | 4:50:00 PM | 79/79a | Huachuca/Kaibab Residence Hall | RESIDENTIAL - R2 | False Alarm | Kitchen | Cooking |
| 9/24/2011 | 10:33:00 PM | 423 | Sky View Apartments | RESIDENTIAL - R2 | False Alarm | 4th Floor, no specific room | Police officers said the alarm was set off on the 4th floor because of burnt food |
| 9/20/2011 | 9:07:00 PM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | Drill | 1st floor lobby | Scheduled drill |
| 9/20/2011 | 9:30:00 PM | 34 | Yavapai Residence Hall | RESIDENTIAL - R2 | Drill | p/s by 103 | Scheduled fire drill. |
| 9/20/2011 | 6:55:00 PM | 52/53 | Greenlee/Graham Residence Halls | RESIDENTIAL - R2 | Drill | Greenlee Front Desk | Scheduled drill. |
| 9/20/2011 | 8:28:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | Drill | Lobby | Scheduled fire drill |
| 9/20/2011 | 5:45:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | Drill | na | Scheduled fire drill |
| 9/20/2011 | 9:50:00 PM | 423 | Sky View Apartments | RESIDENTIAL - R2 | Drill | Front lobby area | Scheduled fire drill |
| 9/15/2011 | 7:35:00 PM | 5 | Coconino Residence Hall | RESIDENTIAL - R2 | Drill | na | Scheduled Fire Drill |
| 9/15/2011 | 8:20:00 PM | 8 | Gila Residence Hall | RESIDENTIAL - R2 | Drill | Kitchen room 107 | Scheduled drill |
| 9/15/2011 | 8:00:00 PM | 10 | Yuma Residence hall | RESIDENTIAL - R2 | Drill | Front Desk | Scheduled drill with UA Risk Managemnet and ISG |
| 9/15/2011 | 7:15:00 PM | 151 | Babcock | RESIDENTIAL - R2 | Drill | By B211A | Scheduled fire drill with UA risk management and ISG |
| 9/14/2011 | 8:00:00 PM | 57 | Hopi Lodge Residence Hall | RESIDENTIAL - R2 | Drill | Lobby | RM&S requested fire drill |
| 9/14/2011 | 7:30:00 PM | 122 | Posada San Pedro | RESIDENTIAL - R2 | Drill | Front desk | RM&S scheduled fire drill |
| 9/14/2011 | 8:00:00 PM | 123 | Pueblo De La Cienega | RESIDENTIAL - R2 | Drill | Front Desk | Scheduled Drill |
| 9/6/2011 | 3:07:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Fire pump room Arizona side | The fire pump pressure switch caused the alarm. The pressure switch was replaced 9/7/11 by residence life. |
| 9/2/2011 | 2:00:00 AM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | D222 | Unknown |
| 8/30/2011 | 1:30:00 PM | 7/7a | Manzanita/Mohave Residence Halls | RESIDENTIAL - R2 | False Alarm | Mohave basement boiler tanks | Res life maint. turned on steam to building without shutdown request, and it set off heat detector |
| 8/27/2011 | 3:19:00 PM | 131 | Likins Hall | RESIDENTIAL - R2 | Trouble | Duct detector in room 113 | Faulty equipment |
| 8/26/2011 | 8:30:00 PM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | B110 | Residents burnt their popcorn in the microwave |
| 8/18/2011 | 6:19:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 6th Floor Bathroom | Too much hair spray in hallway. Particle detector activated. |
| 8/18/2011 | 9:10:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | Nuisance Alarm | Roof | Unclear as to cause of alarm |
| 8/17/2011 | 7:48:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | By room 421 | Strong smell of Perfume \ hairspray in the area / Unknown |
| 8/17/2011 | 5:40:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | Bldg. A, 1st floor | TFD said the alarm was caused by a water surge |
| 8/14/2011 | 10:45:00 AM | 122 | Posada San Pedro | RESIDENTIAL - R2 | Trouble | Third floor south in room smoke sounder | Sounder smoke base in room 391 deffective - removed and replaced sounder smoke base reset FACP - all five in room sounder smoke detectors operational |
| 8/14/2011 | 2:00:00 PM | 131 | Likins Hall | RESIDENTIAL - R2 | Trouble | In room A113 duct detector | PC board failure |

| | | | | | | | |
|-----------|-------------|--------|------------------------------------|------------------|-------------|-----------------------------------|---|
| 7/30/2011 | 10:30:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | By room 13 | The signal zam circuit was disabled |
| 7/29/2011 | 10:20:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | D Roof | Not sure what caused the alarm |
| 7/27/2011 | 9:15:00 AM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | Fire | By room S318 | The alarm was caused by the light fixture balast that shorted out by room S 318 which set the smoke detector off M5-100. Per Joe, code as fire. |
| 7/14/2011 | 11:58:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | Trouble | 4th floor by room 420 | Smoke sensor |
| 7/6/2011 | 10:10:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Santa Curz lounge 139S | Smoke sensor dirty |
| 7/4/2011 | 11:30:00 PM | 10 | Yuma Residence hall | RESIDENTIAL - R2 | Trouble | Attic tamper | |
| 7/2/2011 | 12:50:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | 3rd floor by room S-322 | Device failure |
| 6/19/2011 | 8:15:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | Trouble | 8th and 9th floor | Unknown |
| 5/19/2011 | 10:22:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | By room 425 | The cause of the alarm was unknown |
| 5/13/2011 | 5:09:00 AM | 122 | Posada San Pedro | RESIDENTIAL - R2 | False Alarm | By room 141 | Water Leak |
| 5/10/2011 | 6:21:00 PM | 423 | Sky View Apartments | RESIDENTIAL - R2 | False Alarm | 218 | Burnt plastic in room 218, smoke set off |
| 4/30/2011 | 8:30:00 AM | 57 | Hopi Lodge Residence Hall | RESIDENTIAL - R2 | False Alarm | By room 51 | Smoke sensor water damage |
| 4/30/2011 | 9:30:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 4th floor center hallway | Fire extingusher set off by student |
| 4/29/2011 | 8:30:00 AM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | 1st floor 2N2 pull-station/smokes | Unknown |
| 4/29/2011 | 10:10:00 AM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | Trouble | Panel | N/A |
| 4/28/2011 | 11:45:00 AM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | Trouble | Lobby by front desk | Unknown |
| 4/27/2011 | 10:30:00 AM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | Trouble | Panel | N/A |
| 4/23/2011 | 2:35:00 AM | 52/53 | Greenlee/Graham Residence Halls | RESIDENTIAL - R2 | False Alarm | Greenlee Stairwell 2SW by 219 | Intentional |
| 4/22/2011 | 6:48:00 PM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | Trouble | 1W by front desk | Unknown |
| 4/19/2011 | 8:23:00 AM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | In room 300B | The smoke detector was dirty and had to be cleaned |
| 4/17/2011 | 5:59:00 PM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | Lobby | na |
| 4/9/2011 | 10:30:00 PM | 121 | Villa Del Puente | RESIDENTIAL - R2 | False Alarm | Room 348 | Steam from shower |
| 4/6/2011 | 5:15:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | Hall by s-322 | UAPD did not indicate cause or location of alarm |
| 3/30/2011 | 6:20:00 PM | 423 | Sky View Apartments | RESIDENTIAL - R2 | False Alarm | na | Per Leo Taylor, problem was dirty smoke |
| 3/27/2011 | 9:50:00 AM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | Trouble | Lobby | Trouble, card 9, power supply/charger, battery charger capacity |
| 3/1/2011 | 11:30:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 6th floor Arizona side | UAPD accidently set off alarm |

| | | | | | | | |
|-----------|-------------|-------|----------------------------------|------------------|-------------|-----------------------------------|---|
| 2/27/2011 | 4:17:00 PM | 5 | Coconino Residence Hall | RESIDENTIAL - R2 | False Alarm | Coconino Kitchen, 1S Pull Station | Smoke in kitchen, no known flame. Living Room filled with smoke but cleared out before residents were allowed to return. Pull station in 1S pulled, unknown if the two are related. |
| 2/26/2011 | 5:59:00 PM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | Fire | Third floor alarm was set off | Grease fire |
| 2/21/2011 | 6:10:00 AM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | By room 404 | Device malfunction |
| 2/20/2011 | 4:40:00 AM | 5 | Coconino Residence Hall | RESIDENTIAL - R2 | False Alarm | 2nd floor | Unknown person pulled the pull station on the second floor, north wing. There was no fire. |
| 2/13/2011 | 2:06:00 AM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | 3rd floor east stairwell | The pull station was activated by a student for what appears to be the purpose of doing a prank. There was no fire. |
| 2/8/2011 | 3:18:00 AM | 5 | Coconino Residence Hall | RESIDENTIAL - R2 | False Alarm | Elevator | Unknown |
| 2/8/2011 | 11:35:00 AM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | In room 749 | A student burned their noodles in the microwave which caused the alarm |
| 2/5/2011 | 9:57:00 AM | 9 | Maricopa Residence Hall | RESIDENTIAL - R2 | False Alarm | na | Unknown |
| 2/4/2011 | 3:16:00 AM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | 4th Center | A resident had discharged the fire extinguisher |
| 1/30/2011 | 9:50:00 AM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | S308 | Boys D100s pulled "prank" on girls in S308 by expelling the fire extinguisher in the hall. |
| 1/29/2011 | 1:40:00 AM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | Cochise, 2E stairwell | Pull-station activated by unknown |
| 1/29/2011 | 3:30:00 AM | 121 | Villa Del Puente | RESIDENTIAL - R2 | False Alarm | South Building – 2nd Floor | Burnt piece of food from a microwave |
| 1/27/2011 | 1:45:00 AM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | 2E stairwell | Someone pulled pull-station on 2E |
| 1/23/2011 | 8:55:00 PM | 34 | Yavapai Residence Hall | RESIDENTIAL - R2 | False Alarm | Basement Floor/East Wing | Cooking |
| 1/17/2011 | 11:20:00 PM | 34 | Yavapai Residence Hall | RESIDENTIAL - R2 | False Alarm | In room smoke detector (Room 13) | Student cooking in room |
| 1/14/2011 | 11:00:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 4th floor smokes | Student used fire extinguisher in hallway |