

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/18/2012	8:34:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd fl KAHU by rm 329	Bad contacts on detector
12/16/2012	9:14:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	221A	Unknown
12/16/2012	12:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	1st floor room 117	Smoke detector
12/14/2012	5:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	C112	Burnt popcorn
12/13/2012	7:46:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor elevator lobby	Device defective need replace
12/12/2012	7:41:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	2nd floor in room C212	Student showering in bath room with door
12/10/2012	3:00:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	na	Fire Safety working on network
12/10/2012	10:44:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Panel	Power outage
12/9/2012	7:10:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	305	Burnt popcorn
11/30/2012	3:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th floor Sonora by room 613	Burnt popcorn in room 617. Microwave under bed on carpet.
11/29/2012	10:40:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L-206	Strong smell of cologne or air freshener in the room, caused smoke detector to go into alarm
11/26/2012	4:11:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B209	Unknown
11/22/2012	2:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	109 Kitchen	Burned stuffing in community kitchen
11/19/2012	7:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	B2 Side Hallway	Cooking
11/18/2012	11:20:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 26	Burnt popcorn in Microwave
11/15/2012	10:50:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	House side, 3rd floor	Smoke detector sett off by popcorn
11/14/2012	10:30:00 AM	151	Babcock	RESIDENTIAL - R2	Trouble	In room C212	resident of room had removed smoke head from base.
11/12/2012	1:30:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Fire	1st floor North West Lounge by room 151	Lounge sofa chair set on fire
11/11/2012	1:45:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B308	Cooking in microwave
11/10/2012	5:45:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	1W by 101	Cooking / non-fire
11/10/2012	8:45:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	206	
10/28/2012	5:41:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Community Kitchen	Burnt food
10/26/2012	3:44:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Fire	Main Riser	Couch buring in room 114. Arson caused.
10/25/2012	1:57:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	304	Burnt popcorn
10/25/2012		123	Pueblo De La Cienega	RESIDENTIAL - R2	Fire	1st floor TV lounge and 2nd floor kitchen	Unknown person
10/23/2012	7:35:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Mechanical room 226	Smoke detector - unknown
10/21/2012	5:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	945	Resident discharged fire extinguishers, no fire
10/20/2012	11:28:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor	Pull-station - Unknown
10/20/2012	11:10:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	3rd Floor Laundry Room/Rec Room	Wet towel in microwave
10/19/2012	1:35:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor by room 329	Burnt popcorn in room 339 triggered smoke detector
10/19/2012	1:30:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	339	Burnt popcorn
10/18/2012	2:30:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Stove burners left on in kitchen.
10/16/2012	9:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona Lounge Kitchen	Cooking
10/13/2012		5	Coconino Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	3rd Floor, South Wing by 312	It is unknown who discharged the fire extinguisher, a police report was filed. No fire alarm went off.

10/11/2012	6:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	Front desk	Unknown
10/11/2012	9:29:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	Front Desk	Unknown
10/11/2012	6:18:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Trouble	na	Unknown
10/8/2012	9:52:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen in Arizona Lounge	Resident using kitchen
10/8/2012	10:07:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Trouble	na	It was later reported that there was electrical issues due to construction around campus. There was no evacuation necessitated.
10/7/2012	7:55:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	385	Burnt food.
10/6/2012	7:50:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	104	Burnt food on stove
10/4/2012	11:51:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	na	Unknown
10/1/2012	7:30:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L349	na
10/1/2012	10:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L207	na
9/28/2012	8:17:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Common room between 305/304	Smoke from curling iron
9/25/2012	7:35:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen in apartment 120	Burnt food
9/23/2012	8:05:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	Emergency Evacuation	na	Fire in adjoining building
9/21/2012	11:20:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	D503	Blow Dryer
9/18/2012	7:57:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	3rd floor room 348	Student taking a hot shower
9/16/2012	6:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor	Unknown
9/16/2012	6:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	221/227	Smoke detector
9/15/2012	12:00:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	221/227	na
9/15/2012	2:40:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B207	Tampered smoke detector
9/13/2012	6:25:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Drill	Front desk	Scheduled drill
9/13/2012	7:05:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Drill	Staff Office	Scheduled fire drill
9/13/2012	6:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/13/2012	7:30:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	8:50:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	7:30:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	1:57:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 501	Possible contact issue
9/12/2012	6:50:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	Lobby	Scheduled drill
9/12/2012	5:50:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	Lobby	Scheduled drill
9/12/2012	5:56:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	6:00:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	8:07:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Drill	Lobby	Scheduled drill
9/11/2012	6:00:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/11/2012	6:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/11/2012	6:40:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/11/2012	8:25:00 PM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Scheduled drill

9/11/2012	7:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	Front exit pull-station	Scheduled drill
9/11/2012	7:30:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/11/2012	8:15:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Main mechanical room	See Joe B.
9/10/2012	6:45:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	By 104	Scheduled drill
9/10/2012	6:00:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/10/2012	5:51:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	Front desk	Scheduled drill
9/10/2012	8:00:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	Lobby	Scheduled drill
9/10/2012	7:10:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/10/2012	7:30:00 PM	448	Parker House	RESIDENTIAL - R2	Drill	na	Scheduled drill.
9/9/2012	1:30:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Card 4 power supply located basement (miniplex)	Batteries low voltage
9/8/2012	11:47:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	na	Bad device.
9/7/2012	2:00:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	Outside Laundry room	Discharged Fire Extinguisher
9/7/2012	4:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	1st floor	Unkown cause.
9/7/2012	5:47:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Elevator equipment room	Possibly dirty contacts and high humidity.
9/4/2012	12:05:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	273	Burnt food
8/31/2012	3:30:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	5th floor Manzanita by 548	Fire extiguisher discharged intentional
8/29/2012	10:45:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	221	Smoke detector triggered by candle, incense aromatherapy device
8/25/2012	8:05:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Fire	Pull Station in Room 330	Motor fire in fan coil in room 330.
8/24/2012	8:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Lobby Fire Panel	Upon further inspection, the UAPD officers could discern nothing wrong with the smoke detectors and reset the system.
8/24/2012	2:13:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 264	Dirty smoke detector
8/24/2012	2:15:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm		Dirty smoke detector
8/22/2012	9:43:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	D302	A slight smell of hair sprsay in the room, cleaned smoke as a precaution
8/18/2012	4:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 513	Resident of room burned popcorn in microwave
8/18/2012	1:02:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	Unknown
8/18/2012	11:25:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 328	COOKING POPCORN
8/17/2012	11:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Trouble	Room 272	Tampering with smoke detector
8/14/2012	9:05:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 321 a/c	Unknown
7/19/2012	10:01:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 330	inoperative smoke sensor
7/19/2012	9:36:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor east hall by south exit	Inoperative horn/strobe
7/17/2012	1:30:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Panel	Unknown
7/16/2012	7:02:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 724	Unknown
7/4/2012	11:30:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor in room D-307	Dirty smoke sensor
6/27/2012	7:35:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	A003 Main water flow	water flow switch
6/21/2012	10:55:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Fire panel	UAPD testing?
6/20/2012	8:19:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor by room 741	Vendor ctting sheet metal - site superisor was notified of the incedent
6/12/2012	2:39:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor by room 804	Painters
6/11/2012	1:49:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor in room 735	Painters

6/11/2012	1:42:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor in room 835	Painters
6/11/2012	1:33:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 935	Painters
6/4/2012	10:15:00 AM	7/7A	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Trouble	Bsmt Mohave Elev Lobby and 5th Flr Manzi by 540	Custodian with the best of intentions to ensure a clean facility. Status on Departure: Sprinklers bypassed for valve change out in basement.
5/22/2012	12:29:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	3rd floor in room 371	Cleaning around base
5/22/2012	2:00:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm		Solar Panel construction workers were welding pipes and shut it off on two separate occasions. The construction crew stated the entire system was supposed to be shut down during their work (12am-
5/22/2012	2:00:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	na	Construction workers
5/15/2012	9:15:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	In room A107	Burnt food
5/14/2012	8:25:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	In mechanical room 179	Res-Life contractors
5/13/2012	1:00:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	2nd floor room 2a	Dirty smoke sensor
5/13/2012	5:00:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	2nd floor in room 2A	Unable to locate the class A abnormal condition at this time - further troubleshooting is required to accurately find the problem
5/12/2012	12:00:00 PM	85a	La Aldea	RESIDENTIAL - R2	Trouble	201	na
5/11/2012	9:50:00 AM	448	Parker House	RESIDENTIAL - R2	False Alarm	na	Unknown
5/10/2012	8:19:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor by room 537	Contractor cutting dry wall by room 537
5/10/2012	8:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor smoke detector in room 825 and 823	Contractor cutting dry wall in rooms
5/7/2012	10:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 329	Contractor painting door jamb
5/6/2012	2:10:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	MZMO 328	Unknown
5/6/2012	11:53:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Trouble	Graham room 246	Unknown
5/4/2012	10:16:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	By room 236	Contractor, building under construction
4/26/2012	11:59:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 225	Sweeping the floor in room 225 cause dust to acumulate in room
4/19/2012	4:30:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Trouble	Card 4 power supply	Negative earth ground in system
4/19/2012	7:58:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th floor by room 649	Contractor sweeping the hallway by room 649
4/18/2012	10:01:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 604	Construction
4/18/2012	8:44:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor in room 862	dry wall cutting near room 862
4/18/2012	8:56:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th floor in room 606	Contractor sanding dry wall near room 606
4/16/2012	9:22:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor in room 508 smoke detector	Dirty smoke sensor
4/14/2012	7:25:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor kitchen	Burnt food
4/13/2012	11:08:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In rm 356	Construction workers
4/13/2012	12:02:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In rm 561	Construction workers
4/7/2012	6:10:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	5-Mohave-Men	Someone pulled pull-station
4/5/2012	10:45:00 AM	423	Sky View Apartments	RESIDENTIAL - R2	False Alarm	416	Excess dust
4/4/2012	2:07:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 953	contractor painting around smoke sensor
4/4/2012	2:22:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor in room 752 smoke detector	Dust from contractor cleaning room
4/2/2012	11:48:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 205 smoke detector	Painter in room 205 working around the smoke sensor
4/2/2012	8:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 205	Vendor dry wall sanding

4/2/2012	10:15:00 AM	151	Babcock	RESIDENTIAL - R2	Trouble	Bldg. D 2nd floor room 205	Dirty smoke sensor
3/30/2012	12:41:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 926	Painter in room 926 removed smoke sensor
3/30/2012	10:20:00 AM	448	Parker House	RESIDENTIAL - R2	Trouble	2nd floor hallway	Someone disconnected smoke sensor from its base
3/24/2012	4:12:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	By A230	Pull-station
3/22/2012	1:21:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 907/By room 909	Construction work
3/19/2012	1:16:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 506 & In room 834	Building is under construction, dust
3/9/2012	8:24:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 920	Open window caused blowing dust in room
3/9/2012	8:24:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor by room 948	Open windows caused blowing dust
3/8/2012	2:36:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor in room 528	Contractor Sanding dry wall
3/8/2012	4:50:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 909	UAPD report alarm caused by contractor work in building
3/7/2012	2:14:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor smokes/pulls	Possibly wind and dust related
3/5/2012	10:45:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 209	Contractor
3/5/2012	10:57:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 209	Contractor
3/5/2012	2:40:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 926	Contractor sanding dry wall in room
3/3/2012	10:31:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Smoke detector in room 525 (M5-25)	Contractor
3/3/2012	12:22:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 529 (M5-29)	Contractor
3/2/2012	10:41:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 336	Vendor cutting through plaster in room 336
3/1/2012	2:35:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor in room 557	Sanding dry wall by vendor
3/1/2012	2:33:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 208	Sanding dry wall by vendor
2/29/2012	7:02:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	First floor	Cooking - non - fire
2/29/2012	6:50:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	First floor	Unknown
2/29/2012	1:51:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	4th floor in room 442	Vendor sanding on drywall
2/28/2012	12:10:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 342	Vendor spray painting
2/27/2012	3:01:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th flr in room 731	Sweeping in room 731
2/27/2012	11:25:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 844	Construction/wind
2/27/2012	7:56:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd flr in hall way	Sweeping in hall way by vendor
2/24/2012	8:12:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora 7th floor	Cooking - non- fire
2/24/2012	9:45:00 AM	131	Likins Hall	RESIDENTIAL - R2	Trouble	Tamper in room 126	Unknown
2/22/2012	2:40:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	4th floor in room 406	Vaccum cleaner
2/16/2012	2:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor in rooms smoke detectors	Copper pipe under pressure blew apart (Bad solder connection)
2/16/2012	11:04:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor in room 834 smoke detector	sweating/soldering copper
2/16/2012	8:17:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th FLR in room 528	Vender in work area
2/14/2012	11:27:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 253	Someone cause dust to fly up in room 353 which set the smoke detector off
2/11/2012	4:05:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Elevator	UAPD could see no other cause for the alarm
2/11/2012	6:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor/kitchen	Resident was cooking dinner and created smoke, set off alarm by accident.
2/8/2012	11:00:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor in kitchen area	In kitchen area found burning toast in the toaster oven.
2/8/2012	10:00:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Unknown
2/8/2012	10:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 228	Contractor workers dropped wood panels on the floor causing the dust to stir in the air which set the smoke detector off

2/4/2012	1:00:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Yava 3W by 315	Cooking
1/24/2012	9:00:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Room 221	Resident cooked pasta in microwave with out putting water in the container.
1/23/2012	10:03:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	In room 124 bedroom	Hair spray
1/20/2012	9:45:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Trouble	11	Water damaged device
1/20/2012	12:09:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona basement lobby	The cause of the alarm was a dirty smoke detector M1-57 basement lobby.
1/14/2012	9:15:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Trouble	Room 214	Smoke detector battery
1/11/2012	6:25:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Third floor room 319	Dirty smoke detector