

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/15/2013	11:00:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Tampering with fire alarm controls
12/15/2013	4:26:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 705	Unknown
12/8/2013	4:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt popcorn
12/7/2013	12:35:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Trouble	Water valve near basement area	na
12/7/2013	5:08:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Trouble	na	Unknown
12/6/2013	7:30:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	2nd floor S Stairwell, Pima House	Fire extinguisher discharged
12/5/2013	6:40:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room D201	Dirty smoke/Fan running
12/3/2013	11:10:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	Main panel	Unknown. Per Joe B., The trouble was a power supply monitor, not batteries. Amp #2 or #3 was acting up.
11/30/2013	4:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	1st floor pull-stations	Unknown
11/29/2013	5:10:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	rm 13a generator trouble monitor	Unknown
11/27/2013	9:00:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Room 13	Custodian washed the laundry room with a hose, spraying water on the fire alarm devices in the room. This action caused the notification appliance to go no answer.
11/26/2013	10:30:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor	Painting
11/24/2013	9:01:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Nuisance Alarm	E4	Pull station
11/23/2013	2:20:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	2E Study Lounge	Smoke detector set off by dust
11/20/2013	9:25:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	na
11/20/2013	8:10:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 830	Burnt popcorn.
11/20/2013	2:45:00 PM	131	Likins Hall	RESIDENTIAL - R2	Nuisance Alarm	3rd Flr A-E Exit	Custodian was cleaning pull and somehow pulled the alarm.
11/19/2013	6:30:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in kitchen
11/19/2013	10:19:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Smoke in room 101	Cooking

11/16/2013	7:45:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	Room 269	Smoke detector
11/15/2013	4:05:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	Room 269	Resident was found to have been smoking a hookah pen moments before he had dismantled the room's smoke detector. The smoke detector was installed again. The building fire alarm was not activated.
11/13/2013	11:29:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	In room 314A	Unknown
11/13/2013	2:16:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Bldg. A lvl 4 in room 416	Resident burnt popcorn in room caused the fire alarm to go off.
11/12/2013	10:30:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Trouble	In room B117	Resident removed smoke detector head.
11/7/2013	5:35:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor Graham waiting room	Dirty smoke sensor
11/7/2013	11:41:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Fire	In room 956	Source of fire looks to be the cord of the microwave unit.
11/7/2013	10:25:00 AM	151	Babcock	RESIDENTIAL - R2	Trouble	In room C303	Resident removed smoke head
11/3/2013	8:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Trouble	7th floor water flow	Ground fault caused too much noise on the Mapnet circuit.
11/3/2013	3:07:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	room 226	Candle.
11/2/2013	3:35:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	1st floor rec room	Residents lighting a ping pong ball on fire.
10/31/2013	12:20:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	1st floor community director office	Card #3 power supply/charger
10/27/2013	2:08:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	Nuisance Alarm	na	Pull-station pulled
10/24/2013	8:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor by 325	Unknown
10/24/2013	11:00:00 AM	182	El Portal	RESIDENTIAL - R2	False Alarm	In rooms 219	resident of the room was cooking breakfast, and set off smoke detector in room
10/22/2013	12:19:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room C307E	Resident cooking popcorn.
10/21/2013	3:30:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	322 study room	Aerosol
10/21/2013	11:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 516	Dirty smoke detector
10/17/2013	6:23:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in kitchen.

10/17/2013	9:19:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	AZ/SO 325	Burnt popcorn, dirty smoke?
10/16/2013	9:59:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room B405	Burnt popcorn
10/16/2013	7:35:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room d216	Cooking
10/15/2013	10:47:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona Tower 5th Floor	Burnt popcorn
10/14/2013	1:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Sprinklers	Sprinkler system shutdown
10/14/2013	2:50:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Panel	System network
10/13/2013	1:15:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	lobby	Smoke detector
10/13/2013	4:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	na	Steam from iron
10/13/2013	2:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Highland District office	Unknown
10/4/2013	7:38:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	CD Apartment	Burnt food.
10/3/2013	9:16:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor Sonora by 325	Burnt food.
10/2/2013	11:21:00 PM	123	Pueblo De La Cienega	RESIDENTIAL-R2	False Alarm	na	Dirty smoke detector
10/2/2013	1:35:00 PM	132	Arbol De La Vida	RESIDENTIAL-R2	False Alarm	Room 104/104a	Residence life custodial cooking popcorn in the microwave. Over did it a bit.
9/30/2013	11:28:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	By room 161	Cause was a hairdryer that blew dust into the detector into the hallway. Secondary to that the room occupant left her hot iron plugged in and lying on the desk when she evacuated the building.
9/28/2013	11:45:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	Trouble	na	na
9/27/2013	10:35:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor	Cooking omelet in kitchen - burnt
9/26/2013	11:45:00 PM	131	Likins Hall	RESIDENTIAL - R2	Trouble	na	Unknown
9/25/2013	12:00:00 AM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/25/2013	12:00:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	na	Mandated Fire drill
9/25/2013	5:45:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/25/2013	5:40:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/25/2013	7:01:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/24/2013	12:00:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/24/2013	6:45:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/24/2013	6:55:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/24/2013	7:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/24/2013	12:00:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/24/2013	12:00:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/24/2013	7:50:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/24/2013	12:00:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill

9/24/2013	12:00:00 AM	448	Parker House	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/23/2013	5:45:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/23/2013	10:00:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Drill	na	Mandated Fire drill
9/23/2013	7:15:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/23/2013	7:45:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/23/2013	8:05:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/23/2013	10:05:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/23/2013	12:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/23/2013	12:00:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Mandated Fire drill
9/21/2013	11:00:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Residence Hall Kitchen	Fire alarm was triggered by burning toast in a toaster located in the Yuma Residence Hall kitchen area.
9/18/2013	7:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Multiple fire sprinkler valves one by one reporting closed	RLM did not fill out a shutdown request so we responded as if someone was tampering with the Life Safety system.
9/13/2013	1:20:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 272	Smoke detector
9/10/2013	8:07:00 AM	79/79A	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 22	Operation of a non-filtered vacuum cleaner by personnel
9/10/2013	12:13:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	1st Floor East Elevator Lobby	Wet sensor and base caused false alarm.
9/9/2013	6:44:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 421	Dirty smoke
9/9/2013	2:00:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	in room 909	tenants removed smoke head.
9/8/2013	1:15:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking
9/8/2013	3:45:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	Nuisance Alarm	Northeast courtyard door	N/A
9/8/2013	11:56:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	na	Burnt food
9/7/2013	5:07:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	na	na
9/7/2013	1:17:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	na	Burnt popcorn
8/30/2013	10:30:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	In room 424	Burnt popcorn set off smoke detector

8/30/2013	7:03:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Trouble	Lvl 6 Elev. Lobby Heat Bldg. A	Open circuit
8/28/2013	3:15:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 246	Burnt food.
8/27/2013	5:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Trouble	4th floor Sonora (room 433)	Low battery
8/26/2013	7:56:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	na	Unknown
8/25/2013	4:54:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Mutiple rooms on second and third floors	Dust and moisture from students moving in.
8/15/2013	5:25:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Staff Office	Spray paint
8/14/2013	1:05:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	In room 236	Blower/dryer in room 236 blowing forcefully in room caused the smoke sensor to go in alarm.
8/8/2013	11:46:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Elevator Machine Rm. 111	Painter using oil based paint in room
7/30/2013	7:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	by 102	Cooking
7/24/2013	7:30:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor South East elevator	Custodial personnel washing walls with water hose
7/20/2013	11:30:00 AM	448	Parker House	RESIDENTIAL - R2	False Alarm	Room 2	Smoke detector
7/18/2013	6:18:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Trouble	In bathrooms	Unknown
7/13/2013	12:53:00 PM	79/79A	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 229	perfume sprayed in room
6/18/2013	3:00:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	m5-33 building c level 1 rm 135D, m3-27 building b level 1 rm A113	Air filters being changed, dust set off the duct detectors

6/5/2013	9:45:00 AM	85a	La Aldea	RESIDENTIAL - R2	Trouble	C building Northeast stairs	RLM washing down stairwell wet devices
5/29/2013	10:05:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor Smokes and Pulls	Res life cleaning registers with vacuum. Exhaust blowing directly into Smoke detector.
5/19/2013	8:00:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	Trouble	In room 512	Ground on the mapnet 5 circuit
5/10/2013	2:14:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	In room 272	Student in room said he was moving and cleaning the room
5/9/2013	2:20:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor AZ/SO kitchen	Burnt food
5/7/2013	2:16:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 831	resident was cleaning out room set off in room smoke detector
4/15/2013	2:38:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	facp	Fire safety working on network
4/13/2013	6:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen in 100	Cooking
4/10/2013	3:30:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Trouble	5th floor A building	Card 51 hung up.
4/9/2013	2:00:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Trouble	Card 9	Failed card
4/7/2013	5:03:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th Floor by rooms 608, 616, and 620	Fire extinguisher discharged on 6th floor.
4/6/2013	11:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	in room 111	Dirty Smoke Detector
4/6/2013	3:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor Arizona	Faulty alarm
3/29/2013	9:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Trouble	Room 34 and 5	Dirty smoke and other.
3/26/2013	12:45:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	1st floor elevator	Heat detector
3/25/2013	10:31:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	B204	Possible shower steam or hairspray.
3/24/2013	2:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	520	Resident smoking marijuana in room and set off alarm
3/24/2013	4:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	5 AZ	Faulty filter
3/9/2013	8:05:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Lodge kitchen 1st floor	Burnt eggs
3/8/2013	7:18:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In room 101	Cooking

3/5/2013	1:50:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 302	Student cooking in the micro wave oven.
3/1/2013	1:33:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor D107	Strong smell of cologne in room caused the smoke detector to go into alarm
2/28/2013	7:50:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In room 117	Resident burned food on stove and caused the alarm
2/26/2013	1:58:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	1st Floor Kitchen	Girl burnt shrimp in kitchen
2/26/2013	2:55:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	109c	Fire safety working on network
2/24/2013	1:15:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	3rd floor NW pull station	Someone removed pull-station tamper proof cover
2/22/2013	4:20:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	By A219	Burnt food
2/21/2013	7:40:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food, smoke detector
2/18/2013	1:06:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	First floor lobby	Smoke detector
2/13/2013	9:19:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 258	Steam from shower set off detector
2/10/2013	4:50:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Fire	B105 Kitchen	Grease fire
2/7/2013	9:11:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room d307	Heavy smoke in room
2/5/2013	7:45:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	By room 324	Dirty smoke detector
2/5/2013	1:50:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 32	Student cooking cheese sticks in microwave
2/3/2013	3:15:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 269	Burnt food
1/21/2013	1:50:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen room 123	Burnt pan
1/13/2013	8:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	413/411	Residents used baking powder to mask the smell of vomit and then vacuumed the carpet which stirred the powder into the air and set off the sensor.