

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/18/2014	9:28:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 109a	resident was taking a hot shower and the steam from the shower caused the smoke detector to go into alarm.
12/13/2014	11:20:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	ATTIC CENTER	Roof Leak
12/12/2014	7:45:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt chocolate caused fire alarm to go off.
12/8/2014	6:14:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L327 - Restroom	UAPD unable to determine cause, but likely to be steam or some form of aerosol. CDOC 1 to file fire report.
12/6/2014	1:30:00 AM	85a	La Aldea	RESIDENTIAL - R2	Nuisance Alarm	na	Pull station pulled
12/6/2014	2:44:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Nuisance Alarm	East stairwell	Discharged Fire Extinguisher
12/2/2014	12:52:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke by room 352	Dust from disturbed air vent caused alarm
12/2/2014	1:29:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke by room 352	dust from air return vent and possible smoke from room 352
12/1/2014	3:40:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In Lounge 200/202	Smoke was from a hookah with "Blasting Berry" sented material.
11/29/2014	5:20:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	na	fire alarm went off due to fire sprinkler system issues.
11/26/2014	12:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Lobby	Possible dirty smoke detector
11/26/2014	1:30:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	220	Burnt food
11/24/2014	11:46:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room C 208	burnt Mac & cheese in residents microwave.
11/23/2014	10:52:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Lobby	On November 23rd 2014 in Apache Santa Cruz at 10:52pm, the RA's on duty noticed the cover on the fire alarm pull-station next to the double doors on the Santa Cruz side was closed but sounding an alarm. UAPD was called to inspect buzzing and reset, but alarm had stopped just prior to their arrival. A police aide inspected
11/22/2014	8:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L235	Smoke detector alarm sounded in resident room in Colonia de LaPaz residence due to e-cigarette vapor. UAPD responded to the scene and reset the fire panel.

11/21/2014	9:45:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor Manzanita elevator lobby	smell of hairspray in hall way by elevator smoke detector.
11/21/2014	1:30:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 317	Fire panel alarm sounded due to Lysol spray in isolated room in Yavapai. UAPD came and reset panel.
11/20/2014	4:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	D300	Fire alarm going off in residents room for unknown cause.
11/17/2014	8:02:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	Smoke in room D209	Dirty smoke
11/15/2014	5:20:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	na	Dirty smoke detector
11/13/2014	9:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 361	Burnt food.
11/11/2014	12:50:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Room 332	Burnt AC motor
11/2/2014	11:30:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Near elevator	fire alarm was set off due to dust collecting near an elevator, Building Evacuated.
11/2/2014	5:21:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	2nd floor kitchen	Burnt food
10/30/2014	2:26:00 PM	7/7A	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke by room 330	Dirty smoke was probably bumped or disturbed.
10/30/2014	12:39:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	in room 317	resident was spraying Lysol in his room causing the smoke detector to go into alarm.
10/30/2014	1:11:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	in room C122	burnt popcorn
10/29/2014	9:10:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 273	Burnt popcorn
10/24/2014	1:36:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 220	Popcorn a little overdone in the microwave.
10/24/2014	2:22:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	in room 343	resident was cooking food in a microwave and burnt it causing the smoke alarm to go off
10/23/2014	6:45:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 352	Smoke alarm going off in room 352 causing the building fire alarm to go off. According to UAPD, there was no fire that caused the smoke alarm to go off.
10/23/2014	10:28:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor	False fire alarm; building not evacuated.

10/18/2014	10:50:00 PM	85a	La Aldea	RESIDENTIAL - R2	Nuisance Alarm	4th floor pull station	Pull station pulled by unknown party
10/17/2014	8:47:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L 320	Smoke machine in room
10/16/2014	11:11:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	in room 422	resident burnt popcorn in their microwave, causing the smoke detector to go into alarm.
10/15/2014	7:20:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/15/2014	7:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/15/2014	8:50:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
10/15/2014	8:00:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/15/2014	6:10:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/14/2014	1:25:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 348	Burnt food
10/12/2014	5:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	na	No known cause.
10/8/2014	5:30:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	UAPD Responded but no cause was determined.
10/6/2014	7:20:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
10/6/2014	7:44:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/6/2014	8:02:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Drill	na	Fire drill
10/5/2014	1:15:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 115	na
10/4/2014	8:55:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 36	Individual room alarm went off, due to resident straightening their hair.
9/30/2014	8:40:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	7:30:00 PM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Fire drill

9/30/2014	8:00:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	6:00:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	5:45:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	5:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	6:55:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	9:50:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	9:30:00 PM	377	Rawls Eller Lodge	RESIDENTIAL - R2	Drill	na	Fire drill
9/28/2014	6:35:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 385	UAPD could not find cause of the alarm
9/28/2014	5:10:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	CD room 130	No known cause of alarm.
9/25/2014	1:13:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	na	Unknown person had pulled alarm.
9/25/2014	1:17:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	7th floor room 705	The all clear was given and residents were able to re-enter the building at 1:17am
9/24/2014	4:13:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 707	Cause was due to a resident steaming their clothes in the room.
9/18/2014	2:55:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	In room 305	resident of room 305 had removed the smoke head in the room. Both residents of the room denied removing the smoke head.
9/18/2014	9:55:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Building was evacuated following a fire-alarm. UAPD responded to reset the system, but no cause for the alarm was identified.
9/17/2014	12:45:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	Room 534	Cooking food
9/15/2014	1:39:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room L204	Occupants spraying febreze in room.
9/14/2014	5:25:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	kitchen	Pull-station
9/12/2014	2:24:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	hall by room 21	a resident was cooking in the kitchen and burn eggs setting off the fire alarm.

9/12/2014	3:23:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	637	Dust
9/11/2014	9:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 234	Burnt pop tart
9/11/2014	4:12:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room C304	Individual room alarm was sounding and UAPD responded to reset it. The cause for the alarm was burnt popcorn.
9/8/2014	2:36:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Fire	In room 862 in room smoke detector	Student ironing, using steam function under smoke sensor
9/8/2014	2:36:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 862 in room smoke detector	Student ironing, using steam function under smoke sensor
9/6/2014	6:37:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	3 SW, Greenlee	Fire alarm went off at approximately 7pm in Greenlee 3 SW due to resident who bumped off fire alarm cover. UAPD was notified and area was evacuated. RAs were able to replace the cover and turn
9/2/2014	7:15:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	na	Burning plastic
9/2/2014	1:40:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	na	Pull-station
9/2/2014	7:14:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Building Fire Alarm Reporting Point	Electrocution of spider by monitoring voltage created a limited current path which the monitoring system sensed as an alarm.
9/1/2014	11:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 424	Burnt food in microwave
9/1/2014	12:55:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Rom 804	Steam
8/30/2014	12:40:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	124	Unknown
8/29/2014	6:34:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	2nd Floor in room 217	Student hit fire sprinkler head in room 217.
8/28/2014	6:16:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Unknown
8/27/2014	2:39:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor Graham side	UAPD triggered system in error

8/27/2014	5:25:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room c115	UAPD determined that it was the iron steam in the room that caused the alarm to go off.
8/26/2014	2:07:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 622	Resident was cooking food in the microwave fell asleep burnt food causing smoke detector to go into alarm.
8/25/2014	8:27:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	B302	Unknown
8/24/2014	5:47:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Basement	Unknown
8/24/2014	1:24:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 467	na
8/24/2014	11:00:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 361	E-cigarette
8/23/2014	9:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food - popcorn
8/23/2014	5:49:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 272	na
8/22/2014	10:50:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 340	Smoke/vapor from hair styling device. Report f00131-2014
8/17/2014	4:58:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	10th floor pull station	Unknown
8/15/2014	3:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 532	Dirt from the air conditioner was blown into the air causing the detector to go into alarm.
7/18/2014	6:49:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 301	Unknown
7/3/2014	6:30:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Fire panel	Fire panel and alarm sounded due to "excessive heat" on the panel. UAPD responded to reset.
6/30/2014	6:55:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Fire pump run	Pipe break/water
6/21/2014	4:25:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	2nd Floor, NE Pull Station	No source found for alarm. UAPD responded and reset fire panel.
6/17/2014	11:39:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor Mohave by room 401	Staff cleaning the carpet in room 401

6/5/2014	10:00:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room b207	resident burned toast in microwave
6/3/2014	4:54:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	na	Electrician conducting work
5/26/2014	1:54:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Entire building	CRA calling to report building wide power outage had triggered building wide fire alarm. Informed CRA that ERLM and TEP were attempting to fix issue.
5/13/2014	11:25:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B202	RA room smoke detector sounding, UAPD called to reset. False alarm.
5/11/2014	1:30:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	na	Prank
5/11/2014	2:11:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Pull station	Fire alarm went off due to loose pull station on first floor. Only first floor residents evacuated as it was a localized alarm and most residents could not hear it. UAPD arrived to fix pull station. No case
5/10/2014	8:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 944	Possibly dirty contacts
5/9/2014	1:50:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Building evacuated for a fire alarm caused by someone pulling a pull station in the building. Residents were given all clear to enter.
5/6/2014	1:54:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora by 413	Dirty smoke detector by room 413 Sonora
5/6/2014	1:19:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	413	Building was evacuated because of a suspected faulty fire alarm in room 413. This was the second time that this had happened that evening, and the fourth time over a period of 2 days. UAPD was contacted to ensure that fire safety was being dispatched to look at
5/5/2014	12:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th Floor Arizona side	Dust
5/5/2014	2:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	413	Cause was determined to be a dirty smoke sensor/dust in the 413 detector.
5/5/2014	5:46:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	413	Building had been evacuated due to a fire alarm originating from room 413. When UAPD went up to the room to inspect it, there was a hat covering the smoke detector. This was suspected to be the cause, although there was some uncertainty. UAPD reset the fire
4/30/2014	12:30:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 340	Burnt popcorn.
4/27/2014	3:57:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor Huachuca by 352	RA on Duty called to inform the CDOC that there had been a fire alarm. The building was evacuated, and UAPD and others arrived. No cause was determined, and no case number was given. Residents were given the all clear to return to the building. Added

4/26/2014	10:36:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 625	UAPD responded to hall and determined there was no fire in the hall, but that the alarm may have been caused by a candle or burnt hair. Residents were given the all clear to return to the
4/22/2014	10:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th floor study lounge	Fire alarm due to unknown cause. Building was evacuated. Fire panel reset.
4/18/2014	7:20:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 944	CORO smoke detector going off
4/17/2014	12:49:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 413	RAOD called to inform CDOC that fire alarm was triggered due to marijuana. UAPD knocked on student's door but there was no answer. UAPD will follow up with residents.
4/17/2014	10:32:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor by 413	Res. Life steam cleaning carpet and set off detector
4/16/2014	3:42:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	2nd floor	loose fire alarm cover
4/10/2014	8:15:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking
4/9/2014	11:12:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room B405	Cause of alarm was student burning a facial mask in the microwave.
4/7/2014	9:42:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor west study lounge	UAPD determined alarm to be due to electronic cigarette vapor. Event number: V140970071
4/7/2014	12:57:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 621	Unknown
4/7/2014	11:14:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room A206	Dirty smoke detector
4/6/2014	4:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 705	Unknown cause in AZSO 705 set of AZSO fire system at 4:30 AM. Building evacuated. Nothing found. Cleared by UAPD for re-entry at 4:50 AM.
4/3/2014	1:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 413	Fire alarm activated due to faulty smoke detector. Building evacuated. Fire panel reset.
4/2/2014	11:32:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 310	Deodorant being sprayed
3/29/2014	9:40:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Room 217	The alarm originated from room 217. UAPD determined that there was no apparent cause for the alarm. They reset the alarm system and cleared the building for reentry.
3/29/2014	9:45:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Room 213	The alarm originated from room 213. UAPD could not determine cause of alarm. The system was reset and the building was cleared for reentry.
3/24/2014	4:43:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	All present residents evacuated in a timely manner. UAPD responded as well.

3/23/2014	3:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 17a	Smoke detector in room due to steam
3/23/2014	1:20:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	D303	E-Cigarette set off smoke alarm in room.
3/17/2014	3:38:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	Room 384	Smoke detector batteries changed
3/14/2014	3:45:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 230	Smoking in room
3/11/2014	12:34:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room smoke alarm room 114	Student cooking in micro wave and forgot cooking time
3/4/2014	10:48:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 220	Dirt from the HVAC in the room caused the smoke detector to go into alarm.
3/1/2014	4:42:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room E310	A smoke detector was set off in VIDA E310 due to burned food. UAPD responded and reset the fire panel and checked to ensure that the smoke detector in the room were functioning correctly.
2/28/2014	8:05:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Maricopa alarm sounded for unknown reason. TFD and UAPD responded, found panel saying pull station activated, but none found. Panel and system reset.
2/26/2014	11:00:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	CDOC was called due to the fire alarm going off from a hair dryer. Hair Dryer had body powder inside and when dryer was turned on, powder was released in room causing alarm to go off. UAPD was unable to reset the alarm until the powder was gone. CDOC
2/22/2014	3:01:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	2nd and 3rd floor	Fire extinguisher
2/22/2014	2:20:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	P/S in lobby	Unknown individual pulled pull-station
2/20/2014	10:45:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen/Hallway	Burnt food
2/20/2014	11:05:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food
2/20/2014	7:55:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 369	Burnt popcorn
2/20/2014	10:40:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Study room 267	Dirty smoke detector
2/17/2014	11:35:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Between room 316 and 318	Probable cause of the fire alarm was a burnt protein bar in the microwave. The building was evacuated twice. UAPD pinpointed the incident happened between rooms 316 and 318.

2/16/2014	10:35:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	APSC Kitchen	Burnt food and smoke caused the APSC fire alarm to go off. APSC evacuated. Access back into APSC granted shortly thereafter.
2/13/2014	11:46:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room L317	resident of room L317 had a lit candle in the room which caused the smoke to go into alarm.
2/12/2014	12:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora side 7th floor by rm 705	res. Life custodial was cleaning the carpets on the 7th floor and set off the smoke detector.
2/11/2014	11:35:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	na	lthough the fire alarm went off, it was not due to a student. Instead, the fire pad in room A114 is dirty. The alarm may go off again in the future unless the pad is cleaned. (Leo contacted UAPD who
2/9/2014	1:10:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Lobby	na
2/8/2014	12:15:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	D510	Resident was cooking in room and poured water over hot food, which caused steam to trigger alarm. No fire occurred.
2/7/2014	4:30:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Wing 3c	Pull-station pulled
1/29/2014	12:19:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	1st Fl. Elevator Lobby	Custodial was steam cleaning carpets. Steam got into smoke detector.
1/24/2014	8:45:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	Kithcen	Fire extinguisher
1/23/2014	10:45:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 421	Smoke detector
1/23/2014	10:15:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	na	Discharged fire extinguisher
1/21/2014	10:20:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 245	Smoke from Telecom room
1/20/2014	12:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	na	na
1/18/2014	3:05:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Burnt food
1/17/2014	2:32:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	B3 Wing	Pull-station cover removed
1/16/2014	2:57:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room D-309	Unknown
1/15/2014	6:44:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room C109	Broken smoke sensor caused the alarm

1/7/2014	10:20:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora side by room 413	Custodians cleaning the floors caused the smoke detector to go into alarm.
1/6/2014	2:45:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	C and D wings	Discharged fire extinguisher