

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/16/2015	10:19:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	Smoke in room B-516	Dirty smoke detector
12/15/2015	7:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 804	Burnt food in microwave
12/14/2015	2:33:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Smoke in room b511	Burnt popcorn
12/3/2015	3:17:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 219	resident burnt food in the microwave
12/2/2015	7:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B215	Fire alarm activated due to vapor pen in resident room.
11/30/2015	7:30:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 137	Unknown but the sensor was contaminated with some sort of material.
11/22/2015	1:45:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 526	Smoking marijuana in room
11/21/2015	10:57:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	206	Burnt macaroni and cheese
11/18/2015	10:55:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	na	Steam from shower
11/15/2015	6:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	103	Smoke from cooking
11/15/2015	7:35:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 716	Burnt food in microwave
11/14/2015	10:15:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke from burnt food
11/9/2015	11:15:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 248	E-cigarette possibly set off smoke per UAPD
11/8/2015	4:54:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	248	Unknown
11/6/2015	4:40:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	1st floor pulls	Pull station pulled-1st floor
11/6/2015	11:51:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor AZ rec. room	Students were cooking breakfast (fried bananas) and burnt the food causing it to smoke and set off the smoke detector.
11/5/2015	7:47:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Excess smoke from burnt food in the kitchen.
10/30/2015	4:48:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Fire	Kitchen	Burnt food
10/30/2015	10:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	323	Curling iron
10/30/2015	5:24:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	na	Steam from shower
10/30/2015	7:58:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Apartment 121	Steam from shower
10/30/2015	7:55:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 337	Possible faulty outlet or microwave
10/28/2015	10:45:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	Fire	Room 116	Paper lit with zippo lighter
10/26/2015	11:46:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora in room 821	Cause unknown. No smells or smoke in the room verified with UAPD who was in the room as well.
10/23/2015	1:32:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room L330	Wall-plug air freshener
10/22/2015	4:43:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Heat detector in attic M4-2	Defective device
10/22/2015	5:15:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Building A room A119 (Heat detector)	heat detector unknown-followup action required
10/21/2015	9:20:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	1st Floor South	Aerosol sprayed into hallway

10/20/2015	3:25:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor by room 266 smoke detector (APACHE SIDE)	Burnt popcorn
10/15/2015	9:20:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Community Kitchen	Burnt/smoky food in Kitchen
10/12/2015	4:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	Pull station activated - unknown reason
10/9/2015	11:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 431	Resident was using a close steamer on her close.
10/3/2015	12:55:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Kitchen	Faulty oven
10/1/2015	11:15:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in microwave
9/30/2015	2:14:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In room 217	Unknown
9/28/2015	6:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/28/2015	5:45:00 PM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/28/2015	8:05:00 PM	377	Rawls Eller Lodge	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/26/2015	12:15:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	315	Burnt food
9/26/2015	4:12:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 416	Student smoking
9/26/2015	3:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Fourth floor	Cause for alarm was unknown.
9/26/2015	3:03:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Fourth floor	Cause for alarm was unknown.
9/21/2015	1:48:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	in room 723	E-cigarette
9/19/2015	7:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room D212	Cigarette smoke
9/16/2015	5:15:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Community Kitchen	Smoke originated from burnt burgers on stove in community kitchen.
9/6/2015	9:56:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Common Kitchen	Burnt food
9/6/2015	1:40:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 117	Burnt french toast in the microwave
9/6/2015	9:25:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	na	Unknown
9/4/2015	3:30:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 361	Burnt food
9/3/2015	8:56:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 316	Student smoke E-cigarettes in room
9/3/2015	8:56:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 224 smoke detector	Student using a hot flat iron on hair below smoke detector
9/1/2015	12:06:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 226	Occupants smoking an electronic cigarette in room
8/31/2015	12:36:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 316	the smoke detector was dirty.
8/30/2015	9:05:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 316	Smoking in room
8/30/2015	5:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor	Pull station accidentally hit
8/27/2015	11:04:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 65	Unknown
8/25/2015	2:38:00 PM	182	El Portal	RESIDENTIAL - R2	Fire	na	Plastic bin left over stove under low heat
8/21/2015	2:57:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 622	Student was using a vapor cigarette in room

8/21/2015	10:58:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room b101	Stove left on in B101.
8/20/2015	2:36:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In room 100	Resident boiling water for tea. Believe steam set off detector.
8/19/2015	7:44:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room smoke detector 532	Student cooking Mac and cheeses in the micro wave oven
8/18/2015	10:00:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 433	Vapor pin
8/17/2015	5:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 407	It was an e cigarette in room 407 and both residents were absent.
8/10/2015	2:03:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 342	Res. Life custodial removed the smoke detector head to clean
7/29/2015	7:20:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	372	Burnt popcorn
7/29/2015	2:11:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	In room 226	E-cig vapor in room.
7/24/2015	7:15:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Room 119	Smoke Detector goes off in room 119.
7/22/2015	10:48:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	na	Construction workers were putting up dry wall and that caused the alarm to go off.
7/20/2015	6:15:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Top of ramp to sub-basement	Water damage from non working sump pump
7/19/2015	3:18:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Basement	Unknown
7/15/2015	8:48:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	basement in room 2	contractors digging up the floor stirred up dust causing the smoke detector to go into alarm
7/11/2015	11:00:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Top of north stairwell	Cleaned the top of north stairwell smoke detector. Contacts were corroded.
7/10/2015	11:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Nuisance Alarm	4th floor hallway	Fire extinguisher released by guests
7/9/2015	11:15:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Fire alarm went off due to excessive perfume and hair spray in teh basement fogging the smoke detectors.
7/9/2015	8:33:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	North side lounge area	Missed communication on the bypass procedure with contractor.
7/9/2015	10:30:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Main lobby	Contractor removing window frame to install new - cause dust to inter lobby
7/8/2015	2:45:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	635B closet	Unknown, Possible movers
7/4/2015	6:34:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 100	The cause of the alarm was unknown. Alarm unplugged to be reset
6/15/2015	7:02:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	It was determined that the cause was the overcooking of a science experiment conducted by the camp participants.
6/12/2015	9:01:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	By room 218	Contractor installing wifi in the bldg had spray painted a new access door within 10 inches of the smoke detector. Contractor did not call for a shutdown.
6/12/2015	7:47:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 157	Girls State had accidentally hit a sensor which was making alarm sound in room. No space evacuated, and CDOC to file Fire Report.
6/9/2015	1:00:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor center west	Res. Life custodial was washing the walls and washed the pull station and by doing this pulled the handle of the pull station with a rag.
6/9/2015	1:15:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	5th floor by room A518 above ceiling	Duct detector sensor dirty
6/4/2015	12:39:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Smoke by room 218	Contractors spraying
6/3/2015	9:57:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room	Unknown

6/2/2015	10:45:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor hallway	Unknown
6/1/2015	10:59:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Smoke by room 311	Fire alarm program
5/28/2015	1:52:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 658	res life painters in the room sprayed a aerosol primer witch set off the smoke detector. None of the painters left the room while it was in alarm.
5/19/2015	1:33:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	In room 324	Res. Life maintenance was moving furniture in the room causing dust to enter the smoke detector causing it to go into alarm.
5/18/2015	9:57:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basement generator room #3	Generator running an extended period of time due to power outage. Heat built up in the room and set off the heat detector. Found air filters on the vent for the room were extremely dirty.
5/13/2015	8:20:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Nuisance Alarm	na	Possible pull-station cover offset
5/12/2015	5:50:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Fire alarm set off at Maricopa by food burning in the kitchen.
5/12/2015	6:55:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	na	Fire alarm set off by a candle in a resident room.
5/9/2015	8:03:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	101	Cause determined to be burnt food in Community Director apartment.
5/4/2015	3:20:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Melted plastic on the stovetop in Hopi Kitchen caused the fire alarm to sound. UAPD examined the stovetop and the stove was not on at the time of the fire, but the top was warm. Evacuation of
5/3/2015	3:36:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3NE wing	Fire alarm going off due to water pipe valve being loose.
5/3/2015	2:56:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3NE wing	Water valve being loose in 3NE wing caused fire alarm to go off.
5/2/2015	3:09:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	Nuisance Alarm	First floor	Fire alarm going off due to fire alarm box being loose. No open flame present.
4/29/2015	11:36:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th floor in room 646	resident was spraying Lysol in the room that caused the smoke detector to go into alarm
4/10/2015	9:40:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In rm. L-309	Slight smell of hair spray in the air. Believe it got into the detector.
4/5/2015	2:35:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor greenlee east water flow	Someone turned the inspectors test valve causing the fire alarm to go off due to water flowing in the system.
4/2/2015	9:25:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	119	Unknown
4/1/2015	5:45:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	421	Unknown
4/1/2015	12:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	421	Unknown
3/31/2015	12:33:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	In room 306	Possible dust or mist
3/31/2015	9:10:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 265	Unknown
3/12/2015	7:55:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	C210 and D221	Smoke detectors - reason unknown
3/11/2015	8:48:00 AM	79/79A	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Fire	Kaibab TV lounge	a resident by the name of Kietzecume Garcia, told the building CD that " they were cooking food in the Kitchen and heard a pop sound on the stove, they turned around to find the burner on fire." the resident used a fire extinguisher to put out the fire then
3/8/2015	3:08:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	Sonora Tower	Discharged Fire Extinguisher

3/7/2015	7:40:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 106	Hair dryer set off smoke detector
3/7/2015	4:38:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in kitchen
3/7/2015	6:08:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	230	Unknown
3/2/2015	5:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt cooking in kitchen evacuated building. UAPD responded and cleared for reentry.
3/1/2015	1:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Fire	Kitchen	Cooking fire
2/25/2015	4:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 224	Burnt popcorn
2/19/2015	11:31:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor Arizona side	The 4th floor of Arizona side of AZSO was going off. UAPD arrived to reset the alarm. The smell of burnt popcorn was the source, but could not be determined what room it came from.
2/18/2015	3:02:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room A102	Burnt pizza in microwave
2/7/2015	3:56:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Nuisance Alarm	2nd floor	
2/6/2015	9:13:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Nuisance Alarm	3rd floor Navajo	Pull station bumped
2/5/2015	7:41:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	In room 133 smoke detector	Hair blower
2/5/2015	1:45:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 941	smoke detector was dirty
2/4/2015	1:00:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Build "C" main water flow	Point M2-3 not in bypass equation.
2/2/2015	8:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 257	Student steaming clothes
1/31/2015	8:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 448	Aerosol spray
1/24/2015	1:15:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke in kitchen
1/24/2015	11:40:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 51	Smoke detector was set off due to a burning candle in Hopi room 51. Candle was put out.
1/24/2015	6:18:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L318	While there was a smokey odor present, no smoke was seen. Smoke detector was reset. When students returned later, RA Butler questioned them and they stated that the smokey odor was due to their dirty clothes that they wore camping the previous night.
1/21/2015	6:30:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Residents were cooking in the kitchen and smoke caused the alarm to trigger. The building was evacuated, and the all clear was given by UAPD for residents to return to the building.
1/21/2015	6:14:00 AM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	na	Building alarm was activated and the building was evacuated. UAPD responded and determined that the fire alarm was set off by working being done with Tucson Water. UAPD gave the all clear
1/21/2015	6:06:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	na	City water issues
1/19/2015	9:05:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Smoke detector activated
1/19/2015	6:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	613	Cause believed to be a candle in room 613.
1/17/2015	9:00:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 385	Smoke detector went off because of an electronic cigarette. UAPD responded and reset panel.

1/15/2015	5:50:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Community Kitchen	Smoke in Kitchen
1/14/2015	11:48:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Fire	level 1 in S.E. lobby	Res. Life custodial was using a gum removing machine, which uses propane gas. The gum removing machine caught on fire, the custodian told a student to get help, the student called UAPD, and was told to "pull the pull station to evacuate the building". Another
1/12/2015	11:15:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	na	Contractor working on fire sprinkler system
1/4/2015	4:45:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 109 A	Resident was taking a hot shower and the steam from the shower caused the smoke detector to go into alarm.