

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/16/2016	10:30:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	By room 2	Steam pipe broken in room 3
12/12/2016	9:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room c320	Burnt popcorn
12/10/2016	5:38:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	na	Unknown
12/9/2016	10:27:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor of AZSO	Burnt food in kitchen
12/9/2016	11:06:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 427	Unknown
12/4/2016	10:40:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 371	Student vaping in room
12/1/2016	1:35:00 AM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	4th floor Navajo	Unknown-4th floor Navajo
11/30/2016	11:20:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 820	Burnt food
11/20/2016	9:40:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	Pull station level 2	Suspected resident pulled the pull-station
11/20/2016	12:23:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	906	Smoke from room 906
11/20/2016	10:50:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	S312 bathroom	Fire alarm went off due to smoke in bathroom from broken fan motor. No fire present
11/18/2016	2:40:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 710	Burnt food in room
11/17/2016	5:30:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor Study lounge	Smoke in study lounge
11/16/2016	12:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	Sonora side by 421	Resident of the floor loosened smoke head from base causing trouble on fire panel
11/14/2016	11:17:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 318	Burnt popcorn in room
11/1/2016	1:18:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	2nd floor pull station	UAPD inadvertently set off alarm
10/31/2016	8:04:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 340	Residents had a vap pen in room which activated the fire alarm.
10/27/2016	3:25:00 AM	182	El Portal	RESIDENTIAL - R2	False Alarm	Mechanical room	Unknown
10/25/2016	5:13:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 456	Burnt mac and cheese
10/21/2016	11:47:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor by room 346	Res. Life custodians shampooing carpets, floor drying fans stirred up the dust in the air, set off the smoke detector.
10/20/2016	11:43:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	In room 119C	Resident was cooking eggs. Pan was too hot and started smoking, she pulled the pan off the burner and splashed the burner with melted butter causing more smoke. She then panicked and grabbed a fire
10/17/2016	8:30:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Spray paint use in basement
10/17/2016	8:00:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	Room 314	Burnt popcorn
10/9/2016	2:52:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 109	Water leak on the 3rd floor.
10/9/2016	5:51:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 109	Water leak.
10/6/2016	11:08:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room D302	resident was smoking an electronic cigarette, and caused the smoke alarm to go off, UAPD talked to resident about smoking in the building.
10/2/2016	11:05:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Room 143	Unknown
9/29/2016	2:30:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Mechanical room	unknown
9/26/2016	2:36:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	in room 359	E cigarette
9/26/2016	2:26:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	In room 253	Burnt food
9/25/2016	11:50:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor hallway by room 346	Sensor malfunction
9/24/2016	12:36:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 552	Fire alarm malfunction

9/22/2016	12:00:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/22/2016	6:45:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/22/2016	6:45:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	7:45:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	8:05:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	7:14:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	6:24:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	6:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	6:17:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	7:15:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	7:15:00 PM	377	Rawls Eller Lodge	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2016	6:30:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2016	8:45:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2016	6:30:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2016	11:05:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 720	Burnt food
9/19/2016	6:30:00 AM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Risk management conducted a fire drill.
9/19/2016	7:40:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill completed by risk management.
9/19/2016	7:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Drill	na	Risk management conducted a fire drill.
9/19/2016	8:50:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Risk management conducted a firm drill.
9/17/2016	11:45:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	A resident burnt brownies in the Yuma Hall Kitchen.
9/14/2016	12:58:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	in room 226	Burnt food
9/13/2016	10:17:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	in room 422	Burnt food in microwave
9/12/2016	7:05:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	na	Burnt popcorn
9/10/2016	2:37:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In room smoke detector room 102	Pseudo point for in room sounder on
9/10/2016	2:25:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	AZSO kitchen	Cause of smoke undetermined
9/9/2016	8:19:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In room 125	Burnt popcorn
9/9/2016	11:59:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	UAPD proposed the alarm could have been cause by an e-cigarette. Exact cause of the alarm was undetermined.
9/9/2016	7:12:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Basement by room 10 smoke detector	Dirty smoke sensor
9/9/2016	7:25:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 220	Burnt popcorn
9/8/2016	1:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room A308	resident burnt popcorn in microwave.
9/8/2016	1:45:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room S-208	Student smoking an electric cigarette
9/1/2016	1:27:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basement center West smoke	Burnt food
8/31/2016	12:37:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor water flow	Student hit head sprinkler head deploying sprinkler system.
8/29/2016	7:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Communal kitchen	Burnt food
8/29/2016	7:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Communal kitchen	Burnt food in kitchen
8/29/2016	2:17:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora side in room 227	Steam from iron
8/27/2016	2:55:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Communal kitchen	Burnt popcorn
8/25/2016	9:13:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room D215	dirty smoke detector.
8/24/2016	12:30:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	a114	E-cig vapor
8/6/2016	4:00:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor	Pull station pulled by someone

8/3/2016	12:06:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	in elevator equipment room	student workers cleaning with hot water caused steam to condense
7/30/2016	3:30:00 PM	131	Likins Hall	RESIDENTIAL - R2	Nuisance Alarm	In room B256 Smoke/Sounder base	Faulty sounder/base
7/26/2016	8:35:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 29	Contractors working in the room tearing out part of the wall and causing dust.
7/25/2016	9:30:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 1B	Unknown
7/22/2016	12:33:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	in room B103	Cause unknown, Wi-Fi work being done as well as cleaning of the dorm rooms.
7/21/2016	2:45:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 343	Unable to determine cause of alarm after it was reset by UAPD
7/15/2016	6:05:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Main water flow	Suspected that one of the inspector test valves was left slightly open from the test that was performed earlier in the day. Suspect the slight seeping took a while to fill up the retard chamber again. Did
7/11/2016	12:57:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	By room 125 pull station	Painting contractors are power spraying the walls and spraying our equipment. Doing a poor job at trying to mask it.
7/4/2016	10:04:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	In room 268	Burnt popcorn. Fail to reset: Smoke head removed by resident.
6/26/2016	9:41:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	By room 158	Smoke detector was dirty.
6/23/2016	8:32:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke by room 230	Sanding walls
6/8/2016	10:32:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Pull station by stairs 2	Water from pressure washing
6/3/2016	8:37:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor West water flow	maintenance workers were moving furniture and broke a sprinkler head in room 312
6/2/2016	1:47:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	in room 272	Res. Life custodians were cleaning the rooms and caused dust to set off the smoke detector.
5/23/2016	9:15:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 226 - smoke detector	Vendor was cutting an access panel in the ceiling using a dremel tool
5/23/2016	10:32:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basment generator room heat	Generator service
5/17/2016	8:13:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Bldg. B 4th floor room 454	Custodian cleaning the smoke sensor
5/9/2016	6:46:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor in room D-202 east	Excessively dirty smoke sensor
5/7/2016	9:56:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food
5/2/2016	7:48:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 320	Burned food in microwave
4/30/2016	4:07:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Nuisance Alarm	in room 243	Smoke detector electronically failed.
4/30/2016	12:46:00 AM	377	Rawls Eller Lodge	RESIDENTIAL - R2	False Alarm	kitchen exit pull station	Pulled pull station
4/29/2016	1:24:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 357	Occupant of the room was cooking rice and produced smoke which set off smoke alarm.
4/27/2016	3:08:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	413	Unknown
4/27/2016	11:07:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In Bsmt. By room 8	Generator shop was cleaning out the generator room and swept dust into the air.
4/27/2016	6:30:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 242	Unknown
4/27/2016	7:47:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 242	Possible faulty smoke detector
4/27/2016	7:43:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 243	Unknown

4/16/2016	8:03:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 344	UAPD made contact with one of the occupants of the room. When she returned, she explained that her and some friends had been vaping in the room and set off the smoke detector. UAPD Event
4/10/2016	3:55:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	na	na
4/8/2016	7:19:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor pulls/smokes	Burnt food
4/7/2016	9:38:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In room 535A	Aerosol Mist?
3/30/2016	9:28:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	In room 322	Resident was cooking food in the microwave and burned it
3/27/2016	2:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	Nuisance Alarm	na	Fire alarm was set off by student using the fire extinguisher.
3/20/2016	6:40:00 PM	85a	La Aldea	RESIDENTIAL - R2	Fire	In room 208	Student was heating oil on the stove
3/8/2016	11:08:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room S208W	Student burned popcorn in microwave
3/7/2016	9:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 517	Fire alarm activated due to student vaping.
2/24/2016	11:33:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Bsmt by vending machines	Believe the detector to be dirty. Could find no other reason for the alarm.
2/22/2016	2:31:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor by Kitchen	Cooking oil spilled over hot burner of stove
2/20/2016	5:40:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor north	Someone pulled pull-station
2/17/2016	8:03:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 535	Unknown
2/16/2016	10:45:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 316	Burnt popcorn - Incident Number: V160470075
2/15/2016	10:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3 Center wing	UAPD arrived and determined cause to be a result of a student dropping their phone in the hallway. The phone apparently began smoking and set up the smoke detector in the 3-Center hallway.
2/13/2016	2:20:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke in kitchen
2/13/2016	1:15:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 354	Cause of alarm is unknown, but there was a vape in plain sight in the room.
2/11/2016	1:19:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	In room C432	Resident burned hot dog in the microwave. Event V160420036
2/6/2016	2:30:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Dumpster located on the southeastern side of Kaibab-Huachuca	Dumpster located on the southeastern side of Kaibab-Huachuca was smoldering due to possible heat from sun
2/5/2016	11:24:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room B112	Occupants left popcorn cooking in microwave when they left. Over cooked the popcorn.
2/3/2016	2:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Basement elevator lobby smoke detector	Smoke sensor
2/3/2016	1:42:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 947	Occupants cookie overheated.
2/2/2016	12:39:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In room 207	Reheating food
2/1/2016	12:08:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 3	Generator ran so long due to power outage it caused the heat detector to go into alarm.
1/31/2016	1:20:00 PM	131	Likins Hall	RESIDENTIAL - R2	Nuisance Alarm	2nd Floor South Wing	Pull station cover knocked off
1/23/2016	5:05:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	C215	Microwave in room C215 set off the room's smoke detector.
1/22/2016	7:57:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona side elevator	Students discharged fire extinguisher on 4th floor by elevator
1/22/2016	11:22:00 AM	182	El Portal	RESIDENTIAL - R2	False Alarm	3rd floor in room S319	Student using the micro wave oven. (Over cooked food)

1/19/2016	12:03:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	in room 100	A blind resident was cooking chicken in a toaster oven and over cooked his lunch. Causing the smoke detector to go into alarm.
1/13/2016	11:11:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In rm 322	Possible hair spray sprayed in the room.