

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/12/2017	1:22:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	By kitchen room 5	Student burned food in pan on the stove
12/10/2017	5:30:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Two rooms 311-312	Unknown upon investigation by UAPD
12/8/2017	2:25:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	na	Maintenance set off alarm
12/7/2017	10:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 630	Dust
12/7/2017	8:00:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	920	Smoke detector likely triggered by smoking in the room.
12/5/2017	4:00:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	222	Officer said everything was "fine" but did not tell DA what triggered the alarm.
12/5/2017	9:35:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	304	Burnt popcorn
12/4/2017	7:20:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 310	resident burn a bagel in the microwave
12/4/2017	6:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th floor in-room	Unknown
12/3/2017	7:30:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke in kitchen
12/2/2017	3:10:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	346	NA
12/1/2017	3:20:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor	Dirty smoke detector
11/30/2017	2:15:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 707	Burnt popcorn
11/28/2017	8:06:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor center West stairs	Dirty smoke
11/20/2017	6:25:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 202	Unknown
11/19/2017	3:55:00 AM	77a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor pull station	Resident pulled alarm
11/18/2017	8:15:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Basement Kitchen	Residents cooked on extreme heat which caused smoke to build up and set the smoke alarm off
11/18/2017	10:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	714	Resident over cooked food in microwave.
11/18/2017	1:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	E207	Resident over cooked food in microwave.
11/15/2017	6:10:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	2nd floor in room smoke	na
11/9/2017	1:26:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 409	Resident using vaporizer in room
11/8/2017	10:34:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food
11/7/2017	9:11:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor by kitchen 105	burnt item in microwave
11/7/2017	12:05:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	4th floor	Burnt popcorn
11/5/2017	3:20:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	920	Burnt popcorn
11/3/2017	3:40:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke from cooking
10/30/2017	12:25:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 411	Unknown
10/30/2017	10:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 451	Vaping in room
10/30/2017	8:54:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room B215	Dirty smoke detector
10/29/2017	8:35:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke from hamburger grease
10/27/2017	12:56:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 424	Burnt food
10/26/2017	2:37:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 314A	Unknown
10/25/2017	9:32:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	basement in electrical room 8A	maintenance working in the room dust from vac blew dust in the air and set off the smoke detector.
10/21/2017	7:15:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Fire	APSC Kitchen	Grease fire
10/21/2017	1:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor elevator lobby	Fire alarm in the 9th-floor elevator lobby area went off for an unknown reason.
10/18/2017	11:04:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	740	Determined cause to be vaporizer pen.
10/13/2017	4:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L202	Excessive vaping in room, door opened to hallway
10/11/2017	4:25:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Outside room 223 and 224	Spraying aerosol air freshener in hallway
10/9/2017	7:45:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th floor room	Burnt popcorn
10/6/2017	12:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 839	Most likely hair spray based on smoke sensor alarm data of 3.3% smoke level and being in alarm for a long time.
10/2/2017	1:40:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	372	Burnt popcorn
10/2/2017	11:20:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	447	Resident vaping in room

10/1/2017	4:13:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	na	Students smoking e-cigs in room
10/1/2017	7:06:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	D315	Unknown
9/28/2017	7:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	4th floor in room 449	Dirty smoke sensor
9/26/2017	6:25:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	322	Residents using e-cigarettes
9/25/2017	11:55:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor	Unknown
9/25/2017	8:20:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	211	Students burned popcorn
9/22/2017	3:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 227	Burnt popcorn in room
9/21/2017	7:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	118	Resident smoking in room
9/20/2017	7:15:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2017	6:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	Building	Fire drill
9/20/2017	10:55:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	A630	Burnt food
9/20/2017	7:30:00 PM	377	Rawls Eller Lodge	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2017	6:30:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	A203	Residents burned popcorn in their room
9/18/2017	8:35:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/18/2017	7:45:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/18/2017	7:44:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	in room 332	Hairspray
9/18/2017	9:30:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/18/2017	9:20:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/18/2017	10:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Centralized location	Fire panel bumped
9/18/2017	7:00:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/16/2017	2:30:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	4th floor electrical room	Electrical outage
9/15/2017	10:35:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Basement kitchen	Burnt food in kitchen
9/14/2017	10:50:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room A306	Vaping in room
9/13/2017	6:35:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	Building	Fire drill
9/13/2017	6:46:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	Building	Fire drill
9/13/2017	1:10:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 347	Unknown
9/13/2017	7:35:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	Building	Fire drill
9/13/2017	6:15:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	Building	Fire drill
9/13/2017	6:35:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Drill	Building	Fire drill
9/13/2017	6:54:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Risk Management - Residence Hall Fire Drill
9/11/2017	7:32:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	Entire	Fire drill
9/10/2017	1:10:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	226	Burnt food
9/9/2017	7:39:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor elevator lobby	Unknown
9/9/2017	11:37:00 AM	377	Rawls Eller Lodge	RESIDENTIAL - R2	False Alarm	na	Unknown
9/7/2017	2:55:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	2nd floor	Fire extinguisher discharged
9/6/2017	10:10:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	E403	Vaping in room
9/5/2017	9:30:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	s329	Burnt popcorn
9/5/2017	12:53:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	E322	Vaping in room
9/3/2017	7:50:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke in kitchen
9/2/2017	7:35:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	na	Pull station cover removed
8/30/2017	10:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor elevator lobby	Unknown
8/28/2017	10:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 810	Unknown
8/25/2017	5:40:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	A370	Resident vaping in room
8/24/2017	10:25:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 346	Smoke detector cause unknown
8/23/2017	11:50:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	smoke in room C344	Misting machine
8/22/2017	9:27:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Room 318	Room 318 burnt popcorn
8/21/2017	11:03:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	313	Smoke in 313 cause unknown

8/21/2017	1:45:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 313	Smoke detector cause unknown
8/20/2017	6:45:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 503	Burnt popcorn
8/20/2017	2:10:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Kitchen	Accidental
8/19/2017	2:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	D109	Unknown
8/19/2017	11:30:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	B-508	Burnt popcorn
8/17/2017	11:38:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 338	Steam in room
8/10/2017	9:30:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm		347 Possible humidity
8/8/2017	1:14:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	By room C106	Unknown, pull station normal upon our arrival
8/7/2017	5:41:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Basement Sonora Laundry Room	Lint trap burst.
8/6/2017	8:37:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona lobby	Smoke from flourescent lamp
8/4/2017	12:45:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Pull Station 8th Floor end of hall/809	Air conditioner motor was burning up
7/29/2017	12:41:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm		137 Smoke detector triggered - reason unknown
7/26/2017	6:45:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking
7/24/2017	8:25:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Smoke detector in room #5 (study lounge)	Air conditioning unit on blowing in the direction of smoke sensor
7/19/2017	9:00:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Nuisance Alarm		310 Roof leak
7/12/2017	4:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Lobby	The fire alarm went off due to the construction causing dust.
6/28/2017	8:55:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	By room 302 Huachuca	possible dust form construction
6/20/2017	11:43:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room B120	Unknown. Thought to be Possibly AC kicking on.
6/18/2017	8:08:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking/Burnt food
6/15/2017	1:05:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	By room 210 electrical room	drilling on wall
6/5/2017	11:05:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Room 238	Guest using vaporizer
6/1/2017	9:30:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L215	Unknown
5/26/2017	10:31:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	1st floor Bldg. H-I handicap room #117	Maintenance personal changing a bad sensor battery
5/10/2017	7:15:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor hallway	Student pulled pull station
5/10/2017	10:00:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Unknown
5/7/2017	3:40:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt popcorn
5/4/2017	2:49:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 906	Resident vaping
5/3/2017	2:52:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	In room 10	EMTs were grilling right outside the door the grill was right against wall the EMT was in the room when alarm was going off back door was open allowing the smoke to come in
5/2/2017	4:14:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 101	Tampering with smoke detector
4/30/2017	10:40:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 523	Burnt Popcorn
4/29/2017	9:35:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	na	Pull station pulled
4/28/2017	8:10:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	na	Burnt popcorn
4/27/2017	11:50:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	na	A student burned some popcorn in the building setting off the fire alarm and evacuating the building.
4/27/2017	7:39:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room C-108	Dirty detector
4/22/2017	4:03:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L Wing 3rd floor	Pull station pulled - unknown
4/21/2017	1:16:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	In 237	resident was trying to kill a wasp with hair spray, setting off the smoke detector
4/19/2017	10:40:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	By room 370 Graham	Unknown
4/15/2017	11:43:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor	Food in the microwave was what caused the smoke detector to go off.
4/11/2017	2:38:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	in Room 405 Smoke Detector	microwave pizza burnt

4/2/2017	3:25:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	By 350	It was determined that the station pulled (outside room 350) was pulled on purpose, but no evidence of fire was found
4/2/2017	10:40:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor	Food in the microwave was what caused the smoke detector to go off.
4/1/2017	12:45:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	D314	Unknown
3/30/2017	11:00:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	342	Burnt food in microwave
3/30/2017	10:40:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Fire panel	Unknown
3/30/2017	8:45:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B112	Burnt food in microwave
3/24/2017	2:45:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	na	Resident pulled alarm purposely for no cause
3/20/2017	1:21:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	in room 109A	Construction by RLM in the room caused the alarm
3/15/2017	7:57:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	In room C231	Res Life maintenance worker in room sanding drywall
3/10/2017	8:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	818	Burnt popcorn
3/9/2017	1:40:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 305	Burnt bread in microwave
3/9/2017	12:25:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	D212	Burnt popcorn
3/7/2017	2:33:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In Room 237	Students Vaping - smoke in the room
3/4/2017	2:35:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	by 903	Resident pulled the fire alarm in the hall as a joke.
3/2/2017	11:47:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 906	Resident was vaping in the room
3/2/2017	10:15:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	In room C419 (Smoke)	Burnt food
3/1/2017	7:18:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In room 802	Steam from student showering
2/25/2017	7:20:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	by 340	Residents smoking an e-cigarette in a resident room.
2/23/2017	10:05:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 313	Unknown
2/23/2017	7:19:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	170	Burnt food in room
2/21/2017	6:50:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Room 315	Burnt popcorn in a students room.
2/19/2017	10:40:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	Room 244	Uknown
2/18/2017	10:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 810	Residents vaping
2/17/2017	9:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 327	Burnt hair.
2/16/2017	9:53:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Room 148	Washer on 2nd floor over flowed. Flooding room 148.
2/16/2017	11:27:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 537	Student using hair straightener at time of the alarm
2/14/2017	10:05:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	308	Burnt popcorn
2/13/2017	2:50:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	in room B208	Occupant of the room was vaping on an e cig, caused the smoke detector to go in to alarm
2/12/2017	12:30:00 AM	377	Rawls Eller Lodge	RESIDENTIAL - R2	False Alarm	Basement	Unknown
2/8/2017	7:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	kitchen	Burnt food
2/7/2017	7:45:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	na	Burnt popcorn set off Smoke Detector in a student's room.
2/7/2017	7:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Resident burnt food in kitchen.
2/5/2017	2:25:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food
1/31/2017	10:14:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	113	Source unknown
1/30/2017	8:30:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L338	None
1/29/2017	3:16:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room L338	Excessively dirty smoke head
1/26/2017	1:15:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Bldg C Level 3 Room 328	Unknown
1/23/2017	10:05:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Student burnt something
1/23/2017	10:55:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	522	Resident burnt popcorn in room 522 and set up the smoke detector.
1/19/2017	10:35:00 AM	377	Rawls Eller Lodge	RESIDENTIAL - R2	False Alarm	Elevator	Elevator maintenance
1/16/2017	9:53:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L216 or L217	Possible use of vaporizer
1/15/2017	1:30:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	1st and 2nd floor	Unknown student accessed a fire extinguisher and sprayed it throughout the stairwell.
1/15/2017	2:00:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	APSC 364	It is believed that the residue, as a result of the discharged fire extinguisher, set off the alarm in room 364.
1/12/2017	1:42:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th fl; Room 426	6th FL-Fires extinguisher was discharged; 426-smoke from marijuana

1/6/2017	10:45:00 AM	182	EI Portal	RESIDENTIAL - R2	False Alarm	level 1 Deli Room 112	point was not bypass by Fire Safety
----------	-------------	-----	-----------	------------------	-------------	-----------------------	-------------------------------------