

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/16/2016	10:30:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	By room 2	Steam pipe broken in room 3
12/12/2016	9:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room c320	Burnt popcorn
12/10/2016	5:38:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	na	Unknown
12/9/2016	10:27:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor of AZSO	Burnt food in kitchen
12/9/2016	11:06:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 427	Unknown
12/4/2016	10:40:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 371	Student vaping in room
12/1/2016	1:35:00 AM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	4th floor Navajo	Unknown-4th floor Navajo
11/30/2016	11:20:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 820	Burnt food
11/20/2016	9:40:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	Pull station level 2	Suspected resident pulled the pull-station
11/20/2016	12:23:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	906	Smoke from room 906
11/20/2016	10:50:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	S312 bathroom	Fire alarm went off due to smoke in bathroom from broken fan motor. No fire present
11/18/2016	2:40:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 710	Burnt food in room
11/17/2016	5:30:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor Study lounge	Smoke in study lounge
11/16/2016	12:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	Sonora side by 421	Resident of the floor loosened smoke head from base causing trouble on fire panel
11/14/2016	11:17:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 318	Burnt popcorn in room
11/1/2016	1:18:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	2nd floor pull station	UAPD inadvertently set off alarm
10/31/2016	8:04:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 340	Residents had a vap pen in room which activated the fire alarm.
10/27/2016	3:25:00 AM	182	El Portal	RESIDENTIAL - R2	False Alarm	Mechanical room	Unknown
10/25/2016	5:13:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 456	Burnt mac and cheese
10/21/2016	11:47:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor by room 346	Res. Life custodians shampooing carpets, floor drying fans stirred up the dust in the air, set off the smoke detector.
10/20/2016	11:43:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	In room 119C	Resident was cooking eggs. Pan was too hot and started smoking, she pulled the pan off the burner and splashed the burner with melted butter causing more smoke. She then panicked and grabbed a fire
10/17/2016	8:30:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Spray paint use in basement
10/17/2016	8:00:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	Room 314	Burnt popcorn
10/9/2016	2:52:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 109	Water leak on the 3rd floor.
10/9/2016	5:51:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 109	Water leak.
10/6/2016	11:08:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room D302	resident was smoking an electronic cigarette, and caused the smoke alarm to go off, UAPD talked to resident about smoking in the building.
10/2/2016	11:05:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Room 143	Unknown
9/29/2016	2:30:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Mechanical room	unknown
9/26/2016	2:36:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	in room 359	E cigarette
9/26/2016	2:26:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	In room 253	Burnt food
9/25/2016	11:50:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor hallway by room 346	Sensor malfunction
9/24/2016	12:36:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 552	Fire alarm malfunction

9/22/2016	12:00:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/22/2016	6:45:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/22/2016	6:45:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	7:45:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	8:05:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	7:14:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	6:24:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	6:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	6:17:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	7:15:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/20/2016	7:15:00 PM	377	Rawls Eller Lodge	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2016	6:30:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2016	8:45:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2016	6:30:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/19/2016	11:05:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 720	Burnt food
9/19/2016	6:30:00 AM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Risk management conducted a fire drill.
9/19/2016	7:40:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill completed by risk management.
9/19/2016	7:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Drill	na	Risk management conducted a fire drill.
9/19/2016	8:50:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Risk management conducted a firm drill.
9/17/2016	11:45:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	A resident burnt brownies in the Yuma Hall Kitchen.
9/14/2016	12:58:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	in room 226	Burnt food
9/13/2016	10:17:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	in room 422	Burnt food in microwave
9/12/2016	7:05:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	na	Burnt popcorn
9/10/2016	2:37:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In room smoke detector room 102	Pseudo point for in room sounder on
9/10/2016	2:25:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	AZSO kitchen	Cause of smoke undetermined
9/9/2016	8:19:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In room 125	Burnt popcorn
9/9/2016	11:59:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	UAPD proposed the alarm could have been cause by an e-cigarette. Exact cause of the alarm was undetermined.
9/9/2016	7:12:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Basement by room 10 smoke detector	Dirty smoke sensor
9/9/2016	7:25:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 220	Burnt popcorn
9/8/2016	1:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room A308	resident burnt popcorn in microwave.
9/8/2016	1:45:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room S-208	Student smoking an electric cigarette
9/1/2016	1:27:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basement center West smoke	Burnt food
8/31/2016	12:37:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor water flow	Student hit head sprinkler head deploying sprinkler system.
8/29/2016	7:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Communal kitchen	Burnt food
8/29/2016	7:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Communal kitchen	Burnt food in kitchen
8/29/2016	2:17:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora side in room 227	Steam from iron
8/27/2016	2:55:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Communal kitchen	Burnt popcorn
8/25/2016	9:13:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room D215	dirty smoke detector.
8/24/2016	12:30:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	a114	E-cig vapor
8/6/2016	4:00:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor	Pull station pulled by someone

8/3/2016	12:06:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	in elevator equipment room	student workers cleaning with hot water caused steam to condense
7/30/2016	3:30:00 PM	131	Likins Hall	RESIDENTIAL - R2	Nuisance Alarm	In room B256 Smoke/Sounder base	Faulty sounder/base
7/26/2016	8:35:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 29	Contractors working in the room tearing out part of the wall and causing dust.
7/25/2016	9:30:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 1B	Unknown
7/22/2016	12:33:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	in room B103	Cause unknown, Wi-Fi work being done as well as cleaning of the dorm rooms.
7/21/2016	2:45:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 343	Unable to determine cause of alarm after it was reset by UAPD
7/15/2016	6:05:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Main water flow	Suspected that one of the inspector test valves was left slightly open from the test that was performed earlier in the day. Suspect the slight seeping took a while to fill up the retard chamber again. Did
7/11/2016	12:57:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	By room 125 pull station	Painting contractors are power spraying the walls and spraying our equipment. Doing a poor job at trying to mask it.
7/4/2016	10:04:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	In room 268	Burnt popcorn. Fail to reset: Smoke head removed by resident.
6/26/2016	9:41:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	By room 158	Smoke detector was dirty.
6/23/2016	8:32:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke by room 230	Sanding walls
6/8/2016	10:32:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Pull station by stairs 2	Water from pressure washing
6/3/2016	8:37:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor West water flow	maintenance workers were moving furniture and broke a sprinkler head in room 312
6/2/2016	1:47:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	in room 272	Res. Life custodians were cleaning the rooms and caused dust to set off the smoke detector.
5/23/2016	9:15:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 226 - smoke detector	Vendor was cutting an access panel in the ceiling using a dremel tool
5/23/2016	10:32:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basment generator room heat	Generator service
5/17/2016	8:13:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Bldg. B 4th floor room 454	Custodian cleaning the smoke sensor
5/9/2016	6:46:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor in room D-202 east	Excessively dirty smoke sensor
5/7/2016	9:56:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food
5/2/2016	7:48:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 320	Burned food in microwave
4/30/2016	4:07:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Nuisance Alarm	in room 243	Smoke detector electronically failed.
4/30/2016	12:46:00 AM	377	Rawls Eller Lodge	RESIDENTIAL - R2	False Alarm	kitchen exit pull station	Pulled pull station
4/29/2016	1:24:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 357	Occupant of the room was cooking rice and produced smoke which set off smoke alarm.
4/27/2016	3:08:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	413	Unknown
4/27/2016	11:07:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In Bsmt. By room 8	Generator shop was cleaning out the generator room and swept dust into the air.
4/27/2016	6:30:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 242	Unknown
4/27/2016	7:47:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 242	Possible faulty smoke detector
4/27/2016	7:43:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 243	Unknown

4/16/2016	8:03:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 344	UAPD made contact with one of the occupants of the room. When she returned, she explained that her and some friends had been vaping in the room and set off the smoke detector. UAPD Event
4/10/2016	3:55:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	na	na
4/8/2016	7:19:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor pulls/smokes	Burnt food
4/7/2016	9:38:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In room 535A	Aerosol Mist?
3/30/2016	9:28:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	In room 322	Resident was cooking food in the microwave and burned it
3/27/2016	2:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	Nuisance Alarm	na	Fire alarm was set off by student using the fire extinguisher.
3/20/2016	6:40:00 PM	85a	La Aldea	RESIDENTIAL - R2	Fire	In room 208	Student was heating oil on the stove
3/8/2016	11:08:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room S208W	Student burned popcorn in microwave
3/7/2016	9:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 517	Fire alarm activated due to student vaping.
2/24/2016	11:33:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Bsmt by vending machines	Believe the detector to be dirty. Could find no other reason for the alarm.
2/22/2016	2:31:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor by Kitchen	Cooking oil spilled over hot burner of stove
2/20/2016	5:40:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor north	Someone pulled pull-station
2/17/2016	8:03:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 535	Unknown
2/16/2016	10:45:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 316	Burnt popcorn - Incident Number: V160470075
2/15/2016	10:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3 Center wing	UAPD arrived and determined cause to be a result of a student dropping their phone in the hallway. The phone apparently began smoking and set up the smoke detector in the 3-Center hallway.
2/13/2016	2:20:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke in kitchen
2/13/2016	1:15:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 354	Cause of alarm is unknown, but there was a vape in plain sight in the room.
2/11/2016	1:19:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	In room C432	Resident burned hot dog in the microwave. Event V160420036
2/6/2016	2:30:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Dumpster located on the southeastern side of Kaibab-Huachuca	Dumpster located on the southeastern side of Kaibab-Huachuca was smoldering due to possible heat from sun
2/5/2016	11:24:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room B112	Occupants left popcorn cooking in microwave when they left. Over cooked the popcorn.
2/3/2016	2:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Basement elevator lobby smoke detector	Smoke sensor
2/3/2016	1:42:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 947	Occupants cookie overheated.
2/2/2016	12:39:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In room 207	Reheating food
2/1/2016	12:08:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 3	Generator ran so long due to power outage it caused the heat detector to go into alarm.
1/31/2016	1:20:00 PM	131	Likins Hall	RESIDENTIAL - R2	Nuisance Alarm	2nd Floor South Wing	Pull station cover knocked off
1/23/2016	5:05:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	C215	Microwave in room C215 set off the room's smoke detector.
1/22/2016	7:57:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona side elevator	Students discharged fire extinguisher on 4th floor by elevator
1/22/2016	11:22:00 AM	182	El Portal	RESIDENTIAL - R2	False Alarm	3rd floor in room S319	Student using the micro wave oven. (Over cooked food)

1/19/2016	12:03:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	in room 100	A blind resident was cooking chicken in a toaster oven and over cooked his lunch. Causing the smoke detector to go into alarm.
1/13/2016	11:11:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In rm 322	Possible hair spray sprayed in the room.

Date	Time	Bldg#	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/6/2018	6:45:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Pod space 209/211	Steam from shower.
12/4/2018	10:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke detector-Rec room 102	Cooking
12/3/2018	6:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 214	Student microwaved tin foil. Event Number from UAPD #V183370031
12/1/2018	3:37:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 108	Burnt popcorn set off detector.
12/1/2018	8:20:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 856	Burnt food set off detector
12/1/2018	2:40:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 324b	Burnt food set off detector
12/1/2018	12:15:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 459	UAPD responded to reset the fire panel after a faulty detector was set off in LKNS-459.
11/20/2018	3:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 820	Unknown
11/18/2018	1:20:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In 326	Unknown
11/17/2018	5:05:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor pull station	Unknown
11/17/2018	11:51:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In 822	Unknown
11/16/2018	8:28:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	D317	Unknown
11/15/2018	10:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	room 838	Fire alarm going off in 838 but turned off when UAPD got to room. No known cause for trigger.
11/15/2018	1:15:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	By room 106	Burnt food
11/14/2018	12:29:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	By room353	May have been hit or bumped
11/13/2018	7:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In room 816	Contacts were dirty on smoke head.
11/13/2018	4:20:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room c205	Fire alarm activated due to burnt food from microwave.
11/11/2018	10:55:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Room 304	TFD and UAPD responded, no one was in the room. UAPD disarmed the alarm.
11/7/2018	12:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	room 746	Residents burnt popcorn in room
11/5/2018	7:40:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Possibility of a pot of beans in kitchen.
11/4/2018	3:29:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Room 302	A resident accidentally hit the fire alarm in the dorm study room, causing the alarm to sound and UAPD to be called but did not respond.
10/29/2018	8:30:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	304	Resident was straightening her hair and set off the alarm.
10/28/2018	2:40:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Room 308	Resident was straightening her hair and set off the alarm.
10/27/2018	8:20:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	In room - 2nd floor	Smoke detector possibly triggered by vaping.
10/24/2018	8:25:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 112	Flat iron.
10/23/2018	8:30:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking
10/18/2018	11:05:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	Room 214	Device was tampered with
10/18/2018	12:30:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	Navajo/Pinal	It is unclear why the alarm went off at the Stadium since we were located in Navajo Pinal.
10/17/2018	9:10:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Room 207	Resident using air fryer
10/14/2018	1:00:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 302	Building fire alarm possibly due to burnt popcorn.
10/11/2018	2:43:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	1st flr building H-I handicap rm 121	Burnt food
10/10/2018	12:20:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Room 304	Room alarm set off due to resident's straightening hair.

10/8/2018	8:35:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Room 371	Building alarm activated due to burnt popcorn.
10/8/2018	9:45:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 341	Room alarm activated due to steaming sheets in room.
10/5/2018	3:31:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	1st floor by kitchen	By student burning potatoe cakes in skillet
10/5/2018	3:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke from cooking in dorm kitchen.
10/5/2018	11:53:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	In room A208	Burnt popcorn
10/2/2018	11:55:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 204	Cause unknown
10/1/2018	1:45:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	NA	Unknown
10/1/2018	4:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt popcorn in kitchen.
10/1/2018	6:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke in the kitchen from cooking.
10/1/2018	4:55:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	El Portal	False alarm was triggered in the south building of Villa del Puente due to fire alarm set off in El Portal.
10/1/2018	7:40:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	El Portal	False fire alarm occurred in the south building of Villa del Puente.
10/1/2018	3:04:00 PM	182	El Portal	RESIDENTIAL - R2	False Alarm	Level 1 elevator lobby	Condensation from the rain was collecting on the detector, and causing the false alarms.
9/30/2018	8:13:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Room 118	Air freshner set off smoke detector
9/23/2018	10:40:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 106	Unknown cause of alarm
9/22/2018	2:00:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	316	Outlet sparking when hair dryer plugged in.
9/19/2018	10:15:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/17/2018	8:14:00 AM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	Stadium Construction Zone	Construction
9/17/2018	11:36:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	5th floor in room 520	Resident was cooking food in the microwave , the food was wrapped in aluminum foil.
9/17/2018	7:00:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L230	Smoke detector
9/16/2018	8:24:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	353	Residents had a candle.
9/13/2018	6:20:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
9/13/2018	1:33:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	9th floor	Fire alarm on the 9th floor was activated but UAPD couldn't find out where or why.
9/13/2018	6:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
9/13/2018	10:40:00 AM	377	Rawls Eller Lodge	RESIDENTIAL - R2	Drill	na	Fire drill
9/10/2018	9:37:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 646	Alarm activated by burnt popcorn
9/9/2018	10:50:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	CD Apartment	Fire alarm set off in CD apartment.
9/6/2018	4:05:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen in basement	Cooking in kitchen
9/3/2018	5:10:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke from cooking - no other details provided.
8/30/2018	11:34:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor by West center stairs	Residents were cooking bacon, smoke from the bacon set off the smoke detector
8/29/2018	8:35:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	411	Alarm activated by opening bag of popcorn under smoke detector
8/27/2018	7:20:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking burger.
8/27/2018	12:21:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	1ST FLR SANTA CRUZ IN 183	Steam iron for clothes

8/26/2018	7:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	706	Clothing steamer
8/26/2018	7:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	706	Clothing steamer. UAPD Case # V182380068
8/25/2018	5:55:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	758	Burnt toast
8/25/2018	10:51:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	550	Burnt popcorn
8/23/2018	10:30:00 AM	151	Babcock	RESIDENTIAL - R2	Nuisance Alarm	2nd floor in room B203 (Smoke detector) no answer	Trouble alarm was cause by the removal of the smoke sensor from its base.
8/17/2018	5:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	A430	Alarm in a dorm room went off due to a burnt pop tart.
8/16/2018	9:45:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room B-203	Dirty smoke contacts.
8/14/2018	8:00:00 AM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	Navajo/Pinal	Construction
8/14/2018	8:58:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B203	Smoke detector
8/6/2018	1:14:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Heat Detector, bottom of elev shaft	Determined that custodial had been using a hose to wash down outdoor corridors and got water in the elevator shaft getting the device wet.
7/29/2018	7:25:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In room 405 bed room smoke detector	Low battery alarm
7/20/2018	6:58:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Basement heat over 4160 Transformer	Contractor work heat from ambient air
7/20/2018	9:57:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In handicap room 100	Contractors resumed working in the room. Upon arrival there was a worker, wearing a respirator because of the dust he was creating, scraping the floor. I instructed them they are to not work any more and to leave campus for the day. Informed them they are wasting state resources by activating Fire Safety, UAPD and TFD for
7/20/2018	9:29:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In room 100	Contractors working on floor.
7/18/2018	12:35:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In handicap room 100	Contractors were cutting a hole in the quartz countertop to install a sink
7/17/2018	11:20:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	5th floor elevator lobby	Res life is moving new mattresses in, possibly hit detector with one
7/14/2018	6:05:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Fire alarm went off due to cover being lifted.
7/13/2018	9:35:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Fire alarm due to cover being lifted.
7/13/2018	1:43:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Building D LVL 3 Room D304	Candle in room
7/11/2018	7:45:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	Conference guest burnt food
6/27/2018	1:48:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	4th Floor Building C Water Flow	Contractor Lloyd Construction hit and broke sprinkler head. Superintendent Chris Velasquez shut down the 4th floor tamper himself preventing water from flowing.
6/12/2018	7:10:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	2nd floor	It was discovered that a Med Start Facilitator and a Med Start Counselor had engaged in a sage burning Native American ceremony within the building without notifying UAPD or Residential Life.
6/10/2018	11:14:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor in room 507 smoke detector	Dirty smoke sensor (M5-7)
6/4/2018	1:33:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor Kaibab by room 321	Sanding in rooms contractor IFS James is the supervisor outside contractor



5/25/2018	1:10:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Elevator electrical room	Elevator electrical room was filled with smoke
5/22/2018	2:24:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Level 1 in room 137	Contractors
5/21/2018	12:47:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room A222/D221	Dusting
5/10/2018	2:27:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor by room 127	dryer #13 burning hot caused smoke and strong burning smell in laundry room
5/5/2018	2:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 636	Unknown
5/3/2018	10:26:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	In room 161	Curling iron had residue on it that started smoking.
5/2/2018	11:35:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room B116	Resident was making a cookie in the microwave and it burnt
4/30/2018	10:00:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Santa Cruz west hall smoke detector	Smoke detector base
4/28/2018	10:00:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	na	Unknown cause of fire alarm activation.
4/24/2018	6:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 300	UAPD gave the all clear, and stated that an air freshener may have been the cause of the alarm.
4/24/2018	9:18:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	E319	Burnt food in microwave
4/14/2018	2:35:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Hallway	Source unknown
4/14/2018	2:19:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	na	Someone pulled pull station no location provided
4/14/2018	9:00:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	By janitor room 21	Student cooking in kitchen (Hot cooking oil)
4/12/2018	9:46:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food
4/6/2018	1:09:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 6	Student vaping in room
4/4/2018	8:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 300	Possible vaping by resident
4/1/2018	11:57:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Laundry room 11	Overfull lint trap in laundry room
3/28/2018	1:33:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th Floor	Fire extinguisher discharged
3/27/2018	9:10:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B110	Burnt popcorn
3/26/2018	9:29:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in kitchen
3/25/2018	7:00:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	Smoke in room c307	Found smoke detector cover off and broken, inner cover off and bent and base off the wall and screws bent.
3/20/2018	7:18:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 625	Steam for iron for clothing
3/15/2018	1:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room C223	Humidifier
3/14/2018	9:45:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	505	Burnt food in microwave
3/14/2018	4:25:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	C223	Air conditioning unit
3/13/2018	4:20:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	D308	Resident burnt food in microwave.
3/12/2018	4:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	425	Resident using vape pen.
3/12/2018	1:13:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room D311	Occupant using steam aroma diffuser
3/8/2018	2:50:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	Sierra Waterflow monitor	Contractors opened a valve for a part of the system they thought was deactivated. System still has water and is active.
3/8/2018	10:35:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	522	Burnt food in microwave.
3/4/2018	3:37:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke in kitchen. Source not identified in report.
3/2/2018	9:02:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Room 344	Students vaping in room
3/1/2018	12:48:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	By room 327	Window and door to the bathroom was open creating a breeze

2/27/2018	3:00:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor by room 327	air freshener was sprayed in hall
2/27/2018	7:40:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor West stair entrance	Someone discharged a fire extinguisher in the West stair well on the 4th floor
2/26/2018	9:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	715	Unknown
2/24/2018	7:01:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	110	Burnt hair from curling iron
2/24/2018	9:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor east wing	Cotton candy machine began to smoke
2/24/2018	10:11:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	A215	Residents vaping in room
2/23/2018	8:55:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor in room 116 south	Resident was cooking bacon and caused the smoke detector to go in to alarm
2/20/2018	10:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	607	Burnt popcorn
2/18/2018	3:10:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Pull-station - unknown
2/18/2018	3:10:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	FACP	Unknown
2/16/2018	5:44:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor manzanita by room 226	Cause unknown. UAPD had not reset the pull station.
2/16/2018	2:52:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	3rd flr in room D314	foot warmer in microwave gave off sent and steam
2/15/2018	1:21:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	N. Side in hall by janitors rm 21	Cooking in kitchen - burnt food
2/15/2018	8:39:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	By room B110	Device got wet and shorted
2/14/2018	5:30:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking smoke
2/14/2018	2:12:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room B304	Resident says he pulled something steamy out of the microwave and set off the smoke detector, what was observed was a haze in the room with a strong smell of cherry vape in the room, resident denies
2/4/2018	4:26:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Basement lounge	Steam from popcorn machine
2/4/2018	7:47:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room A207	Burnt cookies
1/29/2018	8:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 644	Student using hand held hair straightener
1/24/2018	3:23:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 229	UAPD suspected an e-cigarette
1/20/2018	5:00:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor	Unknown
1/20/2018	7:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor	Student set off a fire extinguisher.
1/18/2018	12:00:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 318	Residents vaping in room. Case V180170099
1/14/2018	11:58:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 941	Unknown
1/13/2018	10:29:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	51	Nuisance alarm in a students room.
1/13/2018	10:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in kitchen
1/12/2018	9:55:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	215	Burnt pasta in resident room
1/9/2018	6:40:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking
1/9/2018	6:40:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	D315	Resident was blow drying her hair and set off the alarm.
1/8/2018	10:15:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	na	Dust, no location provided.
1/7/2018	6:30:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Laundry Room	Resident overfilled washer which caused it to smoke.

1/1/2018	4:50:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	D300 Hallway	During winter closure, a hallway lightbulb overheated and causing smoke to occur and set off alarm
----------	------------	-----	------------------	------------------	-------------	--------------	--

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/16/2015	10:19:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	Smoke in room B-516	Dirty smoke detector
12/15/2015	7:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 804	Burnt food in microwave
12/14/2015	2:33:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Smoke in room b511	Burnt popcorn
12/3/2015	3:17:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 219	resident burnt food in the microwave
12/2/2015	7:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B215	Fire alarm activated due to vapor pen in resident room.
11/30/2015	7:30:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 137	Unknown but the sensor was contaminated with some sort of material.
11/22/2015	1:45:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 526	Smoking marijuana in room
11/21/2015	10:57:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	206	Burnt macaroni and cheese
11/18/2015	10:55:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	na	Steam from shower
11/15/2015	6:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	103	Smoke from cooking
11/15/2015	7:35:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 716	Burnt food in microwave
11/14/2015	10:15:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke from burnt food
11/9/2015	11:15:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 248	E-cigarette possibly set off smoke per UAPD
11/8/2015	4:54:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	248	Unknown
11/6/2015	4:40:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	1st floor pulls	Pull station pulled-1st floor
11/6/2015	11:51:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor AZ rec. room	Students were cooking breakfast (fried bananas) and burnt the food causing it to smoke and set off the smoke detector.
11/5/2015	7:47:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Excess smoke from burnt food in the kitchen.
10/30/2015	4:48:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Fire	Kitchen	Burnt food
10/30/2015	10:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	323	Curling iron
10/30/2015	5:24:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	na	Steam from shower
10/30/2015	7:58:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Apartment 121	Steam from shower
10/30/2015	7:55:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 337	Possible faulty outlet or microwave
10/28/2015	10:45:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	Fire	Room 116	Paper lit with zippo lighter
10/26/2015	11:46:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora in room 821	Cause unknown. No smells or smoke in the room verified with UAPD who was in the room as well.
10/23/2015	1:32:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room L330	Wall-plug air freshener
10/22/2015	4:43:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Heat detector in attic M4-2	Defective device
10/22/2015	5:15:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Building A room A119 (Heat detector)	heat detector unknown-followup action required
10/21/2015	9:20:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	1st Floor South	Aerosol sprayed into hallway

10/20/2015	3:25:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor by room 266 smoke detector (APACHE SIDE)	Burnt popcorn
10/15/2015	9:20:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Community Kitchen	Burnt/smoky food in Kitchen
10/12/2015	4:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	Pull station activated - unknown reason
10/9/2015	11:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 431	Resident was using a close steamer on her close.
10/3/2015	12:55:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Kitchen	Faulty oven
10/1/2015	11:15:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in microwave
9/30/2015	2:14:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In room 217	Unknown
9/28/2015	6:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/28/2015	5:45:00 PM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/28/2015	8:05:00 PM	377	Rawls Eller Lodge	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/26/2015	12:15:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	315	Burnt food
9/26/2015	4:12:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 416	Student smoking
9/26/2015	3:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Fourth floor	Cause for alarm was unknown.
9/26/2015	3:03:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Fourth floor	Cause for alarm was unknown.
9/21/2015	1:48:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	in room 723	E-cigarette
9/19/2015	7:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room D212	Cigarette smoke
9/16/2015	5:15:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Community Kitchen	Smoke originated from burnt burgers on stove in community kitchen.
9/6/2015	9:56:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Common Kitchen	Burnt food
9/6/2015	1:40:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 117	Burnt french toast in the microwave
9/6/2015	9:25:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	na	Unknown
9/4/2015	3:30:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 361	Burnt food
9/3/2015	8:56:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 316	Student smoke E-cigarettes in room
9/3/2015	8:56:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 224 smoke detector	Student using a hot flat iron on hair below smoke detector
9/1/2015	12:06:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 226	Occupants smoking an electronic cigarette in room
8/31/2015	12:36:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 316	the smoke detector was dirty.
8/30/2015	9:05:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 316	Smoking in room
8/30/2015	5:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor	Pull station accidentally hit
8/27/2015	11:04:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 65	Unknown
8/25/2015	2:38:00 PM	182	El Portal	RESIDENTIAL - R2	Fire	na	Plastic bin left over stove under low heat
8/21/2015	2:57:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 622	Student was using a vapor cigarette in room

8/21/2015	10:58:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room b101	Stove left on in B101.
8/20/2015	2:36:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In room 100	Resident boiling water for tea. Believe steam set off detector.
8/19/2015	7:44:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room smoke detector 532	Student cooking Mac and cheeses in the micro wave oven
8/18/2015	10:00:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 433	Vapor pin
8/17/2015	5:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 407	It was an e cigarette in room 407 and both residents were absent.
8/10/2015	2:03:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 342	Res. Life custodial removed the smoke detector head to clean
7/29/2015	7:20:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	372	Burnt popcorn
7/29/2015	2:11:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	In room 226	E-cig vapor in room.
7/24/2015	7:15:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Room 119	Smoke Detector goes off in room 119.
7/22/2015	10:48:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	na	Construction workers were putting up dry wall and that caused the alarm to go off.
7/20/2015	6:15:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Top of ramp to sub-basement	Water damage from non working sump pump
7/19/2015	3:18:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Basement	Unknown
7/15/2015	8:48:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	basement in room 2	contractors digging up the floor stirred up dust causing the smoke detector to go into alarm
7/11/2015	11:00:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Top of north stairwell	Cleaned the top of north stairwell smoke detector. Contacts were corroded.
7/10/2015	11:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Nuisance Alarm	4th floor hallway	Fire extinguisher released by guests
7/9/2015	11:15:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Fire alarm went off due to excessive perfume and hair spray in teh basement fogging the smoke detectors.
7/9/2015	8:33:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	North side lounge area	Missed communication on the bypass procedure with contractor.
7/9/2015	10:30:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Main lobby	Contractor removing window frame to install new - cause dust to inter lobby
7/8/2015	2:45:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	635B closet	Unknown, Possible movers
7/4/2015	6:34:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 100	The cause of the alarm was unknown. Alarm unplugged to be reset
6/15/2015	7:02:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	It was determined that the cause was the overcooking of a science experiment conducted by the camp participants.
6/12/2015	9:01:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	By room 218	Contractor installing wifi in the bldg had spray painted a new access door within 10 inches of the smoke detector. Contractor did not call for a shutdown.
6/12/2015	7:47:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 157	Girls State had accidentally hit a sensor which was making alarm sound in room. No space evacuated, and CDOC to file Fire Report.
6/9/2015	1:00:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor center west	Res. Life custodial was washing the walls and washed the pull station and by doing this pulled the handle of the pull station with a rag.
6/9/2015	1:15:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	5th floor by room A518 above ceiling	Duct detector sensor dirty
6/4/2015	12:39:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Smoke by room 218	Contractors spraying
6/3/2015	9:57:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room	Unknown

6/2/2015	10:45:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor hallway	Unknown
6/1/2015	10:59:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Smoke by room 311	Fire alarm program
5/28/2015	1:52:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 658	res life painters in the room sprayed a aerosol primer witch set off the smoke detector. None of the painters left the room while it was in alarm.
5/19/2015	1:33:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	In room 324	Res. Life maintenance was moving furniture in the room causing dust to enter the smoke detector causing it to go into alarm.
5/18/2015	9:57:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basement generator room #3	Generator running an extended period of time due to power outage. Heat built up in the room and set off the heat detector. Found air filters on the vent for the room were extremely dirty.
5/13/2015	8:20:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Nuisance Alarm	na	Possible pull-station cover offset
5/12/2015	5:50:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Fire alarm set off at Maricopa by food burning in the kitchen.
5/12/2015	6:55:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	na	Fire alarm set off by a candle in a resident room.
5/9/2015	8:03:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	101	Cause determined to be burnt food in Community Director apartment.
5/4/2015	3:20:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Melted plastic on the stovetop in Hopi Kitchen caused the fire alarm to sound. UAPD examined the stovetop and the stove was not on at the time of the fire, but the top was warm. Evacuation of
5/3/2015	3:36:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3NE wing	Fire alarm going off due to water pipe valve being loose.
5/3/2015	2:56:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3NE wing	Water valve being loose in 3NE wing caused fire alarm to go off.
5/2/2015	3:09:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	Nuisance Alarm	First floor	Fire alarm going off due to fire alarm box being loose. No open flame present.
4/29/2015	11:36:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th floor in room 646	resident was spraying Lysol in the room that caused the smoke detector to go into alarm
4/10/2015	9:40:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In rm. L-309	Slight smell of hair spray in the air. Believe it got into the detector.
4/5/2015	2:35:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor greenlee east water flow	Someone turned the inspectors test valve causing the fire alarm to go off due to water flowing in the system.
4/2/2015	9:25:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	119	Unknown
4/1/2015	5:45:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	421	Unknown
4/1/2015	12:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	421	Unknown
3/31/2015	12:33:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	In room 306	Possible dust or mist
3/31/2015	9:10:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 265	Unknown
3/12/2015	7:55:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	C210 and D221	Smoke detectors - reason unknown
3/11/2015	8:48:00 AM	79/79A	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Fire	Kaibab TV lounge	a resident by the name of Kietzecume Garcia, told the building CD that " they were cooking food in the Kitchen and heard a pop sound on the stove, they turned around to find the burner on fire." the resident used a fire extinguisher to put out the fire then
3/8/2015	3:08:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	Sonora Tower	Discharged Fire Extinguisher

3/7/2015	7:40:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 106	Hair dryer set off smoke detector
3/7/2015	4:38:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in kitchen
3/7/2015	6:08:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	230	Unknown
3/2/2015	5:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt cooking in kitchen evacuated building. UAPD responded and cleared for reentry.
3/1/2015	1:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Fire	Kitchen	Cooking fire
2/25/2015	4:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 224	Burnt popcorn
2/19/2015	11:31:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor Arizona side	The 4th floor of Arizona side of AZSO was going off. UAPD arrived to reset the alarm. The smell of burnt popcorn was the source, but could not be determined what room it came from.
2/18/2015	3:02:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room A102	Burnt pizza in microwave
2/7/2015	3:56:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Nuisance Alarm	2nd floor	
2/6/2015	9:13:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Nuisance Alarm	3rd floor Navajo	Pull station bumped
2/5/2015	7:41:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	In room 133 smoke detector	Hair blower
2/5/2015	1:45:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 941	smoke detector was dirty
2/4/2015	1:00:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Build "C" main water flow	Point M2-3 not in bypass equation.
2/2/2015	8:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 257	Student steaming clothes
1/31/2015	8:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 448	Aerosol spray
1/24/2015	1:15:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Smoke in kitchen
1/24/2015	11:40:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 51	Smoke detector was set off due to a burning candle in Hopi room 51. Candle was put out.
1/24/2015	6:18:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L318	While there was a smokey odor present, no smoke was seen. Smoke detector was reset. When students returned later, RA Butler questioned them and they stated that the smokey odor was due to their dirty clothes that they wore camping the previous night.
1/21/2015	6:30:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Residents were cooking in the kitchen and smoke caused the alarm to trigger. The building was evacuated, and the all clear was given by UAPD for residents to return to the building.
1/21/2015	6:14:00 AM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	na	Building alarm was activated and the building was evacuated. UAPD responded and determined that the fire alarm was set off by working being done with Tucson Water. UAPD gave the all clear
1/21/2015	6:06:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	na	City water issues
1/19/2015	9:05:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Smoke detector activated
1/19/2015	6:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	613	Cause believed to be a candle in room 613.
1/17/2015	9:00:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 385	Smoke detector went off because of an electronic cigarette. UAPD responded and reset panel.



1/15/2015	5:50:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Community Kitchen	Smoke in Kitchen
1/14/2015	11:48:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Fire	level 1 in S.E. lobby	Res. Life custodial was using a gum removing machine, which uses propane gas. The gum removing machine caught on fire, the custodian told a student to get help, the student called UAPD, and was told to "pull the pull station to evacuate the building". Another
1/12/2015	11:15:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	na	Contractor working on fire sprinkler system
1/4/2015	4:45:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 109 A	Resident was taking a hot shower and the steam from the shower caused the smoke detector to go into alarm.

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/18/2014	9:28:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 109a	resident was taking a hot shower and the steam from the shower caused the smoke detector to go into alarm.
12/13/2014	11:20:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	ATTIC CENTER	Roof Leak
12/12/2014	7:45:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt chocolate caused fire alarm to go off.
12/8/2014	6:14:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L327 - Restroom	UAPD unable to determine cause, but likely to be steam or some form of aerosol. CDOC 1 to file fire report.
12/6/2014	1:30:00 AM	85a	La Aldea	RESIDENTIAL - R2	Nuisance Alarm	na	Pull station pulled
12/6/2014	2:44:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Nuisance Alarm	East stairwell	Discharged Fire Extinguisher
12/2/2014	12:52:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke by room 352	Dust from disturbed air vent caused alarm
12/2/2014	1:29:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke by room 352	dust from air return vent and possible smoke from room 352
12/1/2014	3:40:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	In Lounge 200/202	Smoke was from a hookah with "Blasting Berry" sented material.
11/29/2014	5:20:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	na	fire alarm went off due to fire sprinkler system issues.
11/26/2014	12:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Lobby	Possible dirty smoke detector
11/26/2014	1:30:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	220	Burnt food
11/24/2014	11:46:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room C 208	burnt Mac & cheese in residents microwave.
11/23/2014	10:52:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Lobby	On November 23rd 2014 in Apache Santa Cruz at 10:52pm, the RA's on duty noticed the cover on the fire alarm pull-station next to the double doors on the Santa Cruz side was closed but sounding an alarm. UAPD was called to inspect buzzing and reset, but alarm had stopped just prior to their arrival. A police aide inspected
11/22/2014	8:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L235	Smoke detector alarm sounded in resident room in Colonia de LaPaz residence due to e-cigarette vapor. UAPD responded to the scene and reset the fire panel.

11/21/2014	9:45:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor Manzanita elevator lobby	smell of hairspray in hall way by elevator smoke detector.
11/21/2014	1:30:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 317	Fire panel alarm sounded due to Lysol spray in isolated room in Yavapai. UAPD came and reset panel.
11/20/2014	4:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	D300	Fire alarm going off in residents room for unknown cause.
11/17/2014	8:02:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	Smoke in room D209	Dirty smoke
11/15/2014	5:20:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	na	Dirty smoke detector
11/13/2014	9:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 361	Burnt food.
11/11/2014	12:50:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Room 332	Burnt AC motor
11/2/2014	11:30:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Near elevator	fire alarm was set off due to dust collecting near an elevator, Building Evacuated.
11/2/2014	5:21:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	False Alarm	2nd floor kitchen	Burnt food
10/30/2014	2:26:00 PM	7/7A	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Smoke by room 330	Dirty smoke was probably bumped or disturbed.
10/30/2014	12:39:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	in room 317	resident was spraying Lysol in his room causing the smoke detector to go into alarm.
10/30/2014	1:11:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	in room C122	burnt popcorn
10/29/2014	9:10:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 273	Burnt popcorn
10/24/2014	1:36:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room 220	Popcorn a little overdone in the microwave.
10/24/2014	2:22:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	in room 343	resident was cooking food in a microwave and burnt it causing the smoke alarm to go off
10/23/2014	6:45:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 352	Smoke alarm going off in room 352 causing the building fire alarm to go off. According to UAPD, there was no fire that caused the smoke alarm to go off.
10/23/2014	10:28:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor	False fire alarm; building not evacuated.

10/18/2014	10:50:00 PM	85a	La Aldea	RESIDENTIAL - R2	Nuisance Alarm	4th floor pull station	Pull station pulled by unknown party
10/17/2014	8:47:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L 320	Smoke machine in room
10/16/2014	11:11:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	in room 422	resident burnt popcorn in their microwave, causing the smoke detector to go into alarm.
10/15/2014	7:20:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/15/2014	7:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/15/2014	8:50:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
10/15/2014	8:00:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/15/2014	6:10:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/14/2014	1:25:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 348	Burnt food
10/12/2014	5:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	na	No known cause.
10/8/2014	5:30:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	UAPD Responded but no cause was determined.
10/6/2014	7:20:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
10/6/2014	7:44:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	na	Fire drill
10/6/2014	8:02:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Drill	na	Fire drill
10/5/2014	1:15:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 115	na
10/4/2014	8:55:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 36	Individual room alarm went off, due to resident straightening their hair.
9/30/2014	8:40:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	7:30:00 PM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Fire drill

9/30/2014	8:00:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	6:00:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	5:45:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	5:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	6:55:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	9:50:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Fire drill
9/30/2014	9:30:00 PM	377	Rawls Eller Lodge	RESIDENTIAL - R2	Drill	na	Fire drill
9/28/2014	6:35:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 385	UAPD could not find cause of the alarm
9/28/2014	5:10:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	CD room 130	No known cause of alarm.
9/25/2014	1:13:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	na	Unknown person had pulled alarm.
9/25/2014	1:17:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	7th floor room 705	The all clear was given and residents were able to re-enter the building at 1:17am
9/24/2014	4:13:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 707	Cause was due to a resident steaming their clothes in the room.
9/18/2014	2:55:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	In room 305	resident of room 305 had removed the smoke head in the room. Both residents of the room denied removing the smoke head.
9/18/2014	9:55:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Building was evacuated following a fire-alarm. UAPD responded to reset the system, but no cause for the alarm was identified.
9/17/2014	12:45:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	Room 534	Cooking food
9/15/2014	1:39:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room L204	Occupants spraying febreze in room.
9/14/2014	5:25:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	kitchen	Pull-station
9/12/2014	2:24:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	hall by room 21	a resident was cooking in the kitchen and burn eggs setting off the fire alarm.

9/12/2014	3:23:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	637	Dust
9/11/2014	9:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 234	Burnt pop tart
9/11/2014	4:12:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room C304	Individual room alarm was sounding and UAPD responded to reset it. The cause for the alarm was burnt popcorn.
9/8/2014	2:36:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Fire	In room 862 in room smoke detector	Student ironing, using steam function under smoke sensor
9/8/2014	2:36:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 862 in room smoke detector	Student ironing, using steam function under smoke sensor
9/6/2014	6:37:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	3 SW, Greenlee	Fire alarm went off at approximately 7pm in Greenlee 3 SW due to resident who bumped off fire alarm cover. UAPD was notified and area was evacuated. RAs were able to replace the cover and turn
9/2/2014	7:15:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	na	Burning plastic
9/2/2014	1:40:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	na	Pull-station
9/2/2014	7:14:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Building Fire Alarm Reporting Point	Electrocution of spider by monitoring voltage created a limited current path which the monitoring system sensed as an alarm.
9/1/2014	11:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 424	Burnt food in microwave
9/1/2014	12:55:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Rom 804	Steam
8/30/2014	12:40:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	124	Unknown
8/29/2014	6:34:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	2nd Floor in room 217	Student hit fire sprinkler head in room 217.
8/28/2014	6:16:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Unknown
8/27/2014	2:39:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor Graham side	UAPD triggered system in error

8/27/2014	5:25:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room c115	UAPD determined that it was the iron steam in the room that caused the alarm to go off.
8/26/2014	2:07:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 622	Resident was cooking food in the microwave fell asleep burnt food causing smoke detector to go into alarm.
8/25/2014	8:27:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	B302	Unknown
8/24/2014	5:47:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Basement	Unknown
8/24/2014	1:24:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 467	na
8/24/2014	11:00:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Room 361	E-cigarette
8/23/2014	9:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food - popcorn
8/23/2014	5:49:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 272	na
8/22/2014	10:50:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 340	Smoke/vapor from hair styling device. Report f00131-2014
8/17/2014	4:58:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	10th floor pull station	Unknown
8/15/2014	3:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 532	Dirt from the air conditioner was blown into the air causing the detector to go into alarm.
7/18/2014	6:49:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 301	Unknown
7/3/2014	6:30:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Fire panel	Fire panel and alarm sounded due to "excessive heat" on the panel. UAPD responded to reset.
6/30/2014	6:55:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Fire pump run	Pipe break/water
6/21/2014	4:25:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	2nd Floor, NE Pull Station	No source found for alarm. UAPD responded and reset fire panel.
6/17/2014	11:39:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor Mohave by room 401	Staff cleaning the carpet in room 401

6/5/2014	10:00:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room b207	resident burned toast in microwave
6/3/2014	4:54:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	na	Electrician conducting work
5/26/2014	1:54:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Entire building	CRA calling to report building wide power outage had triggered building wide fire alarm. Informed CRA that ERLM and TEP were attempting to fix issue.
5/13/2014	11:25:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B202	RA room smoke detector sounding, UAPD called to reset. False alarm.
5/11/2014	1:30:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	na	Prank
5/11/2014	2:11:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Pull station	Fire alarm went off due to loose pull station on first floor. Only first floor residents evacuated as it was a localized alarm and most residents could not hear it. UAPD arrived to fix pull station. No case
5/10/2014	8:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 944	Possibly dirty contacts
5/9/2014	1:50:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Building evacuated for a fire alarm caused by someone pulling a pull station in the building. Residents were given all clear to enter.
5/6/2014	1:54:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora by 413	Dirty smoke detector by room 413 Sonora
5/6/2014	1:19:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	413	Building was evacuated because of a suspected faulty fire alarm in room 413. This was the second time that this had happened that evening, and the fourth time over a period of 2 days. UAPD was contacted to ensure that fire safety was being dispatched to look at
5/5/2014	12:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th Floor Arizona side	Dust
5/5/2014	2:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	413	Cause was determined to be a dirty smoke sensor/dust in the 413 detector.
5/5/2014	5:46:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	413	Building had been evacuated due to a fire alarm originating from room 413. When UAPD went up to the room to inspect it, there was a hat covering the smoke detector. This was suspected to be the cause, although there was some uncertainty. UAPD reset the fire
4/30/2014	12:30:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 340	Burnt popcorn.
4/27/2014	3:57:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor Huachuca by 352	RA on Duty called to inform the CDOC that there had been a fire alarm. The building was evacuated, and UAPD and others arrived. No cause was determined, and no case number was given. Residents were given the all clear to return to the building. Added



4/26/2014	10:36:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 625	UAPD responded to hall and determined there was no fire in the hall, but that the alarm may have been caused by a candle or burnt hair. Residents were given the all clear to return to the
4/22/2014	10:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th floor study lounge	Fire alarm due to unknown cause. Building was evacuated. Fire panel reset.
4/18/2014	7:20:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 944	CORO smoke detector going off
4/17/2014	12:49:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 413	RAOD called to inform CDOC that fire alarm was triggered due to marijuana. UAPD knocked on student's door but there was no answer. UAPD will follow up with residents.
4/17/2014	10:32:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor by 413	Res. Life steam cleaning carpet and set off detector
4/16/2014	3:42:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	2nd floor	loose fire alarm cover
4/10/2014	8:15:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking
4/9/2014	11:12:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room B405	Cause of alarm was student burning a facial mask in the microwave.
4/7/2014	9:42:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor west study lounge	UAPD determined alarm to be due to electronic cigarette vapor. Event number: V140970071
4/7/2014	12:57:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 621	Unknown
4/7/2014	11:14:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room A206	Dirty smoke detector
4/6/2014	4:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 705	Unknown cause in AZSO 705 set of AZSO fire system at 4:30 AM. Building evacuated. Nothing found. Cleared by UAPD for re-entry at 4:50 AM.
4/3/2014	1:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 413	Fire alarm activated due to faulty smoke detector. Building evacuated. Fire panel reset.
4/2/2014	11:32:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 310	Deodorant being sprayed
3/29/2014	9:40:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Room 217	The alarm originated from room 217. UAPD determined that there was no apparent cause for the alarm. They reset the alarm system and cleared the building for reentry.
3/29/2014	9:45:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Room 213	The alarm originated from room 213. UAPD could not determine cause of alarm. The system was reset and the building was cleared for reentry.
3/24/2014	4:43:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	All present residents evacuated in a timely manner. UAPD responded as well.

3/23/2014	3:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Room 17a	Smoke detector in room due to steam
3/23/2014	1:20:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	D303	E-Cigarette set off smoke alarm in room.
3/17/2014	3:38:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	Room 384	Smoke detector batteries changed
3/14/2014	3:45:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 230	Smoking in room
3/11/2014	12:34:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room smoke alarm room 114	Student cooking in micro wave and forgot cooking time
3/4/2014	10:48:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 220	Dirt from the HVAC in the room caused the smoke detector to go into alarm.
3/1/2014	4:42:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room E310	A smoke detector was set off in VIDA E310 due to burned food. UAPD responded and reset the fire panel and checked to ensure that the smoke detector in the room were functioning correctly.
2/28/2014	8:05:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Maricopa alarm sounded for unknown reason. TFD and UAPD responded, found panel saying pull station activated, but none found. Panel and system reset.
2/26/2014	11:00:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	CDOC was called due to the fire alarm going off from a hair dryer. Hair Dryer had body powder inside and when dryer was turned on, powder was released in room causing alarm to go off. UAPD was unable to reset the alarm until the powder was gone. CDOC
2/22/2014	3:01:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	2nd and 3rd floor	Fire extinguisher
2/22/2014	2:20:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	P/S in lobby	Unknown individual pulled pull-station
2/20/2014	10:45:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen/Hallway	Burnt food
2/20/2014	11:05:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food
2/20/2014	7:55:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 369	Burnt popcorn
2/20/2014	10:40:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Study room 267	Dirty smoke detector
2/17/2014	11:35:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Between room 316 and 318	Probable cause of the fire alarm was a burnt protein bar in the microwave. The building was evacuated twice. UAPD pinpointed the incident happened between rooms 316 and 318.

2/16/2014	10:35:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	APSC Kitchen	Burnt food and smoke caused the APSC fire alarm to go off. APSC evacuated. Access back into APSC granted shortly thereafter.
2/13/2014	11:46:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room L317	resident of room L317 had a lit candle in the room which caused the smoke to go into alarm.
2/12/2014	12:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora side 7th floor by rm 705	res. Life custodial was cleaning the carpets on the 7th floor and set off the smoke detector.
2/11/2014	11:35:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	na	lthough the fire alarm went off, it was not due to a student. Instead, the fire pad in room A114 is dirty. The alarm may go off again in the future unless the pad is cleaned. (Leo contacted UAPD who
2/9/2014	1:10:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Lobby	na
2/8/2014	12:15:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	D510	Resident was cooking in room and poured water over hot food, which caused steam to trigger alarm. No fire occurred.
2/7/2014	4:30:00 AM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Wing 3c	Pull-station pulled
1/29/2014	12:19:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	1st Fl. Elevator Lobby	Custodial was steam cleaning carpets. Steam got into smoke detector.
1/24/2014	8:45:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	Kithcen	Fire extinguisher
1/23/2014	10:45:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 421	Smoke detector
1/23/2014	10:15:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	na	Discharged fire extinguisher
1/21/2014	10:20:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 245	Smoke from Telecom room
1/20/2014	12:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	na	na
1/18/2014	3:05:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Burnt food
1/17/2014	2:32:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	B3 Wing	Pull-station cover removed
1/16/2014	2:57:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room D-309	Unknown
1/15/2014	6:44:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room C109	Broken smoke sensor caused the alarm

1/7/2014	10:20:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora side by room 413	Custodians cleaning the floors caused the smoke detector to go into alarm.
1/6/2014	2:45:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	C and D wings	Discharged fire extinguisher

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/15/2013	11:00:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	na	Tampering with fire alarm controls
12/15/2013	4:26:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 705	Unknown
12/8/2013	4:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt popcorn
12/7/2013	12:35:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Trouble	Water valve near basement area	na
12/7/2013	5:08:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Trouble	na	Unknown
12/6/2013	7:30:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	2nd floor S Stairwell, Pima House	Fire extinguisher discharged
12/5/2013	6:40:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	In room D201	Dirty smoke/Fan running
12/3/2013	11:10:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	Main panel	Unknown. Per Joe B., The trouble was a power supply monitor, not batteries. Amp #2 or #3 was acting up.
11/30/2013	4:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	1st floor pull-stations	Unknown
11/29/2013	5:10:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	rm 13a generator trouble monitor	Unknown
11/27/2013	9:00:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Room 13	Custodian washed the laundry room with a hose, spraying water on the fire alarm devices in the room. This action caused the notification appliance to go no answer.
11/26/2013	10:30:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor	Painting
11/24/2013	9:01:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Nuisance Alarm	E4	Pull station
11/23/2013	2:20:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	2E Study Lounge	Smoke detector set off by dust
11/20/2013	9:25:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	na
11/20/2013	8:10:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 830	Burnt popcorn.
11/20/2013	2:45:00 PM	131	Likins Hall	RESIDENTIAL - R2	Nuisance Alarm	3rd Flr A-E Exit	Custodian was cleaning pull and somehow pulled the alarm.
11/19/2013	6:30:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in kitchen
11/19/2013	10:19:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Smoke in room 101	Cooking

11/16/2013	7:45:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	Room 269	Smoke detector
11/15/2013	4:05:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	Room 269	Resident was found to have been smoking a hookah pen moments before he had dismantled the room's smoke detector. The smoke detector was installed again. The building fire alarm was not activated.
11/13/2013	11:29:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	In room 314A	Unknown
11/13/2013	2:16:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	Bldg. A lvl 4 in room 416	Resident burnt popcorn in room caused the fire alarm to go off.
11/12/2013	10:30:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Trouble	In room B117	Resident removed smoke detector head.
11/7/2013	5:35:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor Graham waiting room	Dirty smoke sensor
11/7/2013	11:41:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Fire	In room 956	Source of fire looks to be the cord of the microwave unit.
11/7/2013	10:25:00 AM	151	Babcock	RESIDENTIAL - R2	Trouble	In room C303	Resident removed smoke head
11/3/2013	8:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Trouble	7th floor water flow	Ground fault caused too much noise on the Mapnet circuit.
11/3/2013	3:07:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	room 226	Candle.
11/2/2013	3:35:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	1st floor rec room	Residents lighting a ping pong ball on fire.
10/31/2013	12:20:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	1st floor community director office	Card #3 power supply/charger
10/27/2013	2:08:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	Nuisance Alarm	na	Pull-station pulled
10/24/2013	8:20:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor by 325	Unknown
10/24/2013	11:00:00 AM	182	El Portal	RESIDENTIAL - R2	False Alarm	In rooms 219	resident of the room was cooking breakfast, and set off smoke detector in room
10/22/2013	12:19:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	in room C307E	Resident cooking popcorn.
10/21/2013	3:30:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	322 study room	Aerosol
10/21/2013	11:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 516	Dirty smoke detector
10/17/2013	6:23:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food in kitchen.

10/17/2013	9:19:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	AZ/SO 325	Burnt popcorn, dirty smoke?
10/16/2013	9:59:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Room B405	Burnt popcorn
10/16/2013	7:35:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room d216	Cooking
10/15/2013	10:47:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona Tower 5th Floor	Burnt popcorn
10/14/2013	1:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Sprinklers	Sprinkler system shutdown
10/14/2013	2:50:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Panel	System network
10/13/2013	1:15:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	lobby	Smoke detector
10/13/2013	4:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	na	Steam from iron
10/13/2013	2:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Highland District office	Unknown
10/4/2013	7:38:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	CD Apartment	Burnt food.
10/3/2013	9:16:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor Sonora by 325	Burnt food.
10/2/2013	11:21:00 PM	123	Pueblo De La Cienega	RESIDENTIAL-R2	False Alarm	na	Dirty smoke detector
10/2/2013	1:35:00 PM	132	Arbol De La Vida	RESIDENTIAL-R2	False Alarm	Room 104/104a	Residence life custodial cooking popcorn in the microwave. Over did it a bit.
9/30/2013	11:28:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	By room 161	Cause was a hairdryer that blew dust into the detector into the hallway. Secondary to that the room occupant left her hot iron plugged in and lying on the desk when she evacuated the building.
9/28/2013	11:45:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	Trouble	na	na
9/27/2013	10:35:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor	Cooking omelet in kitchen - burnt
9/26/2013	11:45:00 PM	131	Likins Hall	RESIDENTIAL - R2	Trouble	na	Unknown
9/25/2013	12:00:00 AM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/25/2013	12:00:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	na	Mandated Fire drill
9/25/2013	5:45:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/25/2013	5:40:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/25/2013	7:01:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/24/2013	12:00:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/24/2013	6:45:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/24/2013	6:55:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/24/2013	7:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/24/2013	12:00:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/24/2013	12:00:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/24/2013	7:50:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/24/2013	12:00:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill

9/24/2013	12:00:00 AM	448	Parker House	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/23/2013	5:45:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/23/2013	10:00:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Drill	na	Mandated Fire drill
9/23/2013	7:15:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/23/2013	7:45:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/23/2013	8:05:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/23/2013	10:05:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	na	Mandated Fire Drill
9/23/2013	12:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Drill	na	Mandated fire drill
9/23/2013	12:00:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Mandated Fire drill
9/21/2013	11:00:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Residence Hall Kitchen	Fire alarm was triggered by burning toast in a toaster located in the Yuma Residence Hall kitchen area.
9/18/2013	7:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Multiple fire sprinkler valves one by one reporting closed	RLM did not fill out a shutdown request so we responded as if someone was tampering with the Life Safety system.
9/13/2013	1:20:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 272	Smoke detector
9/10/2013	8:07:00 AM	79/79A	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 22	Operation of a non-filtered vacuum cleaner by personnel
9/10/2013	12:13:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	1st Floor East Elevator Lobby	Wet sensor and base caused false alarm.
9/9/2013	6:44:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 421	Dirty smoke
9/9/2013	2:00:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	in room 909	tenants removed smoke head.
9/8/2013	1:15:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking
9/8/2013	3:45:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	Nuisance Alarm	Northeast courtyard door	N/A
9/8/2013	11:56:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	na	Burnt food
9/7/2013	5:07:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	na	na
9/7/2013	1:17:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	na	Burnt popcorn
8/30/2013	10:30:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	In room 424	Burnt popcorn set off smoke detector



8/30/2013	7:03:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Trouble	Lvl 6 Elev. Lobby Heat Bldg. A	Open circuit
8/28/2013	3:15:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 246	Burnt food.
8/27/2013	5:00:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Trouble	4th floor Sonora (room 433)	Low battery
8/26/2013	7:56:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	na	Unknown
8/25/2013	4:54:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Mutiple rooms on second and third floors	Dust and moisture from students moving in.
8/15/2013	5:25:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Staff Office	Spray paint
8/14/2013	1:05:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	In room 236	Blower/dryer in room 236 blowing forcefully in room caused the smoke sensor to go in alarm.
8/8/2013	11:46:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Elevator Machine Rm. 111	Painter using oil based paint in room
7/30/2013	7:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	by 102	Cooking
7/24/2013	7:30:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor South East elevator	Custodial personnel washing walls with water hose
7/20/2013	11:30:00 AM	448	Parker House	RESIDENTIAL - R2	False Alarm	Room 2	Smoke detector
7/18/2013	6:18:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Trouble	In bathrooms	Unknown
7/13/2013	12:53:00 PM	79/79A	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Room 229	perfume sprayed in room
6/18/2013	3:00:00 PM	131	Likins Hall	RESIDENTIAL - R2	False Alarm	m5-33 building c level 1 rm 135D, m3-27 building b level 1 rm A113	Air filters being changed, dust set off the duct detectors

6/5/2013	9:45:00 AM	85a	La Aldea	RESIDENTIAL - R2	Trouble	C building Northeast stairs	RLM washing down stairwell wet devices
5/29/2013	10:05:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor Smokes and Pulls	Res life cleaning registers with vacuum. Exhaust blowing directly into Smoke detector.
5/19/2013	8:00:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	Trouble	In room 512	Ground on the mapnet 5 circuit
5/10/2013	2:14:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	In room 272	Student in room said he was moving and cleaning the room
5/9/2013	2:20:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor AZ/SO kitchen	Burnt food
5/7/2013	2:16:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 831	resident was cleaning out room set off in room smoke detector
4/15/2013	2:38:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	facp	Fire safety working on network
4/13/2013	6:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen in 100	Cooking
4/10/2013	3:30:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Trouble	5th floor A building	Card 51 hung up.
4/9/2013	2:00:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Trouble	Card 9	Failed card
4/7/2013	5:03:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th Floor by rooms 608, 616, and 620	Fire extinguisher discharged on 6th floor.
4/6/2013	11:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	in room 111	Dirty Smoke Detector
4/6/2013	3:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor Arizona	Faulty alarm
3/29/2013	9:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Trouble	Room 34 and 5	Dirty smoke and other.
3/26/2013	12:45:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	1st floor elevator	Heat detector
3/25/2013	10:31:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	B204	Possible shower steam or hairspray.
3/24/2013	2:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	520	Resident smoking marijuana in room and set off alarm
3/24/2013	4:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	5 AZ	Faulty filter
3/9/2013	8:05:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Lodge kitchen 1st floor	Burnt eggs
3/8/2013	7:18:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In room 101	Cooking

3/5/2013	1:50:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 302	Student cooking in the micro wave oven.
3/1/2013	1:33:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	1st flrm D107	Strong smell of cologne in room caused the smoke detector to go into alarm
2/28/2013	7:50:00 AM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	In room 117	Resident burned food on stove and caused the alarm
2/26/2013	1:58:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	1st Floor Kitchen	Girl burnt shrimp in kitchen
2/26/2013	2:55:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	109c	Fire safety working on network
2/24/2013	1:15:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	3rd floor NW pull station	Someone removed pull-station tamper proof cover
2/22/2013	4:20:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	By A219	Burnt food
2/21/2013	7:40:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food, smoke detector
2/18/2013	1:06:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	First floor lobby	Smoke detector
2/13/2013	9:19:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 258	Steam from shower set off detector
2/10/2013	4:50:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Fire	B105 Kitchen	Grease fire
2/7/2013	9:11:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Room d307	Heavy smoke in room
2/5/2013	7:45:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	By room 324	Dirty smoke detector
2/5/2013	1:50:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	Room 32	Student cooking cheese sticks in microwave
2/3/2013	3:15:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 269	Burnt food
1/21/2013	1:50:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen room 123	Burnt pan
1/13/2013	8:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	413/411	Residents used baking powder to mask the smell of vomit and then vacuumed the carpet which stirred the powder into the air and set off the sensor.

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/18/2012	8:34:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd fl KAHU by rm 329	Bad contacts on detector
12/16/2012	9:14:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	221A	Unknown
12/16/2012	12:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	1st floor room 117	Smoke detector
12/14/2012	5:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	C112	Burnt popcorn
12/13/2012	7:46:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor elevator lobby	Device defective need replace
12/12/2012	7:41:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	2nd floor in room C212	Student showering in bath room with door
12/10/2012	3:00:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	na	Fire Safety working on network
12/10/2012	10:44:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Panel	Power outage
12/9/2012	7:10:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	305	Burnt popcorn
11/30/2012	3:10:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th floor Sonora by room 613	Burnt popcorn in room 617. Microwave under bed on carpet.
11/29/2012	10:40:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L-206	Strong smell of cologne or air freshener in the room, caused smoke detector to go into alarm
11/26/2012	4:11:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B209	Unknown
11/22/2012	2:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	109 Kitchen	Burned stuffing in community kitchen
11/19/2012	7:00:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	B2 Side Hallway	Cooking
11/18/2012	11:20:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 26	Burnt popcorn in Microwave
11/15/2012	10:50:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	House side, 3rd floor	Smoke detector sett off by popcorn
11/14/2012	10:30:00 AM	151	Babcock	RESIDENTIAL - R2	Trouble	In room C212	resident of room had removed smoke head from base.
11/12/2012	1:30:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Fire	1st floor North West Lounge by room 151	Lounge sofa chair set on fire
11/11/2012	1:45:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B308	Cooking in microwave
11/10/2012	5:45:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	1W by 101	Cooking / non-fire
11/10/2012	8:45:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	206	
10/28/2012	5:41:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Community Kitchen	Burnt food
10/26/2012	3:44:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Fire	Main Riser	Couch buring in room 114. Arson caused.
10/25/2012	1:57:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	304	Burnt popcorn
10/25/2012		123	Pueblo De La Cienega	RESIDENTIAL - R2	Fire	1st floor TV lounge and 2nd floor kitchen	Unknown person
10/23/2012	7:35:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Mechanical room 226	Smoke detector - unknown
10/21/2012	5:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	945	Resident discharged fire extinguishers, no fire
10/20/2012	11:28:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor	Pull-station - Unknown
10/20/2012	11:10:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Nuisance Alarm	3rd Floor Laundry Room/Rec Room	Wet towel in microwave
10/19/2012	1:35:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor by room 329	Burnt popcorn in room 339 triggered smoke detector
10/19/2012	1:30:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	339	Burnt popcorn
10/18/2012	2:30:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Stove burners left on in kitchen.
10/16/2012	9:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona Lounge Kitchen	Cooking
10/13/2012		5	Coconino Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	3rd Floor, South Wing by 312	It is unknown who discharged the fire extinguisher, a police report was filed. No fire alarm went off.

10/11/2012	6:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	Front desk	Unknown
10/11/2012	9:29:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	Front Desk	Unknown
10/11/2012	6:18:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Trouble	na	Unknown
10/8/2012	9:52:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen in Arizona Lounge	Resident using kitchen
10/8/2012	10:07:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Trouble	na	It was later reported that there was electrical issues due to construction around campus. There was no evacuation necessitated.
10/7/2012	7:55:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	385	Burnt food.
10/6/2012	7:50:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	104	Burnt food on stove
10/4/2012	11:51:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	na	Unknown
10/1/2012	7:30:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L349	na
10/1/2012	10:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	L207	na
9/28/2012	8:17:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Common room between 305/304	Smoke from curling iron
9/25/2012	7:35:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen in apartment 120	Burnt food
9/23/2012	8:05:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	Emergency Evacuation	na	Fire in adjoining building
9/21/2012	11:20:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	D503	Blow Dryer
9/18/2012	7:57:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	3rd floor room 348	Student taking a hot shower
9/16/2012	6:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor	Unknown
9/16/2012	6:45:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	221/227	Smoke detector
9/15/2012	12:00:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	221/227	na
9/15/2012	2:40:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B207	Tampered smoke detector
9/13/2012	6:25:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Drill	Front desk	Scheduled drill
9/13/2012	7:05:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Drill	Staff Office	Scheduled fire drill
9/13/2012	6:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/13/2012	7:30:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	8:50:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	7:30:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	1:57:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 501	Possible contact issue
9/12/2012	6:50:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	Lobby	Scheduled drill
9/12/2012	5:50:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	Lobby	Scheduled drill
9/12/2012	5:56:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	6:00:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/12/2012	8:07:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Drill	Lobby	Scheduled drill
9/11/2012	6:00:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/11/2012	6:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/11/2012	6:40:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/11/2012	8:25:00 PM	85a	La Aldea	RESIDENTIAL - R2	Drill	na	Scheduled drill

9/11/2012	7:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	Front exit pull-station	Scheduled drill
9/11/2012	7:30:00 PM	131	Likins Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/11/2012	8:15:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Main mechanical room	See Joe B.
9/10/2012	6:45:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	By 104	Scheduled drill
9/10/2012	6:00:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/10/2012	5:51:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	Front desk	Scheduled drill
9/10/2012	8:00:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	Lobby	Scheduled drill
9/10/2012	7:10:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled drill
9/10/2012	7:30:00 PM	448	Parker House	RESIDENTIAL - R2	Drill	na	Scheduled drill.
9/9/2012	1:30:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Card 4 power supply located basement (miniplex)	Batteries low voltage
9/8/2012	11:47:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	na	Bad device.
9/7/2012	2:00:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	Outside Laundry room	Discharged Fire Extinguisher
9/7/2012	4:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	1st floor	Unkown cause.
9/7/2012	5:47:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Elevator equipment room	Possibly dirty contacts and high humidity.
9/4/2012	12:05:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	273	Burnt food
8/31/2012	3:30:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	5th floor Manzanita by 548	Fire extiguisher discharged intentional
8/29/2012	10:45:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	221	Smoke detector triggered by candle, incense aromatherapy device
8/25/2012	8:05:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Fire	Pull Station in Room 330	Motor fire in fan coil in room 330.
8/24/2012	8:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Lobby Fire Panel	Upon further inspection, the UAPD officers could discern nothing wrong with the smoke detectors and reset the system.
8/24/2012	2:13:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 264	Dirty smoke detector
8/24/2012	2:15:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm		Dirty smoke detector
8/22/2012	9:43:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	D302	A slight smell of hair sprsay in the room, cleaned smoke as a precaution
8/18/2012	4:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Room 513	Resident of room burned popcorn in microwave
8/18/2012	1:02:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	Unknown
8/18/2012	11:25:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 328	COOKING POPCORN
8/17/2012	11:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Trouble	Room 272	Tampering with smoke detector
8/14/2012	9:05:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 321 a/c	Unknown
7/19/2012	10:01:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 330	inoperative smoke sensor
7/19/2012	9:36:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor east hall by south exit	Inoperative horn/strobe
7/17/2012	1:30:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Panel	Unknown
7/16/2012	7:02:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 724	Unknown
7/4/2012	11:30:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor in room D-307	Dirty smoke sensor
6/27/2012	7:35:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	A003 Main water flow	water flow switch
6/21/2012	10:55:00 AM	123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Fire panel	UAPD testing?
6/20/2012	8:19:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor by room 741	Vendor ctting sheet metal - site superisor was notified of the incedent
6/12/2012	2:39:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor by room 804	Painters
6/11/2012	1:49:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor in room 735	Painters

6/11/2012	1:42:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor in room 835	Painters
6/11/2012	1:33:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 935	Painters
6/4/2012	10:15:00 AM	7/7A	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Trouble	Bsmt Mohave Elev Lobby and 5th Flr Manzi by 540	Custodian with the best of intentions to ensure a clean facility. Status on Departure: Sprinklers bypassed for valve change out in basement.
5/22/2012	12:29:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	3rd floor in room 371	Cleaning around base
5/22/2012	2:00:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm		Solar Panel construction workers were welding pipes and shut it off on two separate occasions. The construction crew stated the entire system was supposed to be shut down during their work (12am-
5/22/2012	2:00:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	na	Construction workers
5/15/2012	9:15:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	In room A107	Burnt food
5/14/2012	8:25:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	In mechanical room 179	Res-Life contractors
5/13/2012	1:00:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	2nd floor room 2a	Dirty smoke sensor
5/13/2012	5:00:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	2nd floor in room 2A	Unable to locate the class A abnormal condition at this time - further troubleshooting is required to accurately find the problem
5/12/2012	12:00:00 PM	85a	La Aldea	RESIDENTIAL - R2	Trouble	201	na
5/11/2012	9:50:00 AM	448	Parker House	RESIDENTIAL - R2	False Alarm	na	Unknown
5/10/2012	8:19:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor by room 537	Contractor cutting dry wall by room 537
5/10/2012	8:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor smoke detector in room 825 and 823	Contractor cutting dry wall in rooms
5/7/2012	10:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 329	Contractor painting door jamb
5/6/2012	2:10:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	MZMO 328	Unknown
5/6/2012	11:53:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Trouble	Graham room 246	Unknown
5/4/2012	10:16:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	By room 236	Contractor, building under construction
4/26/2012	11:59:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 225	Sweeping the floor in room 225 cause dust to acumulate in room
4/19/2012	4:30:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Trouble	Card 4 power supply	Negative earth ground in system
4/19/2012	7:58:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th floor by room 649	Contractor sweeping the hallway by room 649
4/18/2012	10:01:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 604	Construction
4/18/2012	8:44:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor in room 862	dry wall cutting near room 862
4/18/2012	8:56:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	6th floor in room 606	Contractor sanding dry wall near room 606
4/16/2012	9:22:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor in room 508 smoke detector	Dirty smoke sensor
4/14/2012	7:25:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor kitchen	Burnt food
4/13/2012	11:08:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In rm 356	Construction workers
4/13/2012	12:02:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In rm 561	Construction workers
4/7/2012	6:10:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	5-Mohave-Men	Someone pulled pull-station
4/5/2012	10:45:00 AM	423	Sky View Apartments	RESIDENTIAL - R2	False Alarm	416	Excess dust
4/4/2012	2:07:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 953	contractor painting around smoke sensor
4/4/2012	2:22:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor in room 752 smoke detector	Dust from contractor cleaning room
4/2/2012	11:48:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 205 smoke detector	Painter in room 205 working around the smoke sensor
4/2/2012	8:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 205	Vendor dry wall sanding

4/2/2012	10:15:00 AM	151	Babcock	RESIDENTIAL - R2	Trouble	Bldg. D 2nd floor room 205	Dirty smoke sensor
3/30/2012	12:41:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 926	Painter in room 926 removed smoke sensor
3/30/2012	10:20:00 AM	448	Parker House	RESIDENTIAL - R2	Trouble	2nd floor hallway	Someone disconnected smoke sensor from its base
3/24/2012	4:12:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	By A230	Pull-station
3/22/2012	1:21:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 907/By room 909	Construction work
3/19/2012	1:16:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 506 & In room 834	Building is under construction, dust
3/9/2012	8:24:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 920	Open window caused blowing dust in room
3/9/2012	8:24:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor by room 948	Open windows caused blowing dust
3/8/2012	2:36:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor in room 528	Contractor Sanding dry wall
3/8/2012	4:50:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 909	UAPD report alarm caused by contractor work in building
3/7/2012	2:14:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor smokes/pulls	Possibly wind and dust related
3/5/2012	10:45:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 209	Contractor
3/5/2012	10:57:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 209	Contractor
3/5/2012	2:40:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	9th floor in room 926	Contractor sanding dry wall in room
3/3/2012	10:31:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Smoke detector in room 525 (M5-25)	Contractor
3/3/2012	12:22:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 529 (M5-29)	Contractor
3/2/2012	10:41:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 336	Vendor cutting through plaster in room 336
3/1/2012	2:35:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th floor in room 557	Sanding dry wall by vendor
3/1/2012	2:33:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd floor in room 208	Sanding dry wall by vendor
2/29/2012	7:02:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	First floor	Cooking - non - fire
2/29/2012	6:50:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	First floor	Unknown
2/29/2012	1:51:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	4th floor in room 442	Vendor sanding on drywall
2/28/2012	12:10:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor in room 342	Vendor spray painting
2/27/2012	3:01:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th flr in room 731	Sweeping in room 731
2/27/2012	11:25:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 844	Construction/wind
2/27/2012	7:56:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	2nd flr in hall way	Sweeping in hall way by vendor
2/24/2012	8:12:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Sonora 7th floor	Cooking - non- fire
2/24/2012	9:45:00 AM	131	Likins Hall	RESIDENTIAL - R2	Trouble	Tamper in room 126	Unknown
2/22/2012	2:40:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	4th floor in room 406	Vaccum cleaner
2/16/2012	2:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	7th floor in rooms smoke detectors	Copper pipe under pressure blew apart (Bad solder connection)
2/16/2012	11:04:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor in room 834 smoke detector	sweating/soldering copper
2/16/2012	8:17:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	5th FLR in room 528	Vender in work area
2/14/2012	11:27:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 253	Someone cause dust to fly up in room 353 which set the smoke detector off
2/11/2012	4:05:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Elevator	UAPD could see no other cause for the alarm
2/11/2012	6:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor/kitchen	Resident was cooking dinner and created smoke, set off alarm by accident.
2/8/2012	11:00:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor in kitchen area	In kitchen area found burning toast in the toaster oven.
2/8/2012	10:00:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basement	Unknown
2/8/2012	10:30:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 228	Contractor workers dropped wood panels on the floor causing the dust to stir in the air which set the smoke detector off



2/4/2012	1:00:00 AM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Yava 3W by 315	Cooking
1/24/2012	9:00:00 PM	135	Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Room 221	Resident cooked pasta in microwave with out putting water in the container.
1/23/2012	10:03:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	In room 124 bedroom	Hair spray
1/20/2012	9:45:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Trouble	11	Water damaged device
1/20/2012	12:09:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona basement lobby	The cause of the alarm was a dirty smoke detector M1-57 basement lobby.
1/14/2012	9:15:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Trouble	Room 214	Smoke detector battery
1/11/2012	6:25:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Third floor room 319	Dirty smoke detector

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/22/2011	6:30:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	Nuisance Alarm	'A' Building	UAPD attributed the alarm to surging water, same as multiple other alarms
12/16/2011	4:00:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	na	Repeated water flow issue per UAPD
12/14/2011	2:25:00 AM	85a	La Aldea	RESIDENTIAL - R2	Nuisance Alarm	By 125	Unknown individual pulled pull station, no damages reported
12/13/2011	4:00:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	3-Mohave Women's Wing	Could not identify the person who pulled it as no witnesses came forward.
12/13/2011	11:20:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food
12/13/2011	3:50:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Roof Building C, AHU E5 Duct Detector	Water damaged duct detector test switch
12/12/2011	3:12:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Roof AHU B6.01 Duct detector	Unknown at the time of site investigation
12/10/2011	12:30:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm		Loss of water pressure
12/8/2011	5:00:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	Kitchen B101	Burnt food
11/28/2011	2:45:00 PM	131	Likins Hall	RESIDENTIAL - R2	Fire	3rd floor Waterflow	Someone started a fire to the paper towel dispenser in the mens restroom in room B352 and the sprinkler head released which put the fire out in the restroom. The fire caused significant damage to the wall, floor, and dispenser, and the room is closed down until
11/17/2011	6:45:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Room 124, Wing 1E	Burnt food
11/16/2011	6:35:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Burnt food Officer Kubik provided the following case number: U1111160034
11/14/2011	9:25:00 AM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Basement	Custodial cleaning
11/13/2011	1:30:00 AM	135	Pima Residence Hall	RESIDENTIAL - R2	Trouble	In room 106b bathroom	Strobe in room 106B bathroom going bad
11/5/2011	9:05:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Building B 2nd floor west end of hall near stairs	Leaking victaulic inside the wall connected to sprinkler riser
11/3/2011	10:20:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th floor by room 616	The smoke detector was dirty
11/2/2011	10:33:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	In room 139	The student was heating toast in microwave and it burned setting the alarm off
10/25/2011	5:00:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	Kitchen	Case #U1110250027 The fire alarm went off due to smoke coming from someone cooking chicken. The person cooking did not turn the hood on over the stove.
10/24/2011	10:20:00 AM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	Room 200	Burnt food. Students using illegal toaster.
10/22/2011	4:30:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm		Cause of the alarm was unknown, most likely the disturbed plastic cover
10/21/2011	11:11:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	SANP 2N	Fire alarm in the hallway was dirty which caused the fire panel to sound
10/21/2011	12:25:00 PM	423	Sky View Apartments	RESIDENTIAL - R2	False Alarm	Not determined	UAPD could not determine cause
10/21/2011	4:25:00 AM	423	Sky View Apartments	RESIDENTIAL - R2	False Alarm	not determined	Once again, UAPD could not determine the cause
10/21/2011	7:52:00 PM	423	Sky View Apartments	RESIDENTIAL - R2	False Alarm	na	Other, unknown
10/17/2011	6:40:00 AM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Basement	Water pressure issue with sprinkler control system in basement

10/13/2011	3:36:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th floor by room 616	Unknown - unable to pin-point cause
10/8/2011	4:00:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B204	The smoke detector was excessively dirty.
10/7/2011	11:35:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Trouble	206b	Dirty smoke detector
10/1/2011	2:30:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	Room 390	Burnt Food
9/27/2011	4:50:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Cooking
9/24/2011	10:33:00 PM	423	Sky View Apartments	RESIDENTIAL - R2	False Alarm	4th Floor, no specific room	Police officers said the alarm was set off on the 4th floor because of burnt food
9/20/2011	9:07:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	1st floor lobby	Scheduled drill
9/20/2011	9:30:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	Drill	p/s by 103	Scheduled fire drill.
9/20/2011	6:55:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	Drill	Greenlee Front Desk	Scheduled drill.
9/20/2011	8:28:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	Lobby	Scheduled fire drill
9/20/2011	5:45:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled fire drill
9/20/2011	9:50:00 PM	423	Sky View Apartments	RESIDENTIAL - R2	Drill	Front lobby area	Scheduled fire drill
9/15/2011	7:35:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	na	Scheduled Fire Drill
9/15/2011	8:20:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	Drill	Kitchen room 107	Scheduled drill
9/15/2011	8:00:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Drill	Front Desk	Scheduled drill with UA Risk Managemnet and ISG
9/15/2011	7:15:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	By B211A	Scheduled fire drill with UA risk management and ISG
9/14/2011	8:00:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	Drill	Lobby	RM&S requested fire drill
9/14/2011	7:30:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	Front desk	RM&S scheduled fire drill
9/14/2011	8:00:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	Front Desk	Scheduled Drill
9/6/2011	3:07:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Fire pump room Arizona side	The fire pump pressure switch caused the alarm. The pressure switch was replaced 9/7/11 by residence life.
9/2/2011	2:00:00 AM	151	Babcock	RESIDENTIAL - R2	False Alarm	D222	Unknown
8/30/2011	1:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	Mohave basement boiler tanks	Res life maint. turned on steam to building without shutdown request, and it set off heat detector
8/27/2011	3:19:00 PM	131	Likins Hall	RESIDENTIAL - R2	Trouble	Duct detector in room 113	Faulty equipment
8/26/2011	8:30:00 PM	151	Babcock	RESIDENTIAL - R2	False Alarm	B110	Residents burnt their popcorn in the microwave
8/18/2011	6:19:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th Floor Bathroom	Too much hair spray in hallway. Particle detector activated.
8/18/2011	9:10:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	Nuisance Alarm	Roof	Unclear as to cause of alarm
8/17/2011	7:48:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 421	Strong smell of Perfume \ hairspray in the area / Unknown
8/17/2011	5:40:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	Bldg. A, 1st floor	TFD said the alarm was caused by a water surge
8/14/2011	10:45:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	Trouble	Third floor south in room smoke sounder	Sounder smoke base in room 391 deffective - removed and replaced sounder smoke base reset FACP - all five in room sounder smoke detectors operational
8/14/2011	2:00:00 PM	131	Likins Hall	RESIDENTIAL - R2	Trouble	In room A113 duct detector	PC board failure

7/30/2011	10:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 13	The signal zam circuit was disabled
7/29/2011	10:20:00 PM	132	Arbol De La Vida	RESIDENTIAL - R2	False Alarm	D Roof	Not sure what caused the alarm
7/27/2011	9:15:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Fire	By room S318	The alarm was caused by the light fixture balast that shorted out by room S 318 which set the smoke detector off M5-100. Per Joe, code as fire.
7/14/2011	11:58:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Trouble	4th floor by room 420	Smoke sensor
7/6/2011	10:10:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Santa Curz lounge 139S	Smoke sensor dirty
7/4/2011	11:30:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Trouble	Attic tamper	
7/2/2011	12:50:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor by room S-322	Device failure
6/19/2011	8:15:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Trouble	8th and 9th floor	Unknown
5/19/2011	10:22:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 425	The cause of the alarm was unknown
5/13/2011	5:09:00 AM	122	Posada San Pedro	RESIDENTIAL - R2	False Alarm	By room 141	Water Leak
5/10/2011	6:21:00 PM	423	Sky View Apartments	RESIDENTIAL - R2	False Alarm	218	Burnt plastic in room 218, smoke set off
4/30/2011	8:30:00 AM	57	Hopi Lodge Residence Hall	RESIDENTIAL - R2	False Alarm	By room 51	Smoke sensor water damage
4/30/2011	9:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor center hallway	Fire extingusher set off by student
4/29/2011	8:30:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor 2N2 pull-station/smokes	Unknown
4/29/2011	10:10:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Panel	N/A
4/28/2011	11:45:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Lobby by front desk	Unknown
4/27/2011	10:30:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Panel	N/A
4/23/2011	2:35:00 AM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	Greenlee Stairwell 2SW by 219	Intentional
4/22/2011	6:48:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	1W by front desk	Unknown
4/19/2011	8:23:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	In room 300B	The smoke detector was dirty and had to be cleaned
4/17/2011	5:59:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Lobby	na
4/9/2011	10:30:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	Room 348	Steam from shower
4/6/2011	5:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Hall by s-322	UAPD did not indicate cause or location of alarm
3/30/2011	6:20:00 PM	423	Sky View Apartments	RESIDENTIAL - R2	False Alarm	na	Per Leo Taylor, problem was dirty smoke
3/27/2011	9:50:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	Trouble	Lobby	Trouble, card 9, power supply/charger, battery charger capacity
3/1/2011	11:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	6th floor Arizona side	UAPD accidently set off alarm

2/27/2011	4:17:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Coconino Kitchen, 1S Pull Station	Smoke in kitchen, no known flame. Living Room filled with smoke but cleared out before residents were allowed to return. Pull station in 1S pulled, unknown if the two are related.
2/26/2011	5:59:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Fire	Third floor alarm was set off	Grease fire
2/21/2011	6:10:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	By room 404	Device malfunction
2/20/2011	4:40:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor	Unknown person pulled the pull station on the second floor, north wing. There was no fire.
2/13/2011	2:06:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor east stairwell	The pull station was activated by a student for what appears to be the purpose of doing a prank. There was no fire.
2/8/2011	3:18:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Elevator	Unknown
2/8/2011	11:35:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	In room 749	A student burned their noodles in the microwave which caused the alarm
2/5/2011	9:57:00 AM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	na	Unknown
2/4/2011	3:16:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	4th Center	A resident had discharged the fire extinguisher
1/30/2011	9:50:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	S308	Boys D100s pulled "prank" on girls in S308 by expelling the fire extinguisher in the hall.
1/29/2011	1:40:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Cochise, 2E stairwell	Pull-station activated by unknown
1/29/2011	3:30:00 AM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	South Building – 2nd Floor	Burnt piece of food from a microwave
1/27/2011	1:45:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2E stairwell	Someone pulled pull-station on 2E
1/23/2011	8:55:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	Basement Floor/East Wing	Cooking
1/17/2011	11:20:00 PM	34	Yavapai Residence Hall	RESIDENTIAL - R2	False Alarm	In room smoke detector (Room 13)	Student cooking in room
1/14/2011	11:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor smokes	Student used fire extinguisher in hallway

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/31/2010	12:30:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL -R2	Trouble	Basement miniplex panel	Bad Power Supply
12/31/2010	1:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement Main Panel	Bad battery charger
12/28/2010	1:15:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL -R2	Trouble	Basement	Bad power supply, will advise supervisor need to order one.
12/24/2010	2:30:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL -R2	Trouble	Basement	Unknown
12/12/2010	2:30:00 AM	31	Cochise Residence Hall	RESIDENTIAL -R2	False Alarm	First floor west hallway	Pull-station pulled
12/10/2010	8:31:00 PM	123	Pueblo De La Cienega	RESIDENTIAL -R2	False Alarm	In room 263	Hair spray used by student
12/7/2010	10:35:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	3rd floor sonora by room 325	Dirty smoke sensor
12/7/2010	8:45:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Outside room 325	UAPD believes it was just a faulty alarm
12/5/2010	12:16:00 PM	31	Cochise Residence Hall	RESIDENTIAL -R2	False Alarm	By 312	The 3E fire extinguisher was sprayed in hallway
12/3/2010	10:16:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor top of stairs	Dirty smoke sensor
12/2/2010	7:20:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	False Alarm	By L302	The alarm panel was indicating that room L302 needs to have its smoke detector cleaned and air filter changed: lint and dirt in the smoke detector.
12/1/2010	4:20:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor (zone 3)	Unknown
11/25/2010	12:12:00 PM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	By room 948	Discharged fire extinguisher
11/19/2010	2:45:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	Kitchen first floor	Cooking
11/17/2010	9:36:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	By room 325	he carpet cleaning crew was steam cleaning the carpet by room 325 smoke detector that caused the alarm
11/16/2010	11:07:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	4th floor hall	Custodial cleaning
11/16/2010	12:37:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	4th floor hall	Custodial cleaning
11/9/2010	9:53:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	By room 420	The carpet cleaning crew set the alarm off by cleaning the carpet in the hallway
11/7/2010	5:25:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Arizona Kitchen	Intentionally caused by students who were later identified.
11/6/2010	10:54:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	Kaibab 2nd floor north	Intentional
11/3/2010	2:00:00 AM	122	Posada San Pedro	RESIDENTIAL -R2	False Alarm	103 Mail area and 341	Unknown
11/1/2010	12:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	Trouble	North basement	Extreme steam
10/31/2010	8:05:00 PM	122	Posada San Pedro	RESIDENTIAL -R2	False Alarm	Lobby by 103	Dirty smoke
10/31/2010	10:00:00 PM	122	Posada San Pedro	RESIDENTIAL -R2	False Alarm	103 mail area	Unknown
10/30/2010	4:00:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor Huachuca	Someone pulled pull-station

10/25/2010	3:15:00 AM	31	Cochise Residence Hall	RESIDENTIAL -R2	False Alarm	2nd floor east side	Someone pulled the 2nd floor east side pull-station
10/25/2010	9:15:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	3rd Kaibab North	Intentional activation of pull-station
10/19/2010	12:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	Trouble	Room 12B	Power outage
10/18/2010	11:33:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	By room 117	Smoke detector by room 117 M1-33 was in alarm because their was a water leaking from the ceiling into the smoke detector base and head. Replaced smoke detector part number is 519-690 and
10/16/2010	4:15:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	By room 323	Broken pull station tamper proof cover
10/13/2010	12:45:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL -R2	Trouble	Ground fault	Found custodial sevicees in two different womens bathrooms with quarter to half inch of water on floor. Water could have seeped to floor below.
10/3/2010	10:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	6th floor Arizona	Unintentional
9/25/2010	8:45:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor stairwell	Noted as water pipe alarm
9/24/2010	12:52:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	Room 721	Extinguisher was set off in room 721 for a spark that was let out by the microwave
9/19/2010	1:25:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor	Unknown
9/17/2010	9:02:00 PM	34	Yavapai Residence Hall	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/16/2010	8:39:00 PM	31	Cochise Residence Hall	RESIDENTIAL -R2	Drill	Lobby	Risk Management annual fire drill
9/16/2010	7:40:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/16/2010	5:55:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/16/2010	8:30:00 PM	423	Sky View Apartments	RESIDENTIAL -R2	Drill	1st floor lobby	Risk Management fire drill
9/15/2010	9:01:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL -R2	Drill	1st floor lobby	Risk Management Annual Fire Drill
9/15/2010	8:21:00 PM	85	Coronado Residence hall	RESIDENTIAL -R2	Drill	na	Risk Management annual fire drill
9/15/2010	7:35:00 PM	121	Villa Del Puente	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/15/2010	7:30:00 PM	122	Posada San Pedro	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/15/2010	6:30:00 PM	123	Pueblo De La Cienega	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/14/2010	6:20:00 PM	5	Coconino Residence Hall	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/14/2010	5:50:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL -R2	Drill	na	Risk Management annual fire drill
9/14/2010	6:30:00 PM	8	Gila Residence Hall	RESIDENTIAL -R2	Drill	Lobby	Risk Management fire drill
9/14/2010	7:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL -R2	Drill	na	Risk Management fire drill

9/14/2010	8:40:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL -R2	Drill	na	Risk Management fire drill
9/14/2010	9:15:00 PM	57	Hopi Lodge Residence Hall	RESIDENTIAL -R2	Drill	Front lobby	Risk Management fire drill
9/14/2010	7:55:00 PM	151	Babcock	RESIDENTIAL -R2	Drill	2nd floor	Risk Management Annual Fire Drill
9/14/2010	9:30:00 PM	448	Parker House	RESIDENTIAL -R2	Drill	Lobby	Risk Management Annual Fire Drill
9/13/2010	9:52:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	8th floor hall	Not sure, something probably sprayed in hallway
9/7/2010	9:30:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL -R2	False Alarm	Room 274 kitchen	na
8/27/2010	10:15:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL -R2	False Alarm	1 NE Wing by 160	Cooking
8/24/2010	6:30:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	6th floor Sonora	UAPD believes it was lint in unit but ultimately said is was just a faulty alarm
8/23/2010	7:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	By room 620	Student cooking top-ramen in microwave oven
8/20/2010	2:30:00 AM	31	Cochise Residence Hall	RESIDENTIAL -R2	Nuisance Alarm	3W	Multiple residents reported seeing a "couple of guys" running from building
8/20/2010	11:35:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	6th floor reading room	Unknown
8/16/2010	8:38:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	By room 463	Water leak above smoke sensor
8/14/2010	5:45:00 PM	423	Sky View Apartments	RESIDENTIAL -R2	False Alarm	3rd floor smoke	The smoke detector was dirty and needed to be cleaned
8/4/2010	4:54:00 PM	31	Cochise Residence Hall	RESIDENTIAL -R2	False Alarm	1st floor	Dirty smoke sensor by 1st floor south east exit door
8/4/2010	5:44:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement elevator lobby	Dirty smoke sensor and base
7/23/2010	4:44:00 AM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor East wing	Unknown
7/23/2010	7:05:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	Basement	Contractor bumped start lever
7/15/2010	2:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Arizona basement lobby	Unknown
7/14/2010	1:01:00 PM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	8th floor in room 860	Dirty smoke sensor
7/1/2010	8:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Room 111	Contractor sweeping floor causing dust which set off alarm
7/1/2010		83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	In room 111	Contractor was sweeping floor causing dust which set off the alarm
6/24/2010	5:20:00 PM	8	Gila Residence Hall	RESIDENTIAL -R2	False Alarm	3rd floor	Dirty smoke sensor
6/18/2010	7:15:00 PM	8	Gila Residence Hall	RESIDENTIAL -R2	Trouble	At panel	Talley over-exceeded limits
6/18/2010	9:20:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	False Alarm	By room L321	Contractor worker using vacuum cleaner w/o filter
6/4/2010	11:42:00 AM	9	Maricopa Residence Hall	RESIDENTIAL -R2	False Alarm	2nd floor smoke detector	Residence life maintenance personnel
4/13/2010	1:00:00 AM	118	Colonia De La Paz Residence Hall	RESIDENTIAL -R2	False Alarm	na	Residence hall maintenance set off smoke detector while cleaning carpet



4/3/2010	1:00:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL -R2	Trouble	na	na
4/3/2010	6:45:00 PM	135	Pima Residence Hall	RESIDENTIAL -R2	False Alarm	Room 328	Unknown
4/2/2010	8:21:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL -R2	False Alarm	2nd floor kitchen	Someone was cooking in the kitchen and burned some food in the oven
3/24/2010	6:44:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	2nd floor by 209	Hair spray
3/17/2010	12:12:00 PM	5	Coconino Residence Hall	RESIDENTIAL -R2	False Alarm	Sitting room 1st floor	Burnt popcorn
3/8/2010	10:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Kitchen	Cooking
2/25/2010	12:42:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL -R2	False Alarm	By room 316	Burn food in microwave
2/25/2010	12:05:00 PM	121	Villa Del Puente	RESIDENTIAL -R2	False Alarm	In room 179	Human error. Hi pressure steam valve removed by Residence Life personnel
2/18/2010	8:21:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	na	TFD reported heat detector probably set off by hair straightener
2/16/2010	10:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	By Room 9/11 Sonora side	Jantiors cleaning
2/10/2010	11:11:00 AM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	11th floor Elevator equipment room	Elevator 1 brake shoes locked up
2/8/2010	3:09:00 PM	135	Pima Residence Hall	RESIDENTIAL -R2	False Alarm	Room 228	Student cooking with microwave
2/1/2010	4:15:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	Room 248	Burnt pop-tart
1/30/2010	8:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement	Uknown
1/29/2010	8:10:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL -R2	False Alarm	Room 209	Unknown
1/26/2010	10:45:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement	Unknown
1/24/2010	10:05:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL -R2	False Alarm	Basement	Unknown
1/22/2010	1:44:00 PM	8	Gila Residence Hall	RESIDENTIAL -R2	False Alarm	Kitchen	Cooking
1/16/2010	8:07:00 PM	85	Coronado Residence hall	RESIDENTIAL -R2	False Alarm	9th floor	Dirty smoke
1/12/2010	9:12:00 AM	5	Coconino Residence Hall	RESIDENTIAL-R2	False Alarm	Top of elevator shaft	Dirt possibly from maintenance of dampers

Date	Time	Bldg #	Building Name	Bldg Type	Nature Of Event	Device Location	Cause
12/30/2009	12:45:00 AM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Trouble	na	AC power rocking in and out of trouble
12/30/2009	9:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	2nd floor	Dirty smoke sensor
12/8/2009	2:21:00 PM	59/60/61	Pinal/Navajo/Sierra Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor Navajo	Burning muffins in oven on 3rd floor. Oven had been reported as malfunctioning on several occasions per RA and had been cleared by Residence life, area needs to be reviewed for possible addition
12/4/2009	12:32:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Stairwell 1st floor Huachuca	Unknown
12/3/2009	7:00:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	3rd floor	Smoke sensor base in 333
11/16/2009	12:24:00 PM	52/53	Greenlee/Graham Residence Halls	RESIDENTIAL - R2	False Alarm	Bldg. 52 1st floor	Dirty smoke sensor
11/1/2009	9:55:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen	Students cooking in kitchen
10/30/2009	7:47:00 PM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	Kaibab 2nd	Unknown
10/28/2009	8:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	na	Unknown
10/26/2009	4:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Emergency Evacuation	4th floor	Fire extinguisher
10/16/2009	3:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Lobby Sonora side elevator	Someone may have hit sprinkler head
10/16/2009	1:00:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Basement elevator	System Failure
10/6/2009	11:55:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	5th floor	Unknown
10/2/2009	10:38:00 AM	79/79a	Huachuca/Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor	Per UAPD vacume cleaner overheated
10/1/2009	4:35:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	Level 2 east stairwell	Dirty smoke detector
10/1/2009	12:45:00 AM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2E	Unknown
9/30/2009	11:40:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	False Alarm	2E	Pull-station pulled
9/30/2009	10:58:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Arizona basement	Smoke detector set off fire alarm
9/29/2009	8:43:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen 1st floor	Burnt food
9/23/2009	7:24:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/23/2009	7:30:00 PM	122	Posada San Pedro	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/23/2009	7:52:00 PM	123	Pueblo De La Cienega	RESIDENTIAL - R2	Drill	na	Risk Management fire drill

9/15/2009	7:25:00 PM	31	Cochise Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/15/2009	9:40:00 PM	59/60/61	Pinal/Navajo/Siera Residence Halls	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/15/2009	8:46:00 PM	79/79a	Huachuca/Kaiba Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/15/2009	6:35:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/15/2009	6:00:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill of the semester
9/12/2009	11:00:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen room 109	Burnt pancakes
9/9/2009	3:15:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor south	Face plate of pull-station came loose and off the wall
9/8/2009	1:05:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B107 hallway	Unknown
9/7/2009	12:50:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	9th floor Arizona	Unknown
9/3/2009	8:04:00 PM	5	Coconino Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management Fire drill
9/3/2009	7:25:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	Drill	na	Fire drill
9/3/2009	8:15:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/3/2009	8:35:00 PM	10	Yuma Residence hall	RESIDENTIAL - R2	Drill	na	Risk Management fire drill
9/3/2009	9:50:00 PM	151	Babcock	RESIDENTIAL - R2	Drill	Student section	Risk Management fire drill
9/2/2009	12:15:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	na	Pull-station
9/1/2009	9:42:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 221	Dirty smoke
9/1/2009	9:43:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Outisde room 221	Defective device
9/1/2009	7:40:00 PM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Outside room 221	Smoke detector
8/29/2009	11:43:00 PM	121	Villa Del Puente	RESIDENTIAL - R2	False Alarm	1st floor lobby	Unknown
8/23/2009	8:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Drill	na	Fire drill
8/18/2009	7:09:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	3rd floor, East wing	Burn food
8/16/2009	11:15:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	11th floor	Elevator brake shoes locked up
8/7/2009	9:40:00 AM	59/60/61	Pinal/Navajo/Siera Residence Halls	RESIDENTIAL - R2	False Alarm	4th floor	Shop vacume set off alarm

6/24/2009	10:10:00 PM	7/7a	Manzanita/Mohave Residence Halls	RESIDENTIAL - R2	False Alarm	na	Student hit smoke detector with mattress
6/18/2009	8:53:00 AM	10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm	1st floor	Dirty smoke
6/17/2009	9:35:00 AM	5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	1st floor	Residence Life soldering
6/17/2009	12:23:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	2nd floor	Cleaning fan coil on second floor
4/27/2009	11:39:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	1st floor lounge in Arizona	Cooking. Vent hood does not vent outside
4/24/2009	12:13:00 PM	9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	3rd floor smokes	Strong odor of food cooked/burnt.
3/20/2009	12:36:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	3rd floor	Burnt food in microwave
2/24/2009	6:45:00 PM	8	Gila Residence Hall	RESIDENTIAL - R2	False Alarm	na	Dirty smoke
2/14/2009	12:30:00 AM	83/84	Sonora/Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	2nd floor	Dirty smoke
1/30/2009	2:30:00 PM	85	Coronado Residence hall	RESIDENTIAL - R2	Trouble	na	na
1/16/2009	11:11:00 AM	85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 857	Burnt food