

Table 1

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|----------|------------|------------|------------------------------------|------------------|-----------------|----------------------------------|--|
| 12/12/19 | 2:12:00 AM | Building # | Maricopa Residence Hall | RESIDENTIAL - R2 | False Alarm | Room 338 | Occupant burnt popcorn |
| 12/12/19 | 5:36:00 AM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | c110 | Unknown |
| 12/10/19 | 7:13:00 AM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | Room 410 | No reason given by UAPD. |
| 12/9/19 | 4:42:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Room 4056 | Cooking tofu. |
| 12/9/19 | 1:54:00 AM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | 1st floor | Door latch? |
| 12/8/19 | 4:48:00 PM | 121 | Villa Del Puente | RESIDENTIAL - R2 | False Alarm | Room 236 | Burnt food. |
| 12/8/19 | 9:54:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Southeast courtyard strobe light | Strobe light malfunction. |
| 12/7/19 | ##### | 121 | Villa Del Puente | RESIDENTIAL - R2 | False Alarm | Level 2 | UAPD/TFD thinks it was the showers. |
| 12/5/19 | 2:23:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 307 | Unknown cause |
| 12/4/19 | 1:47:00 AM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 265 | Burnt popcorn |
| 12/2/19 | 7:08:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 151 | Steam from shower |
| 12/2/19 | 1:13:00 AM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | Room 410 | Unknown has occurred before. |
| 12/2/19 | 5:58:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Courtyard | Strobe light going out |
| 11/27/19 | 3:39:00 PM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 356 | Unknown |
| 11/27/19 | ##### | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | Room 410 | Unknown |
| 11/26/19 | 2:21:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Rec Room 102 | Burnt food. |
| 11/26/19 | ##### | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Room 2070 | Head missing unknown reason |
| 11/26/19 | 7:04:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Floors 1-3 | Unknown |
| 11/25/19 | 2:05:00 PM | 5 | Coconino Residence Hall | RESIDENTIAL - R2 | False Alarm | Kitchen | Student cooking burgers on the stove top. Made excessive smoke |
| 11/24/19 | 3:35:00 PM | 5 | Coconino Residence Hall | RESIDENTIAL - R2 | False Alarm | Kitchen | Smoke in the kitchen |
| 11/23/19 | 9:26:00 PM | 10 | Yuma Residence hall | RESIDENTIAL - R2 | False Alarm | 3rd floor room | Smoke from burnt food in microwave |
| 11/22/19 | ##### | 59/60 | Stadium Complex - Pinal/Navajo | RESIDENTIAL - R2 | False Alarm | 3rd floor corridor smoke | Unknown, UAPD reset system before locating device. |
| 11/22/19 | 1:51:00 PM | 59/60 | Stadium Complex - Pinal/Navajo | RESIDENTIAL - R2 | False Alarm | 3rd Flr. Navajo Corridor | Dirty smoke by 360 |
| 11/22/19 | 1:54:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 312 | Burnt food in microwave |
| 11/22/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 513 | Unknown |

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|----------|------------|------------|----------------------------------|------------------|-----------------|-----------------------------|---|
| 11/22/19 | 8:05:00 PM | 121 | Villa Del Puente | RESIDENTIAL - R2 | False Alarm | Room 205/206 | Steam from shower |
| 11/21/19 | ##### | 77a | Manzanita/Mohave Residence Halls | RESIDENTIAL - R2 | False Alarm | By 452 Manzanita | Unknown |
| 11/21/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | Fire | Room 613 | Battery pack in mattress smoldering caught fire when resident tried to extinguish with water. Resident sprayed battery pack with fire extinguisher. |
| 11/21/19 | 6:43:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Room 3076 | Unknown |
| 11/20/19 | 7:12:00 PM | 135 | Pima Residence Hall | RESIDENTIAL - R2 | False Alarm | Community Kitchen | Burnt food |
| 11/17/19 | 9:57:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 420 | Unknown |
| 11/15/19 | 9:26:00 PM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | Room 319 | Burnt popcorn |
| 11/15/19 | 4:15:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 2nd floor | Fire extinguisher discharged by someone |
| 11/14/19 | 3:21:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 725 | Vaping in room |
| 11/13/19 | 7:40:00 AM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | 2070 | DA called following up that smoke detector in room was not connected to system but was not disconnected from the unit. |
| 11/10/19 | ##### | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | B105 | Burn toast. |
| 11/9/19 | 8:36:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Community kitchen | Unknown |
| 11/8/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 216 | Burnt macaroni and cheese |
| 11/8/19 | 9:30:00 AM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Dining hall | Steam from dishwasher |
| 11/6/19 | 3:24:00 PM | 131 | Likins Hall | RESIDENTIAL - R2 | False Alarm | In room 308, Smoke detector | Student cooking using micro wave to cook chicken wing and left to restroom. |
| 11/5/19 | 7:55:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | 4th fl in room smoke | UAPD and TFD left without providing details to DA |
| 11/4/19 | 2:00:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | In 420 | Possibly e-cig or similar |
| 11/1/19 | 5:50:00 PM | 85a | La Aldea | RESIDENTIAL - R2 | Fire | Room 408 | Resident cooking open flame - sustained minor burns |
| 10/31/19 | 7:34:00 PM | 135 | Pima Residence Hall | RESIDENTIAL - R2 | False Alarm | Room 220 | Unknown |
| 10/30/19 | 1:10:00 AM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | 7th floor pull station | Pull station cover |
| 10/29/19 | 1:19:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 210 | Dirty smoke detector |

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|----------|------------|------------|------------------------------------|------------------|-----------------|-------------------------|--|
| 10/26/19 | 8:00:00 AM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | Room 257 | Unknown |
| 10/24/19 | ##### | | 132 Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | Room A114 | Maintenance work |
| 10/23/19 | 8:00:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 148 | Vaping |
| 10/23/19 | 2:29:00 AM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | 410 | Smoke in 410 - these are battery operated not hardwired. |
| 10/22/19 | 4:20:00 PM | | 31 Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | Basement | Cooking in basement |
| 10/17/19 | ##### | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | 410 | Smoke (battery opreated) triggered by dust per TFD. |
| 10/15/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 1st floor lobby kitchen | Smoke detector in kitchen |
| 10/13/19 | ##### | | 5 Coconino Residence Hall | RESIDENTIAL - R2 | False Alarm | kitchen | Cooking mozzarella sticks in kitchen - no fire just smokey |
| 10/10/19 | ##### | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | 1st floor kitchen | Steam from the dishwasher in the first floor kitchen. UAPD also said that they were locked out from building and had to use the hard key to get into the building. |
| 10/9/19 | 3:41:00 AM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | na | DA called explaining that fire panel was going off with message "trouble alarm- error". DA said this was the second time this week this happened. |
| 10/8/19 | 4:16:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 301 | Resident overheated food in room and also set off building fire alarm. |
| 10/8/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 712 | Burnt popcorn |
| 10/7/19 | 9:32:00 PM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | 257 | Possible electrical problem |
| 10/7/19 | ##### | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Lobby | Unknown-no reponse from UAPD |
| 10/6/19 | 9:54:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Lobby | Unknown |
| 10/5/19 | 2:24:00 AM | | 132 Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | B409 | Burnt popcorn |
| 10/3/19 | 9:27:00 AM | | 31 Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | 1st floor in room 109A | Steam from shower |
| 10/2/19 | ##### | | 9 Maricopa Residence Hall | RESIDENTIAL - R2 | False Alarm | na | Unknown - possible power outage |
| 10/2/19 | 8:40:00 PM | | 10 Yuma Residence hall | RESIDENTIAL - R2 | False Alarm | Kitchen | Unknown |
| 10/2/19 | 9:59:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | 3132 | Steam from iron |
| 10/1/19 | 8:00:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 378 | Unknown |

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|---------|------------|------------|------------------------------------|------------------|-----------------|-------------------------------|---|
| 9/30/19 | 5:18:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | 2nd floor in room smoke | Unknown |
| 9/25/19 | ##### | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | rooms 101, 102, 117, and 121. | Unknown |
| 9/24/19 | ##### | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | 2nd floor Apache in room 280 | Unknown panel cleared by UAPD who had already left |
| 9/22/19 | 7:48:00 PM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | Room 209 | Heating food in microwave w/o water |
| 9/22/19 | 8:27:00 PM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Room 169 | Unknown - follow up |
| 9/21/19 | 4:00:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 6th floor in room smoke | Unknown |
| 9/21/19 | 2:45:00 PM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | B304 | Unknown |
| 9/20/19 | 4:45:00 PM | 59/60 | Stadium Complex - Pinal/Navajo | RESIDENTIAL - R2 | False Alarm | Laundry room | Lint from dryer in laundry room smoking |
| 9/20/19 | ##### | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | 419 | GRA updated CDOC on false alarm for fire alarm. Smoke detector was set off by shower. Residents reminded to turn on fan. UAPD call out cancelled. |
| 9/19/19 | 7:45:00 AM | 167a | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Pillars | Unknown |
| 9/18/19 | 3:04:00 PM | 59/60 | Stadium Complex - Pinal/Navajo | RESIDENTIAL - R2 | False Alarm | na | Water flow bump on campus |
| 9/18/19 | ##### | 79/79a | Huachuca/Kaibab Residence Hall | RESIDENTIAL - R2 | False Alarm | 3rd floor Kaibab by room 341 | Steam from janitor room due to broken pipe caused the alarm in hallway. Referred to RES-LIFE Maintenance |
| 9/18/19 | 1:08:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | By room 812 | Custodial dustin in area |
| 9/17/19 | 6:20:00 AM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | Mechanical room | Unknown cause of alarm |
| 9/16/19 | ##### | 167A | UA Honors Village Residence | RESIDENTIAL - R2 | False Alarm | Room 4083 | Unknown |
| 9/15/19 | ##### | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | CD apartment | Unknown |
| 9/14/19 | 1:22:00 AM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | 4th floor B Building | Unknown |
| 9/13/19 | 9:41:00 PM | 5 | Coconino Residence Hall | RESIDENTIAL - R2 | False Alarm | Community kitchen | Smoke detector in kitchen |
| 9/6/19 | 6:49:00 PM | 7/7a | Manzanita/Mohave Residence Halls | RESIDENTIAL - R2 | Drill | Entire building | Fire drill |
| 9/5/19 | ##### | 34 | Yavapai Residence Hall | RESIDENTIAL - R2 | False Alarm | In TV Lounge 130 | Remaining smoke detector that needs to be removed inside asbestos area |
| 9/5/19 | 1:31:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | 2nd flr Apache in 246 | plug in air Scent |
| 9/3/19 | ##### | 10 | Yuma Residence hall | RESIDENTIAL - R2 | False Alarm | 2nd floor in room smoke | Unknown |

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|---------|------------|------------|----------------------------------|------------------|-----------------|------------------------------|--|
| 9/3/19 | ##### | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | Room D218 | Burnt food in microwave |
| 8/30/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 741 | Burnt popcorn |
| 8/27/19 | ##### | 79/79a | Huachuca/Kaibab Residence Hall | RESIDENTIAL - R2 | False Alarm | Basement kitchen | Smoke from microwave |
| 8/24/19 | 5:30:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 4th floor in room 411 | Student removed the smoke sensor from its base which cause a trouble on the fire control panel. |
| 8/24/19 | 2:40:00 PM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | 2nd floor in room | Unknown |
| 8/23/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | 9th floor elevator lobby | Unknown |
| 8/20/19 | 9:00:00 PM | 131 | Likins Hall | RESIDENTIAL - R2 | False Alarm | Room 531 | Burnt mac and cheese in room |
| 8/19/19 | 1:16:00 PM | 34 | Yavapai Residence Hall | RESIDENTIAL - R2 | False Alarm | 1st Floor TV Lounge room 130 | Contractors have been taping our smoke detectors on a daily basis. I informed them that they needed to have a shutdown for the fire alarm system as well as a permit from Risk Management for the asbestos |
| 8/19/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 262 | Unknown |
| 7/26/19 | 1:45:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | A104 | Burnt popcorn |
| 6/12/19 | ##### | 121 | Villa Del Puente | RESIDENTIAL - R2 | False Alarm | In room 235 | Burnt food |
| 6/4/19 | 5:07:00 PM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | In room 324 | Dirty smoke det |
| 6/2/19 | 8:42:00 AM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | Room 410 | Smoke detector - battery operated |
| 5/29/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | In room 418 | Cleaning carpets |
| 5/28/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 3rd floor Son elev lobby | Custodial cleaning carpet in area |
| 5/5/19 | 2:00:00 AM | 79/79a | Huachuca/Kaibab Residence Hall | RESIDENTIAL - R2 | False Alarm | By room 132 | Pull-station pulled by unknown person. V191250012 |
| 5/5/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room on 7th | Burnt food. Room not noted |
| 5/4/19 | 3:50:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | Room C116 | Cause unknown-UAPD made no contact |
| 4/30/19 | ##### | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | Room D203 | Dirty smoke |
| 4/28/19 | 9:25:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 920 | Unknown |
| 4/27/19 | 9:00:00 PM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | Room 410 | Smoke detectors pulled off wall by student - had to replace |
| 4/27/19 | 7:45:00 PM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | Room 410 | Cooking set off alarm |

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|---------|------------|------------|------------------------------------|------------------|-----------------|----------------------------|---|
| 4/25/19 | 8:55:00 PM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | 7th floor east hallway | False alarm was pulled in CORO. Case # V191150088 |
| 4/24/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Sonora room 419 | Spoke with officer, he explained burnt popcorn |
| 4/22/19 | 8:30:00 PM | 5 | Coconino Residence Hall | RESIDENTIAL - R2 | False Alarm | Elevator room | Smoke in elevator room from belts. V191120058 |
| 4/22/19 | ##### | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | Basement by room #7 | Resident was cooking bacon and burnt it |
| 4/19/19 | 5:35:00 PM | 79/79a | Huachuca/Kaibab Residence Hall | RESIDENTIAL - R2 | False Alarm | Basement | Unknown |
| 4/19/19 | 2:25:00 AM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 746 | Burnt food. V191090006 |
| 4/19/19 | 5:45:00 PM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 465 | Burnt food in microwave |
| 4/18/19 | 7:49:00 AM | 52/53 | Greenlee/Graham Residence Halls | RESIDENTIAL - R2 | False Alarm | 1st floor by room 127 | Laundry lint from a dryer caused the alarm (lint screen being shaken in the air) |
| 4/18/19 | ##### | 52/53 | Greenlee/Graham Residence Halls | RESIDENTIAL - R2 | False Alarm | By room 127 | Dirty smoke detector |
| 4/17/19 | 9:35:00 PM | 122 | Posada San Pedro | RESIDENTIAL - R2 | False Alarm | 3rd floor | Burnt popcorn in microwave |
| 4/16/19 | 9:29:00 PM | 52/53 | Greenlee/Graham Residence Halls | RESIDENTIAL - R2 | False Alarm | Greenlee community kitchen | Hot pan in kitchen |
| 4/16/19 | 2:46:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | 3rd floor rm L-315 West | candle in room set off smoke detector. |
| 4/13/19 | 3:35:00 AM | 79/79a | Huachuca/Kaibab Residence Hall | RESIDENTIAL - R2 | False Alarm | 3rd floor | Someone pulled pull station on 3rd floor |
| 4/10/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 946 | Alarm was activated due to popcorn burning. |
| 4/10/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 946 | Burnt popcorn |
| 4/9/19 | 7:00:00 PM | 59/60 | Stadium Complex - Pinal/Navajo | RESIDENTIAL - R2 | False Alarm | na | The fire alarm lights flickered for a while, but no sound. No one evacuated or knows the cause. |
| 4/8/19 | 8:00:00 PM | 59/60 | Stadium Complex - Pinal/Navajo | RESIDENTIAL - R2 | False Alarm | na | The cause was never shared. |
| 4/8/19 | 9:22:00 AM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | In room D314 | Cleaned smoke detector, contacts had a lot of corrosion |
| 3/30/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 919 | Burnt popcorn |
| 3/25/19 | 8:00:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | APSC 183 | Hair straightener |
| 3/25/19 | 6:36:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 141 | Cooking |

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|---------|------------|------------|------------------------------------|------------------|-----------------|----------------------------|--|
| 3/25/19 | 5:55:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | Fire | Heat detector in room B105 | Student cooking Onion rings in a pot of hot oil which spilled over to the range causing the grease fire in which UAPD was able to extinguish upon arrival to the kitchen. Res-life and risk management |
| 3/18/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | In room 606 | Resident was steaming his clothes and set off the smoke detector. |
| 3/15/19 | 3:59:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | s307 | Unknown |
| 3/11/19 | ##### | 57 | Hopi Lodge Residence Hall | RESIDENTIAL - R2 | False Alarm | na | Fire alarm triggered due to resident making hot coco. |
| 2/27/19 | ##### | 131 | Likins Hall | RESIDENTIAL - R2 | False Alarm | Room 457 | Alarm was activated due to residents tampering with alarm. |
| 2/27/19 | 1:20:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | In room E307 | Resident burnt food in microwave |
| 2/26/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | na | Resident set off the alarm with hairspray. |
| 2/25/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 1st flr AZ Elevator lobby | cooking in kitchen smoke from hot pan |
| 2/24/19 | 4:00:00 AM | 7/7a | Manzanita/Mohave Residence Halls | RESIDENTIAL - R2 | False Alarm | By 2nd floor elevator | he fire extinguisher was discharged by the 2nd-floor elevator. |
| 2/23/19 | 2:20:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 723 | The fire alarm was triggered due to febreze air freshener. |
| 2/20/19 | 6:46:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Community Kitchen | Fire alarm set off in kitchen |
| 2/18/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 227 | Room fire alarm activated due to burnt popcorn. |
| 2/15/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | room 912 | Residents burnt food in microwave |
| 2/15/19 | ##### | 121 | Villa Del Puente | RESIDENTIAL - R2 | False Alarm | 3rd floor | Fire alarm was set off by pull station cover being lifted. |
| 2/14/19 | ##### | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | In room 274 | Occupant had sprayed air freshener in room causing alarm. |
| 2/14/19 | 3:07:00 PM | 50/50a | Santa Cruz/ Apache Residence Halls | RESIDENTIAL - R2 | False Alarm | Santa Cruz room 209 | Cause unknown however room smelled like peanut butter e-cig, all windows in room open. No smoke in room upon arrival. |

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|---------|------------|------------|--------------------------------|------------------|-----------------|-------------------------|---|
| 2/12/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | In room 420 | Occupant was spraying air freshner in the room |
| 2/11/19 | 9:20:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 515 | Burnt food |
| 2/11/19 | ##### | 135 | Pima Residence Hall | RESIDENTIAL - R2 | False Alarm | By room 106 - Pima east | Resident was cooking in the kitchen and burnt the food. |
| 2/9/19 | 8:45:00 PM | 57 | Hopi Lodge Residence Hall | RESIDENTIAL - R2 | False Alarm | 57 | No cause for the alarm could be determined as the room is vacant. UAPD resent the alarm. Case: V190400073 |
| 2/8/19 | 4:05:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 818 | No cause could be determined and UAPD reset the alarm. Case: V190390041 |
| 2/7/19 | 3:15:00 AM | 79/79a | Huachuca/Kaibab Residence Hall | RESIDENTIAL - R2 | False Alarm | Basement | Resident pulled fire alarm in basement causing building evacuation. |
| 2/5/19 | 1:49:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | Bldg E Room 222 | Occupant thought to be using an e-cig in their room. |
| 2/3/19 | 2:20:00 PM | 34 | Yavapai Residence Hall | RESIDENTIAL - R2 | False Alarm | 3rd floor | Unknown |
| 1/31/19 | 2:20:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | 2nd floor pull station | Pull station cover knocked over. |
| 1/31/19 | 7:04:00 PM | 377 | Rawls Eller Lodge | RESIDENTIAL - R2 | False Alarm | Fire panel | Fire panel. HMS is aware of the issue with reoccurring ringing and have ordered parts to repair. |
| 1/30/19 | 7:44:00 PM | 377 | Rawls Eller Lodge | RESIDENTIAL - R2 | False Alarm | na | Panel |
| 1/29/19 | ##### | 377 | Rawls Eller Lodge | RESIDENTIAL - R2 | Nuisance Alarm | na | UAPD reset the fire panel for because of a "loop error". CDOC to file fire report. |
| 1/28/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 822 | UAPD responded to reset fire panel. The cause was unknown and no contact was made with residents. |
| 1/28/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | 205 | Possible steam from bathroom |
| 1/27/19 | 6:00:00 AM | 151 | Babcock | RESIDENTIAL - R2 | False Alarm | D205 | Unknown |
| 1/26/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Room 720 | Students burnt popcorn while cooking in room. |
| 1/23/19 | 3:16:00 PM | 31 | Cochise Residence Hall | RESIDENTIAL - R2 | False Alarm | In room 226 | Resident was boiling water and the steam caused the smoke detector to go in to alarm |

| Date | Time | Building # | Building Name | Building Type | Nature of Event | Device Location | Cause |
|---------|------------|------------|----------------------------------|------------------|-----------------|----------------------------------|---|
| 1/15/19 | 5:25:00 PM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Room 235 | Resident vaping in room. Vape set off the fire alarm. |
| 1/13/19 | 3:00:00 AM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | 725 | Microwaved food - V190130001 |
| 1/13/19 | 4:25:00 PM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | 428 | Microwaving a piece of bread |
| 1/12/19 | 3:40:00 PM | 132 | Arbol De La Vida | RESIDENTIAL - R2 | False Alarm | E217 | Microwaved food set off alarm |
| 1/11/19 | 1:38:00 PM | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | In 959 | Unknown |
| 1/10/19 | 6:30:00 PM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | Apartment 121 | Cooking |
| 1/9/19 | ##### | 85 | Coronado Residence hall | RESIDENTIAL - R2 | False Alarm | Fire alarm 7th floor in room 757 | student was vaping in the room Electronic cigarette |
| 1/8/19 | ##### | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Fire pump run-Sonora rm 1 | Jockey pump shut off. Notified Res-Life |
| 1/6/19 | 4:30:00 AM | 85a | La Aldea | RESIDENTIAL - R2 | False Alarm | In room 324 Building C | unknown maybe dust. There were fans blowing from water damage in room |
| 1/3/19 | 7:30:00 PM | 83/84 | Sonora/Arizona Residence Halls | RESIDENTIAL - R2 | False Alarm | Basement | Alarm sounded in the basement potentially due to the pipes. |
| 1/3/19 | 1:30:00 PM | 118 | Colonia De La Paz Residence Hall | RESIDENTIAL - R2 | False Alarm | na | Smoke detector went off in room potentially due to dust. |