



3/22/2021 8:22 AM	132	Arbol de la Vida	Residential-R2	False Alarm	By 106	Resident bumped fire alarm pull station, causing it to go off. Emergency maintenance contacted due to Fire Safety not answering phone calls. Multiple calls between Em. Maintenance and front desk, situation resolved after entire building was tripped to reset system.	114
3/23/2021 12:37 PM	167a	Honors Village	Residential-R2	False Alarm		4078 Smoke detector sounding in room without smoke or fire. RAOD called UAPD to reset, but detector not responding. UAPD called Johnson Controls to disconnect detector, and JCI will respond later in week to fix.	115
3/23/2021 11:23 AM	167a	Honors Village	Residential-R2	False Alarm		2061 Resident burnt food while cooking in apartment, resulting in building evacuation. UAPD %26amp; TFD responded and reset alarm	116
3/25/2021 4:00 PM	83/84	Arizona-Sonora	Residential-R2	False Alarm	7th floor in room / hallway	RA informed CDOC that fire alarm went off and UAPD responded to the hall. Resident was seen walking down the hall with a White Claw and UAPD addressed incident. RA to write IR.	117
3/27/2021 3:10 PM	167a	Honors Village	Residential-R2	False Alarm		6099 Student Staff called to inform CDOC 2 that the Fire Alarm was sounding for room 6099 after the student burned some food while cooking.	118
3/26/2021 10:57 AM	83/84	Arizona-Sonora	Residential-R2	False Alarm		809 RA called to inform CDOC that UAPD was in building responding to a smoke detector in AZSO room 809. Reason for smoke detector going off was burnt popcorn.	119
3/30/2021 2:21 PM	167a	Honors Village	Residential-R2	False Alarm	na	Multiple calls with DA, RAOD, PM, and MOD. DA reported fire panel alarm was going off and UAPD was unable to turn it off. UAPD contacted ACC with no resolution. CDOC approved DA to call out to ACC and ACC respond	120
4/7/2021 7:30 AM	167a	Hall/Honors Village	Residential-R2	False Alarm		4021 Smoke alarm sounded for cooking, UAPD responded and determined there was no fire	121
4/6/2021 10:35 PM	85a	La Aldea	Residential-R2	False Alarm		121 UAPD and Tucson Fire responded due to a fire alarm. Tucson Fire inspected the apartment and determined it was likely due to a water diffuser.	122
4/13/2021 5:45 AM	167a	Honors Village	Residential-R2	False Alarm		1049 HNRV evacuated due to a fire alarm caused by burnt toast in a toaster oven. UAPD responded. See IR.	123
4/16/2021 2:23 PM	123	Pueblo de la Cienega	Residential-R2	False Alarm	by 309/310	Fire alarm went off and was pinpointed outside 309/310 pod suite. Building evacuated.	124
4/16/2021 6:45 PM	167a	Honors Village	Residential-R2	False Alarm	1083 and 4078.	While CDOC was responding to another incident, she found the HNRV Fire Panel sending a trouble alarm for rooms 1083 and 4078. CDOC worked with UAPD to check the spaces and silence the alarm. No fire or smoke wa	125
4/17/2021 7:04 PM	85	Coronado	Residential-R2	False Alarm	5th floor	RAOD called to report a fire alarm that was sounding on the 5th floor only. CDOC instructed RA to call UAPD to have them come to silence the alarm. The alarm turned itself off before UAPD was contacted.	126
4/30/2021 11:33 AM	167a	Honors Village	Residential-R2	False Alarm		1063 An alarm panel was sounding due to a dirty smoke detector in Office 1063. UAPD responded and resolved the situation.	127
5/2/2021 2:07 AM	167a	Honors Village	Residential-R2	False Alarm	3rd floor	Alarm panel was sounding. UAPD responded and called panel company for assistance in turning off. No fire or other issues were found on 3rd floor.	128
5/2/2021 11:27 PM	167a	Honors Village	Residential-R2	False Alarm	na	Alarm panel was sounding. Alarm stopped and UAPD response was no longer needed.	129
5/4/2021 1:36 AM	151	Babcock	Residential-R2	False Alarm	c112	Initially Reported%26%2358; Fire alarm Status on Arrival%26%2358; In alarm Actions Performed%26%2358; Approached by contractors working in the room causing dust. Checked rooms, no smoke/fire Cause of Alarm%26%2358; Contractors removing flooring. They had taped the smoke detectors up in both rooms they were working in. Smoke detectors will now have to be replaced. Pictures attached. Status on Departure%26%2358; Per Joe Branaum they were issued a 1st floor smoke bypass and will be submitting a shut down request.	130
5/9/2021 4:13 AM	31	Cochise	Residential-R2	False Alarm	Kitchen room 6	RAOD shared the fire alarm sounded at 7%26%2358:30 AM due to a resident cooking and accidentally burning eggs.	131
5/8/2021 7:55 AM	167a	Honors Village	Residential-R2	trouble	panel	DA asked for permission to callout to ACC due to fire panel alarm malfunction, as it had no location or problem indicated. Callout approved.	132
5/11/2021 5:00 AM	132	Arbol de la Vida	Residential-R2	False Alarm	1st floor - room %23 na	RAOD reported UAPD in building due to smoke alarm. Room noted on fire panel was empty and no smoke/fire present.	133
5/16/2021 3:50 AM	151	Babcock	Residential-R2	False Alarm	D206	Initially Reported%26%2358; Fire alarm 2nd floor in room D206 Status on Arrival%26%2358; In trouble Actions Performed%26%2358; Checked panel after UAPD call me out and found a trouble after they had reset the panel I went to the room and found the device disconnected I reconnected the device and cleared the pa Cause of Alarm%26%2358; dust from demo of walls in bathroom Status on Departure%26%2358; panel and device back to normal.	134
5/24/2021 12:40 AM	123	Pueblo De La Cienega	Residential-R2	False Alarm		292 Initially Reported%26%2358; Fire alarm Status on Arrival%26%2358; In alarm Actions Performed%26%2358; Painter from Res Life notified us he was sanding in the room. Checked room, no smoke/fire Cause of Alarm%26%2358; Res Life Painter using sander on drywall in room Status on Departure%26%2358; Cleared alarm, instructed painter not to use electric sander as it creates too much dust.	135
6/2/2021 11:45 AM	8	Gila	Residential-R2	False Alarm	na	UAPD in building due to fire panel beeping. FLS informed of dust being the issue %26amp; UAPD reset panel.	136
6/3/2021 2:09 AM	31	Cochise	Residential-R2	False Alarm		119 Res Life custodial were cleaning and hit the smoke detector	137
7/14/2021 3:40 PM	121	Villa del Puente	Residential-R2	False Alarm	na	UAPD dispatch called asking for CDOC presence at VDP due to a fire alarm sounding and UAPD officers not having access to check a room. UAPD dispatch called CDOC again after a few minutes stating that UAPD access UAPD Case Number V211950051	138
7/26/2021 5:46 AM	118	La Paz	Residential-R2	False Alarm	L225	False Alarm Device ID%26%2358; M3-18 Device Location%26%2358; In room L-225 Initially Reported%26%2358; Fire alarm Status on Arrival%26%2358; Alarm silenced by UAPD Actions Performed%26%2358; Checked room, no smoke/fire Cause of Alarm%26%2358; Custodial cleaning	140
7/29/2021 6:00 AM	132	Arbol De La Vida	Residential-R2	False Alarm	By C412	Initially Reported%26%2358; Fire alarm Building C level 4 By room 412 Status on Arrival%26%2358; In alarm Actions Performed%26%2358; checked are no smoke no fire tried to reset the system and failed I checked the device and found water in the device I removed the device and checked 4 more devices and fore 2 others w Cause of Alarm%26%2358; water damage from AC units drains were plugged. Status on Departure%26%2358; devices removed and panel in trouble from 3 missing devices. Panel back on line	141
8/2/2021 6:30 AM	8	Gila	trouble		In 202	Nature%26%2358; Trouble Device ID%26%2358; M2-8 Device Location%26%2358; In room 202 Initially Reported%26%2358; Device reported No Answer Status on Arrival%26%2358; No Answer Actions Performed%26%2358; Replaced pull station Cause of Alarm%26%2358; Device went bad Status on Departure%26%2358; Panel clear	142
8/2/2021 6:00 AM	167a	Honors Village Dorms	Residential-R2	False Alarm	facp	Fire panel was beeping with trouble light on. GCD contacted fire safety to get more info or to resolve issue.	143
8/10/2021 5:50 PM	61a	East Stadium	Residential-R2	False Alarm	na	There were 3 room leaks last night at the stadium, 375, 245, and 229 RA called CDOC to inform that a fire alarm went off at Stadium Hall at 11%26%2358:50pm, and that UAPD responded to the building. UAPD Officer Timpani informed RA that the Fire Alarm went off due to a leak in Sierra Ha	144
8/12/2021 2:31 PM	85a	La Aldea	False Alarm		411	GRA called CDOC about a fire alarm going off in La Aldea 411 without any form of fire or smoke. UAPD stated there was no visible cause of what set off the alarm. Maintenance request placed by GRA for later inspection. UA	145
8/12/2021 1:36 AM	34	Yavapai	Residential-R2	False Alarm	1st floor	Smoke detector on first floor going off for an unknown reason. UAPD arrived to reset fire panel.	146
8/16/2021 3:43 PM	83/84	Arizona/Sonora	Residential-R2	False Alarm	11th Floor Stairwell (Electrical area)	Building wide fire alarm dump - CDOC 2/GCD Julia contacted CDOC 1. Nothing was found from alarm trigger. UAPD Case Number V212280083	147
8/19/2021 1:17 AM	121	Villa Del Puente	Residential-R2	False Alarm		391 Cause of Alarm%26%2358; dirty smoke detector	148
8/18/2021 12:00 PM	151	Babcock	Residential-R2	False Alarm	b101	CD called to inform that UAPD had responded earlier in the day to a smoke alarm that had gone off in the kitchen while resident was cooking.	149
8/17/2021 9:30 PM	123	La Cienega	Residential-R2	False Alarm	LCIN 1st floor - outside of room 149	CD contacted CDOC that fire alarm was triggered around 4%26%2358:30am for a building wide dump due to smoke identified in the hallway- no smoke was found. Officers said rain may have triggered it. UAPD Case Number V212290002	150
8/21/2021 8:41 PM	121	VDP	Residential-R2	False Alarm	VDP 2nd floor hallway	RA called CDOC because alarm was going off after plastic cover had been bumped on fire pull. CDOC asked RA to replace the plastic lid and the alarm stopped.	151
8/23/2021 12:10 AM	132	Arbol De La Vida	Residential-R2	False Alarm	B100 Main Lobby North	Fire alarm Status on Arrival%26%2358; UAPD was in process of resetting alarm. Actions Performed%26%2358; Spoke with UAPD, no smoke/fire Cause of Alarm%26%2358; Person pulled pull station Status on Departure%26%2358; Panel clear	152
8/21/2021 3:40 PM	85a	La Aldea	Residential-R2	False Alarm		117 UAPD could not reset alarm Status on Arrival%26%2358; In alarm, detector normal Actions Performed%26%2358; Reset fire alarm panel Cause of Alarm%26%2358; UAPD reported could not ascertain why alarm went off Status on Departure%26%2358; Panel Clear	153



Table 1

1/1/2020	5:53:00 AM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	na		Unknown reason					
1/1/2020	6:34:00 AM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Fire Pump		Fire pump in alarm					
1/14/2020	11:23:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 107		Unknown					
1/17/2020	2:20:00 AM		85 Coronado Residence hall	RESIDENTIAL - R2	False Alarm		743	Burnt macaroni and cheese					
1/17/2020	2:30:00 PM		85 Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 860		Burnt food					
1/18/2020	6:45:00 PM		132 Arbol De La Vida	RESIDENTIAL - R2	False Alarm	4th floor room		Burnt food					
1/20/2020	5:12:00 AM		8 Gila Residence Hall	RESIDENTIAL - R2	Nuisance Alarm	Across from room 120		UAPD responded to adjust the fire alarm pull station cover.					
1/20/2020	9:57:00 PM		118 Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	B107 aned B110		Burnt popcorn					
1/21/2020	8:18:00 PM		118 Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	C202		Unknown					
1/21/2020	11:18:00 AM		131 Likins Hall	RESIDENTIAL - R2	False Alarm	Room 633 and then room 638a		Custodial Steam cleaning carpets					
1/25/2020	1:54:00 AM	83/84	Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	room 219		Burnt food					
1/25/2020	2:42:00 PM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	room 1057		Burnt popcorn					
1/26/2020	12:00:00 AM	83/84	Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	room 711		No source was found that started the alarm.					
1/26/2020	4:54:00 AM		85 Coronado Residence hall	RESIDENTIAL - R2	False Alarm	room 232		Burnt ramen in room					
1/26/2020	9:52:00 AM		151 Babcock	RESIDENTIAL - R2	False Alarm	room D320		Unknown					
1/27/2020	7:05:00 PM	7/7a	Manzanita/ Mohave Residence Halls	RESIDENTIAL - R2	Drill	na		Fire drill					
1/27/2020	7:51:00 PM	52/53	Greenlee/ Graham Residence Halls	RESIDENTIAL - R2	Drill	na		Fire drill					
1/29/2020	6:29:00 PM	59/60	Stadium Complex - Pinal/Navajo	RESIDENTIAL - R2	Drill	pull station		Fire drill					
1/29/2020	7:25:00 PM	83/84	Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	Drill	pull station		Fire drill					
1/29/2020	7:01:00 PM		121 Villa Del Puente	RESIDENTIAL - R2	Drill	pull station		Fire drill					
1/3/2020	7:56:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 322		UAPD could not pinpoint reason.					
1/30/2020	1:14:00 AM		9 Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm	level 3		Burning rubber smell could not pinpoint location smell dissipated.					
1/31/2020	2:29:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Drill	na		Fire drill					
1/31/2020	3:43:00 PM	167a	UA Honors Village Residence	RESIDENTIAL - R2	Drill	na		Fire drill.					
2/1/2020	3:57:00 PM	85a	La Aldea	RESIDENTIAL - R2	False Alarm	Room 410		Batteries in smoke detector					
2/11/2020	5:21:00 PM		135 Pima Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen		Burnt bacon.					
2/11/2020	12:51:00 AM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Fire panel		No reason provided.					
2/11/2020	1:55:00 AM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Fire panel		No reason provided.					
2/12/2020	11:05:00 AM	83/84	Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	8th floor AZ in room 824		Resident had an E-cig smoking in the room.					
2/12/2020	8:56:00 PM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm		4075	Cooking.					
2/13/2020	10:41:00 PM		85 Coronado Residence hall	RESIDENTIAL - R2	False Alarm		733	Unknown					
2/15/2020	1:08:00 AM	7/7a	Manzanita/ Mohave Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	Between 501-523		Student bumped into pull station.					

2/15/2020	8:08:00 PM		9	Maricopa Residence Hall	RESIDENTIAL - R2	False Alarm		338	Humidifier				
2/15/2020	6:49:00 PM		85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm		657	Unknown				
2/16/2020	1:28:00 AM	167a		UA Honors Village Residence	RESIDENTIAL - R2	False Alarm		1023	Burnt popcorn				
2/17/2020	7:16:00 PM		5	Coconino Residence Hall	RESIDENTIAL - R2	False Alarm	Kitchen 100K		Cooking in kitchen.				
2/19/2020	9:05:00 PM	83/84		Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 822		Unknown-no smoke no fire after entry. 1st call 8:55pm.				
2/19/2020	12:20:00 PM	85a		La Aldea	RESIDENTIAL - R2	False Alarm	Room smoke detector		Unknown - battery operated smoke				
2/2/2020	5:34:00 PM	85a		La Aldea	RESIDENTIAL - R2	False Alarm	Room 257		Unknown - malfunction?				
2/2/2020	7:11:00 PM		118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Room a206		Unknown				
2/2/2020	9:05:00 AM	167a		UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Room 2070		Unknown				
2/21/2020	11:13:00 PM	83/84		Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 309		Unknown				
2/21/2020	4:10:00 AM	85a		La Aldea	RESIDENTIAL - R2	False Alarm	Room 410		Unknown				
2/22/2020	5:11:00 PM	167a		UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Room 1043		Steam from cooking				
2/23/2020	1:49:00 PM	85a		La Aldea	RESIDENTIAL - R2	False Alarm	Room 259		Cooking				
2/27/2020	2:32:00 PM	83/84		Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	By room 220		Device hit by custodian per HMS report - replaced cover				
2/27/2020	3:20:00 PM		85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	8th floor in room 829		Cooking with hot plate				
2/29/2020	5:15:00 PM	167a		UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Room 4056		Burnt food.				
2/3/2020	12:40:00 AM	50/50a		Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	False Alarm	Room 310		Hair straightener.				
2/4/2020	12:44:00 PM	83/84		Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	By front desk		pull station cover off base				
2/5/2020	10:27:00 PM		85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm	Room 257		Burnt food.				
2/7/2020	12:48:00 PM	79/79a		Huachuca/ Kaibab Residence Hall	RESIDENTIAL - R2	False Alarm	By room 247		Burnt pizza				
2/7/2020	2:03:00 PM	83/84		Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm		808	Burnt marshmallow in microwave.				
2/7/2020	2:16:00 PM	85a		La Aldea	RESIDENTIAL - R2	Fire	Room 419b		Light burst in restroom.				
2/7/2020	2:38:00 PM		85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm		464	Unknown				
2/9/2020	1:45:00 PM	83/84		Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Kitchen 112		Cooking				
3/1/2020	9:23:00 PM	167a		UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Room 6052		Burnt food.				
3/15/2020	10:05:00 PM	83/84		Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	Room 713		Burnt popcorn				
3/15/2020	9:05:00 PM	85a		La Aldea	RESIDENTIAL - R2	False Alarm		416	Believed that glade plugin may have set off the detector, no case # given.				
3/19/2020	10:19:00 PM		10	Yuma Residence hall	RESIDENTIAL - R2	False Alarm		211	Burnt food				
3/19/2020	9:59:00 PM		85	Coronado Residence hall	RESIDENTIAL - R2	False Alarm		348	Burnt bagel				
3/2/2020	11:00:00 PM		123	Pueblo De La Cienega	RESIDENTIAL - R2	False Alarm	Room 309		Burnt popcorn				
3/28/2020	10:29:00 PM	167a		UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Room 2061		Burnt food				
3/30/2020	3:21:00 PM	167a		UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Room 2061		Burnt food - case V200900033				
3/31/2020	8:44:00 PM	167a		UA Honors Village Residence	RESIDENTIAL - R2	False Alarm		4119	Burnt food				
3/8/2020	9:38:00 PM	83/84		Sonora/ Arizona Residence Halls	RESIDENTIAL - R2	False Alarm	In room smoke 4th floor		Unknown				

4/10/2020	10:41:00 PM	50/50a	Santa Cruz/ Apache Residence Halls	RESIDENTIAL - R2	Nuisance Alarm	2nd fl e west side stairwell	Pull station cover knocked					
4/14/2020	10:08:00 AM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	4119	Burned food while cooking					
4/23/2020	5:33:00 PM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	room 1049	UAPD determined the source was too much steam.					
4/3/2020	4:02:00 PM	167a	UA Honors Village Residence	RESIDENTIAL - R2	False Alarm	Room 2055	Burnt food					
4/28/2020	12:34:00 PM	118	Colonia De La Paz Residence Hall	RESIDENTIAL - R2	False Alarm	Elevator equipment C-110 smoke	Custodial had water on floor that leaked onto device.					
5/15/20 14:09:46	5/15/20 14:11:34	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	5/13/2020	17:11	121	Villa del Puente	Residential-R2	False Alarm	Unknown at this time		CD called to inform CDOC that UAPD was in the building due to fire panel alarm. Building was not evacuated.
5/18/20 10:53:25	5/18/20 10:56:28	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	5/16/2020	09:23 am	85a	La Aldea	Residential-R2	False Alarm		121	GRA reported UAPD in building for apartment fire alarm. UAPD determined cause was humidifier. Building was not evacuated.
5/18/20 10:56:31	5/18/20 10:57:18	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	5/15/2020	01:53 PM	85a	La Aldea	Residential-R2	False Alarm		403	Office Specialist called to notified that UAPD had responded to an apartment alarm going off. UAPD could not determine cause and building was not evacuated.
5/19/20 14:56:28	5/19/20 14:57:39	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	5/19/2020	14:04 pm	123	Pueblo De La Cienega	Residential-R2	False Alarm	By room 340		Custodial was steam cleaning by air intake setting off the duct detector
5/27/20 14:45:10	5/27/20 14:46:45	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	5/26/2020	07:04 am	85A	La Aldea	Residential-R2	Nuisance Alarm	125c		A fire alarm in a resident's room wouldn't stop beeping because the battery was low. La Aldea's front desk ran out of the appropriate batteries. Permission to call maintenance was approved. HMS ON CALL RESOLVED.
6/2/20 14:58:00	6/2/20 14:58:53	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	5/28/2020	01:36 pm	167a	Honors Village	Residential-R2		Room 5022		The fire alarm system in apartment 5022 went off. UAPD responded and reset the alarm.
6/8/20 14:54:18	6/8/20 14:55:00	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	6/4/2020	11:15 am	167a	Honors Village	Residential-R2	False Alarm		3022	Building CD called to inform CDOC that HNRV fire alarm was activated due to painters spraying over the smoke detector. Building not evacuated. UAPD reset alarm.
7/7/20 13:14:04	7/7/20 13:15:18	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	7/6/2020	09:18 pm	85a	La Aldea	Residential-R2		Room 416		UAPD responded to assist in resetting the smoke detector in the vacant room. UAPD determined that the smoke detector was not working properly and removed the battery to prevent it from ringing. HMS GMM has replaced smoke detector today as per work order 180712.
8/17/20 12:25:55	8/17/20 12:28:35	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/17/2020	3:28am	132	Arbol de la Vida	Residential-R2	Nuisance Alarm	By B4		RAOD called and said a resident set off the fire alarm on a floor. CDOC requested RAOD call UAPD to assist. When RA called back, they explained that a resident knocked the box off fire alarm pull station.

8/20/20 14:46:11	8/20/20 14:47:16	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/20/2020	1:43pm	83/84	Arizona/Sonora	Residential-R2	False Alarm	Room 413	Cause of Alarm: Resident was cooking Mac and Cheese with no water and burnt the food. Status on Departure: Panel clear
8/24/20 13:40:56	8/24/20 13:40:56	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/22/2020	12:40am	122	Posada San Pedro	Residential-R2	False Alarm	359	RA reported that UAPD was in building responding to fire alarm. Someone burnt rice in their room. See IR
8/24/20 13:42:27	8/24/20 13:42:27	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/21/2020	3:15pm	34	Yavapai		Nuisance Alarm	na	DA forgot to report UAPD resetting fire panel previous day at 5:15 PM. No known cause. IR filed.
8/24/20 13:57:12	8/24/20 13:59:03	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/20/2020	7:39pm	79/79a	Kaibab/Huachuca	Residential-R2	Nuisance Alarm	110	DA called to report what sounded like a fire alarm/ loud beeping coming from KAHU-110. The noise had stopped by the time CDOC spoke with DA. The DA could not confirm the source of the beeping noise. The building was not evacuated and fire panel was not ringing.
8/25/20 11:09:33	8/25/20 11:09:33	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/24/2020	8:24pm	167a	Honors Village	Residential-R2	False Alarm	Room 4077	The fire panel went off due to residence cooking in their apartment kitchen. UAPD responded.
8/25/20 12:56:22	8/25/20 12:57:34	<a href="mailto:dorland@email.arizona.edu">dorland@email.arizona.edu</a>	Michael Dorland	8/20/2020	7:39pm	79-79a	Kaibab-Huachuca	Residential-R2	Nuisance Alarm	110	DA called to report what sounded like a fire alarm-loud beeping coming from KAHU-110. The noise had stopped by the time CDOC spoke with DA. The DA could not confirm the source of the beeping noise. The building was not evacuated and fire panel was not ringing.
8/27/20 11:02:08	8/27/20 11:02:08	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/26/2020	3:01pm	52/53	Graham/Greenlee	Residential-R2	Nuisance Alarm	na	RA called because fire alarm from alarm case went off and UAPD responded to help close it.
8/31/20 9:42:08	8/31/20 9:42:08	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/28/2020	07:20am	83/84	Arizona/Sonora	Residential-R2	False Alarm	Room 826	Checked 8th floor in room 826 smoke detector in alarm and found resident vaping in room I had the device and panel reset and cleared.
8/31/20 14:02:31	8/31/20 14:02:31	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/30/2020	3:40pm	167a	Honors Village	Residential-R2	False Alarm	Room 1049	Smoke/steam from cooking set off fire alarm. Building was evacuated efficiently.
9/1/20 13:26:27	9/1/20 13:26:27	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	8/31/2020	4:45pm	167a	Honors Village	Residential-R2	False Alarm	Apartment 4072	PM reported the fire alarm went off in Apartment 4072. A resident had been cooking potatoes and the smoke from cooking set off the alarm.
9/8/20 15:13:37	9/8/20 15:13:37	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/5/2020	12:29am	83/84	Arizona/Sonora	Residential-R2	False Alarm	na	Multiple calls between RA and CDOC. Full building evacuation via fire alarm. UAPD responded but could not provide information about cause of alarm or shut off the strobes. Neither TFD nor fire safety said they can do those things. Eventually CDOC got fire safety to send someone to address the strobes.

9/8/20 15:16:47	9/8/20 15:16:47	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/4/2020	6:51pm	132	Arbol de la Vida	Residential-R2	False Alarm	B209	Multiple calls between CD, RA, and DA about room fire alarm. neither UAPD nor fire safety said it was something they could fix, CDOC gave DA permission to call ERLM.	
9/8/20 15:20:43	9/8/20 15:20:43	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/4/2020	2:40pm	167a	Honors Village	Residential-R2	False Alarm	4004	RA reported resident set-off room fire alarm due to a hair appliance. UAPD responded	
9/8/20 15:22:37	9/8/20 15:22:37	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/6/2020	2:38am	50/50a	Apache-Santa Cruz	Residential-R2	False Alarm	308	UAPD called CDOC to notify them that they had just responded to a fire alarm in Apache. UAPD rest the alarm, believes cause was dust or something blowing around from the AC. Building is currently empty.	
9/10/20 11:11:38	9/10/20 11:12:29	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/10/2020	12:15pm	83/84	Arizona-Sonora	Residential-R2	False Alarm	9th floor	RA called because the strobe light from the fire alarm was still going off in the restroom. CDOC instructed RA to put a sign in case someone has epilepsy and that CDOC would follow up with building CDs to get it fixed. (9th floor, Sonora side)	
9/14/20 14:42:29	9/14/20 14:43:38	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/11/2020	1:26pm	8	Gila	Residential-R2	False Alarm	Community Kitchen	RA called to inform CDOC that UAPD was in the building disarming a fire alarm that was sounding due to cooking in the community kitchen. UAPD opening the windows to allow the smoke out and did not provide an event number.	
9/14/20 14:43:40	9/14/20 14:44:35	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/12/2020	11:07pm	31	Cochise	Residential-R2	False Alarm	227	DA called to inform CDOC 2 that a fire alarm was triggered from burnt popcorn in room 227.	
9/16/20 9:32:01	9/16/20 9:33:29	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/15/2020	11:30pm	85a	La Aldea	Residential-R2	Trouble	Room 2C 4009 Power Supply	received a call from Residence life Maintenance Ryan there was a beeping coming from the fire alarm panel I went out found the power supply had bad batteries changed them out and cleared the trouble Cause of Alarm: bad batteries	
9/16/20 12:10:46	9/16/20 12:11:39	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/15/2020	11:48pm	85	Coronado	Residential-R2	False Alarm	643	RAOD reported resident burned sausages in the microwave and fire alarm went off in the room. No fire or damages. UAPD arrived to set the alarm off.	
9/16/20 12:11:43	9/16/20 12:27:09	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/16/2020	12:13pm	79/79a	Kaibab/Huachuca	Residential-R2	False Alarm	3rd floor	RA reported the building fire alarm went off and everyone was evacuated from KAHU. UAPD stated it was set off from somewhere on the third floor but did not find a cause. UAPD found multiple bottles of alcohol on the third-floor hallways. IR submitted. v202590076	
9/17/20 11:40:04	9/17/20 11:41:30	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/15/2020	9:15am	151	Babcock	Residential-R2	False Alarm	B319	Checked room and found smoke detector removed I reinstalled the device I had the device reset and cleared. Cause of Alarm: cleaning of room dust	



9/17/20 12:14:13	9/17/20 12:15:40	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/16/2020 7:15pm	79/79a	Kaibab/Huachuca	Residential-R2	False Alarm	1st floor	Student Coordinator called to give CDOC the case number after UAPD arrived to assist with a fire alarm that went off near the front desk around 5:45pm. V202600047	
9/18/20 14:25:06	9/18/20 14:26:05	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/17/2020 3:33pm	167a	Honors Village	Residential-R2	False Alarm	1012	PM reported fire alarm went off in the HNRV room after resident burnt chicken nuggets with bbq sauce in the microwave. UAPD responded and turned off alarm.	
9/18/20 14:26:07	9/18/20 14:27:30	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/17/2020 11:47am	59/60	Residence Halls/ Navajo-Pinal Hall	Residential-R2	False Alarm	Lowell-Stevens kitchen	Burn food on griddle	
9/18/20 15:15:31	9/18/20 15:16:25	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/18/2020 2:09pm	83/84	Arizona/Sonora	Residential-R2	False Alarm	706	Resident was doing her hair with a at home perm solution, this solution caused the smoke detector to go in to alarm.	
9/22/20 14:23:22	9/22/20 14:24:08	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/21/2020 9:13am	131	Likins	Residential-R2	False Alarm	A113	Res. Life maintenance was replacing a bad motor in the air handler, upon restart dust in the unit caused the duct detector to go in to alarm.	
9/23/20 11:24:04	9/23/20 11:24:49	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/22/2020 9:02pm	50/50a	Apache/Santa Cruz	Residential-R2	False Alarm	522	AZSO RAOD called to report a fire alarm had gone off in one resident's room. UAPD responded and building did not evacuate. Cause unknown, RA to write IR.	
9/25/20 10:08:05	9/25/20 10:08:58	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/25/2020 9:15am	79/79a	Huachuca/Kaibab Residence Hall	Residential-R2	False Alarm	By 302	Custodial using sanitation machine. Mist caused smoke detector to go off	
9/25/20 11:25:35	9/25/20 11:26:27	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/25/2020 4:00am	83/84	Arizona/Sonora	Residential-R2	False Alarm	na	RAOD called to report an alarm going off behind the AZSO front desk that seemed to be coming from the fire panel/telecase. CDOC advised RA to call UAPD to have them shut off the alarm and identify the issue. UAPD did shut off alarm and handle issue.	
9/28/20 10:58:49	9/28/20 10:59:57	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/27/2020 10:30pm	118	La Paz	Residential-R2	False Alarm	B109	Fire Alarm 1st floor room B109 East Smoke detector - went to room removed and cleaned device and reset panel. Cause of Alarm: dirty smoke detector.	
9/30/20 9:38:48	9/30/20 9:39:57	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/30/2020 5:30am	83/84	Arizona-Sonora	Residential-R2	False Alarm	411	RA reported UAPD responded to a fire alarm going off in a room. UAPD could not find the cause of the alarm and set the alarm off	
9/30/20 9:44:15	9/30/20 9:45:10	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/30/2020 12:10am	132	Arbol de la Vida	Residential-R2	False Alarm	na	RA reported UAPD responded to the building due to a fire panel alarm going off. UAPD discovered the lights inside the VIDA elevator were not working. UAPD set the alarm off and fixed the issue.	
10/5/20 15:15:16	10/5/20 15:16:10	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	9/30/2020 5:42pm	83/84	Arizona-Sonora	Residential-R2	False Alarm	319	RA reported fire alarm went off in room. Alarm was set off due to resident straightening hair which caused the smoke. UAPD responded and set the alarm off.	
10/5/20 15:30:18	10/5/20 15:31:46	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/3/2020 2:41pm	132	Arbol de la Vida	Residential-R2	False Alarm	na	DA called about fire panel going off.	

10/5/20 15:33:12	10/5/20 15:34:13	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/2/2020	10:04	132	Arbol de la Vida	Residential-R2	False Alarm	d515	CDOC contacted RAOD's for more information about fire alarm going off earlier as CDOC was not contacted. RAOD provided CDOC with room number but did not know what triggered the alarm or did not get a police event number. CDOC asked RAOD to write IR for CD's of building.	
10/5/20 15:36:17	10/5/20 15:37:34	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/4/2020	7:30pm	83/84	Arizona-Sonora	Residential-R2	False Alarm	6th floor AZ side	RAOD reported building fire alarm went off from 6th floor AZ side-unknown which room. UAPD reset fire alarm and checked room. See IR.	
10/5/20 15:37:37	10/5/20 15:38:27	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/5/2020	2:36am	85a	La Aldea	Residential-R2	Nuisance Alarm	416	Fire alarm was going off in apartment. It is unsure how it was set off. UAPD was unable to turn it off. GRA requested to call out. Call out approved.	
10/6/20 12:16:13	10/6/20 12:17:30	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/5/2020	4:11pm	118	La Paz	Residential-R2	False Alarm	na	UAPD concluded that it was a false alarm.	
10/15/20 13:57:11	10/15/20 13:59:06	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/14/2020	8:09pm	132	Arbol de la Vida	Residential-R2	False Alarm	Room on 4th floor - B Bldg	Fire alarm panel went off due to a "burnt Popeyes biscuit"	
10/19/20 10:52:42	10/19/20 10:53:49	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/18/2020	4:50pm	167a	UA Honors Village Residence	Residential-R2	False Alarm	5109	Set off by a waffle maker in 5109	
10/19/20 13:59:57	10/19/20 14:00:38	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/13/2020	11:20	83/84	Arizona-Sonora	Residential-R2	False Alarm	383	The fire alarm went off in room 383.	
10/21/20 12:28:01	10/21/20 12:28:48	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/19/2020	9:02pm	167a	Honors Village Room	Residential-R2	False Alarm	6101	Fire panel was going off for a singular room and RAOD was unsure what to do. CDOC instructed RA to call UAPD, who were actually already on scene. When UAPD knocked, resident in 6103 came out of their room and said they set off alarm by boiling water. 6101, the connecting room in the suite, is currently vacant.	
10/21/20 13:55:39	10/21/20 13:56:39	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/21/2020	3:51am	85	Coronado	Residential-R2	False Alarm	504	Fire alarm went off in room due to burnt pretzel bites. UAPD responded and reset panel. Building was not evacuated.	
10/27/20 13:11:47	10/27/20 13:13:46	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/24/2020	10:37pm	59/60	Navajo-Pinal Hall	Residential-R2	False Alarm	na	RAOD reported fire alarm sounded for 30 seconds, but strobes continued to flash. UAPD and TFD responded. UAPD determined cause came from stadium maintenance closet and reset alarm Building was evacuated. Note* Fire alarm came from building 58e Lowell Stevens from a gas discharge alarm. FM Fire Safety.	
10/27/20 13:16:15	10/27/20 13:17:11	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/23/2020	10:15pm	167a	Honors Village	Residential-R2	False Alarm	4042	RA called to report a smoke alarm that was set off in one room. UAPD reported to the scene, did not find a cause for the alarm, and reset the fire panel.	
10/27/20 13:18:09	10/27/20 13:19:01	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/23/2020	9:45am	167a	Honors Village	Residential-R2	False Alarm	4136	Fire alarm went off in room due to cooking on a hotplate. UAPD responded. Building was not evacuated.	

10/27/20 13:28:15	10/27/20 13:29:32	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/26/2020	1:18am	83/84	Arizona-Sonora	Residential-R2	False Alarm	Room number pending - 3rd floor in room smoke	RAOD reported call from UAPD about fire alarm going off in room because of overcooked food. UAPD reset alarm. UAPD did not provide RA with room number.
10/28/20 10:06:05	10/28/20 10:07:06	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/27/2020	2:37pm	83/84	Arizona/Sonora	Residential-R2	False Alarm	609	Investigate cause of alarm, reset FACP Cause of Alarm: Resident burnt food and set off smoke detector Status on Departure: Panel clear
10/28/20 11:29:19	10/28/20 11:30:32	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/28/2020	12:15am	118	La Paz	Residential-R2	False Alarm	BSMNT Main Water Flow	Initially Reported: Student hung jersey on sprinkler head and broke head. Instructed UAPD to call Residence Life to replace the sprinkler head and clean up the water that was released. Status on Arrival: Upon arrival to work the alarm was still on the system. Responded to the building to evaluate. The sprinkler had not been replaced and the main water valve had been closed. Actions Performed: Isolated section that had broken sprinkler head with 1st floor valve. Restored fire suppression to the rest of the building. Contacted Residence Life and they sent someone to change the head. Once changed, refilled that section and reset the fire panel. Cause of Alarm: Occupant broke sprinkler head by hanging clothing on it. Status on Departure: Panel clear and sprinkler service restored to the building.

10/28/20 15:18:35	10/28/20 15:19:35	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/28/2020	12:15am	118	La Paz	Residential-R2	False Alarm	Basement Water flow	Initially Reported: Student hung jersey on sprinkler head and broke head. Instructed UAPD to call Residence Life to replace the sprinkler head and clean up the water that was released. Status on Arrival: Upon arrival to work the alarm was still on the system. Responded to the building to evaluate. The sprinkler had not been replaced and the main water valve had been closed. Actions Performed: Isolated section that had broken sprinkler head with 1st floor valve. Restored fire suppression to the rest of the building. Contacted Residence Life and they sent someone to change the head. Once changed, refilled that section and reset the fire panel. Cause of Alarm: Occupant broke sprinkler head by hanging clothing on it. Status on Departure: Panel clear and sprinkler service restored to the building.	
10/30/20 14:01:06	10/30/20 14:01:56	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	10/30/2020	1:10pm	9	Maricopa	Residential-R2	False Alarm	332	cooking in room with induction cooktop	
11/3/20 13:34:38	11/3/20 13:36:08	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/1/2020	1:26pm	167a	Honors Village	Residential-R2	False Alarm	Rooms: 6032, 5032, 4032.	Toilet leak in 6032 emanated down to the rooms below. RAOD requested to call ACC. RAOD noted that the pipe broke in this apartment last week. When water got to 5032, it hit the fire alarm and triggered the alarm- UAPD and Fire responded to check and turn off. RAOD called ACC and submitted work order.	
11/6/20 10:25:06	11/6/20 10:26:31	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/6/2020	1:09am	50/50a	Apache-Santa Cruz	Residential-R2	False Alarm	Fire panel	Fire panel was continuously beeping with a trouble alarm. IA could not remember who to call. CDOC instructed them to notify UAPD. UAPD arrived and said there was a "power surge issue" with the panel, but silenced it and told the IA they would work on getting it fixed. CDOC 2 provided IA with CDOC 1 number for future.	
11/9/20 9:01:30	11/9/20 9:03:27	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/8/2020	4:49pm	132	Arbol de la Vida	Residential-R2	False Alarm	D409	DA called CDOC to report fire alarm going off. CDOC told DA to call UAPD and RAOD. CDOC requested DA call back when they obtain more information. Burnt Popcorn was the cause. checked room no fire smoke form popcorn I had cleared the room and had device and panel replaced Cause of Alarm: burnt popcorn	
11/10/20 9:50:19	11/10/20 9:51:53	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/4/2020	8:21am	50/50a	Santa Cruz/ Apache Residence Halls	Residential-R2	False Alarm	115		

11/10/20 14:54:49	11/10/20 14:57:08	hernands@email. arizona.edu	Sonia Hernandez	11/9/2020	12:41am	132	Arbol De La Vida	Residential-R2	False Alarm	B226c	CD Evans checked in with the other CD, and both had been asleep during the case. The UAPD officer stated with our RA that nothing seemed out of the ordinary and that after resetting the panel that everything had been fixed. Our apartments would be B225/B226.	
11/10/20 15:06:51	11/10/20 15:10:39	dorland@email.ar izona.edu	Michael Dorland	11/9/2020	12:41 am	132	Arbol De La Vida	Residential-R2	False Alarm	B226c	CD Evans checked in with the other CD, and both had been asleep during the case. The UAPD officer stated with our RA that nothing seemed out of the ordinary and that after resetting the panel that everything had been fixed. Our apartments would be B225/B226.	
11/10/20 15:12:39	11/10/20 15:13:36	dorland@email.ar izona.edu	Michael Dorland	11/9/2020	12:41 am	132	Arbol De La Vida	Residential-R2	False Alarm	B226c	CD Evans checked in with the other CD, and both had been asleep during the case. The UAPD officer stated with our RA that nothing seemed out of the ordinary and that after resetting the panel that everything had been fixed. Our apartments would be B225-B226.	
11/10/20 15:40:10	11/10/20 16:08:47	dorland@email.ar izona.edu	Michael Dorland	11/9/2020	12:41 am	132	Arbol De La Vida	Residential-R2	False Alarm	B226c	CD Evans checked in with the other CD, and both had been asleep during the case. The UAPD officer stated with our RA that nothing seemed out of the ordinary and that after resetting the panel that everything had been fixed. Our apartments would be B225-B226.	
11/10/20 16:09:09	11/10/20 16:11:13	dorland@email.ar izona.edu	Michael Dorland	11/9/2020	12:41 am	132	Arbol De La Vida	Residential-R2	False Alarm	B226c	CD Evans checked in with the other CD, and both had been asleep during the case. The UAPD officer stated with our RA that nothing seemed out of the ordinary and that after resetting the panel that everything had been fixed. Our apartments would be B225-B226.	
11/10/20 16:11:37	11/10/20 16:12:08	dorland@email.ar izona.edu	Michael Dorland	11/9/2020	12:41 am	111	testing	Residential-R2	False Alarm	over there	this is a test.	
11/10/20 16:12:31	11/10/20 16:12:59	dorland@email.ar izona.edu	Michael Dorland	11/9/2020	12:41 am	132	Arbol De La Vida	Residential-R2	False Alarm	B226c		
11/12/20 14:13:16	11/12/20 14:14:13	hernands@email. arizona.edu	Sonia Hernandez	11/11/2020	7:31pm	83/84	Arizona-Sonora	Residential-R2	False Alarm	1st floro kitchen	Resident burned potatoes in kitchen that triggered alarm.	
11/12/20 14:21:31	11/12/20 14:22:24	hernands@email. arizona.edu	Sonia Hernandez	11/11/2020	9:22pm	167a	Honors Village	Residential-R2	False Alarm	Community kitchen	Mike called to report the findings during a fire drill (burnt pizza in the community kitchen microwave) in the Honors Village.	
11/13/20 14:11:50	11/13/20 14:12:35	hernands@email. arizona.edu	Sonia Hernandez	11/13/2020	12:15am	7/7a	Manzanita-Mohave	Residential-R2	False Alarm	Kitchen	RA called to report the fire alarm going off in MZMO due to a fire extinguisher sprayed in the halls.	
11/16/20 16:21:29	11/16/20 16:22:25	hernands@email. arizona.edu	Sonia Hernandez	11/15/2020	17:00	83/84	Arizona-Sonora	Residential-R2	False Alarm	614	RA called to report UAPD in the building due to fire panel going off. Resident had burnt popcorn in the microwave and officers reset the alarm and left once no further issue was identified.	

11/16/20 16:23:50	11/16/20 16:24:29	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/16/2020	6:57	167a	Honors Village	Residential-R2	False Alarm	2061	Building evacuated due to fire alarm being set off by residents cooking tortillas. UAPD responded and all clear was given for reentry.
11/16/20 16:33:01	11/16/20 16:33:51	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/15/2020	2:46am	83/84	Arizona-Sonora	Residential-R2	False Alarm	206	RAOD called to report the fire panel had gone off and UAPD/ Fire Dept. was on scene. Alarm went off due to burnt popcorn, Fire Dept. turned it off and left after seeing no other issues. RA instructed to create IR.
11/18/20 15:13:26	11/18/20 15:14:18	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/17/2020	5:20	34	Yavapai	Residential-R2	False Alarm	Community Kitchen	UAPD responded to reset fire panel after resident burned their food in the community kitchen.
11/30/20 11:03:38	11/30/20 11:04:22	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/24/2020	1:18pm	57	Hopi	Residential-R2	False Alarm	63	Student vacuuming and vacuum expelling dust.
12/1/20 10:59:42	12/1/20 11:02:58	<a href="mailto:hernands@email.arizona.edu">hernands@email.arizona.edu</a>	Sonia Hernandez	11/25/2020	9:30pm	132	Arbol de la Vida	Residential-R2	False Alarm	na	Outgoing call placed to UAPD in regards to fire alarm panel going off. MOD notified and UAPD responded to the hall. UAPD set off whole building alarm in order to reset the system as no issues were present.

